Gmail

anju meena <bohra.02anju@gmail.com>

CPWD - Redevelopment of General Pool Residential Accommodation at Sriniwaspuri New Delhi-Electrical load assessment and approval of local authority

1 message

Subrata Barman <deleerped@cpwd.gov.in> Fri, Apr 5, 2019 at 3:25 PM
To: bohra.02anju@gmail.com, anjucpwd93@gmail.com

-------- Original Message --------
From: Manoj.Su.Kumar@relianceada.com
Date: Mar 18, 2019 3:01:53 PM
Subject: Fw: CPWD - Redevelopment of General Pool Residential Accommodation at Sriniwaspuri New Delhi-Electrical load assessment and approval of local authority
To: deleerped@cpwd.gov.in

FYI please

Thanking you.

Regards

Manoj Kumar
Key Consumer Cell - Execution Dept. | BSES Rajdhani Power Ltd
1st Floor, D Block, BSES Bhawan, Nehru Place, Delhi-110019, India
Ph: 011 39999552 | Mob: 9350130066

----- Forwarded by Manoj Su Kumar/REL/RelianceADA on 18-03-2019 15:03 -----

From:	Manoj Su Kumar/REL/RelianceADA
To:	deleerped@cpwd.gov
Cc:	Sanjay N Arora/REL/RelianceADA@INFOCOMM, Manmeet Singh/REL/RelianceADA@INFOCOMM
Date:	18-03-2019 14:49
Subject:	Fw: CPWD - Redevelopment of General Pool Residential Accommodation at Sriniwaspuri New Delhi-Electrical load assessment and approval of local authority

---

Dear Sir

This is regarding new 33 KV substation required for 45 MW proposed load for CPWD redevelopment project at Sriniwaspuri. We wish to update that this proposal has been discussed in our technical feasibility committee. The conclusion may be briefed as following:

1. At least one 33/11 KV Substation needs to be established for load requirement.
2. However at present there is no capable source available in nearby network. For the load amounting 45 MW, *DTL source would be required to feed the substation on 33 KV, without which BRPL can not assure any supply provision.* We are informed that DTL is planning to set up a 220/33 KV substation near Kalkaji mandir metro station. Which shall be most suitable source for your project. DTL officials are already taking up with DDA for land acquisition. Though we shall take up the matter with DTL on our own level but request to CPWD also to pursue DTL for the same.
3. This substation supply shall be used by both BRPL & CPWD.
4. For setting up 33/11 KV S/Stn, a plot measuring 3600 sqm (60Mx60M) shall be required, which needs to be handed over to BRPL (without any obstacle like trees, any utility, drain, any setback requirement etc.) and should be good enough to start the grid construction work.
5. The proposed grid substation shall remain in custody of BRPL. 24x7 access shall be provided to BRPL personnel for operation & maintenance.

Regards

Manoj Kumar
Key Consumer Cell - Execution Dept. | BSES Rajdhani Power Ltd
1st Floor, D Block, BSES Bhawan, Nehru Place, Delhi-110019, India
Ph: 011 39999552 | Mob: 9350130066

The information contained in this electronic message (email) and any attachments to this email are intended for the exclusive use of the addressee(s) and access to this email by any one else is unauthorised. The email may contain proprietary, confidential or privileged information or information relating to Reliance Group. If you are not the intended recipient, please notify the sender by telephone, fax, or return email and delete this communication and any attachments thereto, immediately from your computer. Any dissemination, distribution, or copying of this communication and the attachments thereto (in whole or part), in any manner, is strictly prohibited and actionable at law. The recipient acknowledges that emails are susceptible to alteration and their integrity can not be guaranteed and that Company does not guarantee that any e-mail is virus-free and accept no liability for any damage caused by any virus transmitted by this email.

--
With Best Regards,

Subrata Barman
EE (E) , RPED

CPWD dt 4.5.18 (ceo 57873).pdf
188K