

### **Minutes of 672<sup>nd</sup> SEAC-1 Meeting Dated 18/07/2022**

The 672<sup>nd</sup> meeting of SEAC-1 was held in the Directorate of Environment, U.P. through dual-mode (physically/virtually) at 10:00 AM on 18/07/2022. Following members participated in the meeting:

- |    |                             |                             |
|----|-----------------------------|-----------------------------|
| 1. | Shri Rajive Kumar,          | Chairman, SEAC-1            |
| 2. | Dr. Ajai Mishra,            | Member, SEAC-1 (through VC) |
| 3. | Shri Om Prakash Srivastava, | Member, SEAC-1 (through VC) |
| 4. | Dr. Brij Bihari Awasthi,    | Member, SEAC-1 (through VC) |
| 5. | Shri Umesh Chandra Sharma,  | Member, SEAC-1              |
| 6. | Dr. Ratan Kar,              | Member, SEAC-1              |
| 7. | Shri Ashish Tiwari,         | Member-Secretary, SEAC-1    |

The Chairman welcomed the members to the 672<sup>nd</sup> SEAC-1 meeting which was conducted via dual-mode (virtually/physically). Nodal Officer, SEAC-1 informed the committee that the agenda has been approved by the Member Secretary, SEAC-1/Director Environment. Nodal Officer, SEAC-1 placed the agenda items along with the available file and documents before the SEAC-1.

1. **Stone, Gitti, Khanda & Boulder Mining at Gata No. 281 (Khand No.- 08), Village-Madorakhurd, Tehsil-Moth, Jhansi, Shri Ratan Singh Yadav, M/s Ratan Stone Gramodhyog Area-1.214 Ha. File No. 6014/Proposal No. SIA/UP/MIN/ 58853/2020**

#### **RESOLUTION AGAINST AGENDA NO. 01**

The project proponent/consultant did not appear. The committee discussed and deliberated that the project file should be closed and be opened only after request from the project proponent. The file shall not be treated as pending at SEAC. The matter will be discussed only after submission of online request on prescribed online portal.

2. **Sand Stone Mining at Araj No. 83 ऋ Village-Bhusi Patharaha, Tehsil-Lalganj Mirzapur., Smt. Sushma Mishra., Area – 2.424 Ha. File No. 6855/Proposal No. SIA/UP/MIN/ 70909/2022**

The committee noted that the matter was earlier listed in 633<sup>rd</sup> SEAC meeting dated 04/03/2022 and the project proponent did not appear in the meeting and the committee directed that project file should be closed and be opened only after request from the project proponent. The project proponent through online portal on 07/06/2022 has requested to list the matter in next SEAC meeting and the matter was listed in 672<sup>nd</sup> SEAC meeting dated 18/07/2022.

The consultant informed the committee that they are strictly following the rules, regulations and other instructions of QCI/NABET. A presentation was made by the project proponent along with their consultant M/s Environmental Research and Analysis, Lucknow (U.P. Based on the documents submitted and presentation made by the project proponent along with the consultant, the following facts have emerged: -

1. The terms of reference is sought for Sand Stone Mining at Araj No. 83 ऋ Village-Bhusi Patharaha, Tehsil-Lalganj Mirzapur, U.P., (Leased Area – 2.424 Ha.).
2. Salient features of the project as submitted by the project proponent:

1. On-line proposal No.	SIA/UP/MIN/70909/2022		
2. File No. allotted by SEIAA, UP	6855		
3. Name of Proponent	Smt. Sushma Mishra W/o - Shri Rajesh Kumar Mishra		
4. Full correspondence address of proponent and mobile no.	R/o- Vill.- Chandika, Tehsil – Sadar, District - Mirzapur, U.P.		
5. Name of Project	Building Stone (Sand Stone)Mining Project		
6. Project location (Plot/Khasra/Gata No.)	Araji No – 83 ऋ		
7. Name of River	NA		
8. Name of Village	Bhusi Pathraha		
9. Tehsil	Lalganj		
10. District	Mirzapur (U.P)		
11. Name of Minor Mineral	Building Stone (Sand Stone)Mining Project		
12. Sanctioned Lease Area (in Ha.)	2.424 Ha.		
13. Mineable Area (in Ha.)	2.0188 Ha.(Safety area 0.4052Ha.)		
14. Zero level mRL	NA		
15. Max. & Min mrl within lease area	Maximum mRL 164 mRL Minimum mRL 162 mRL		
16. Pillar Coordinates (Verified by DMO)	Pillar	Latitude(N)	Longitude(E)
	A	25°00'07.8"N	82°28'43.1"E
	B	25°00'07.8"N	82°28'48.9"E
	C	25°00'02.9"N	82°28'48.9"E
	D	25°00'02.8"N	82°28'43.1"E
17. Total Geological Reserves	7,32,944 m <sup>3</sup>		
18. Total Mineable Reserves	58,176 m <sup>3</sup> per year as per LOI		
19. Total Proposed Production	2,90,880 m <sup>3</sup>		
20. Proposed Production/year	58,176 m <sup>3</sup> per year		
21. Sanctioned Period of Mine lease	10 Year		
22. Total Mineable reserve for lease period of 10 years.	5,81,760 m <sup>3</sup> for lease period of 10 years.		
23. Production of mine/day	232.704 m <sup>3</sup> /day		
24. Method of Mining	Open cast, semi-mechanized		
25. No. of working days	250		
26. Working hours/day	8 hours/day		
27. No. Of workers	34		
28. No. Of vehicles movement/day	18-19 Vehicles movement/day		
29. Type of Land	Building Stone (Sand Stone)Mining Project		
30. Ultimate Depth of Mining	25.5 m for 5 years as per approved mining plan		
31. Nearest metalled road from site	NH-135 is about 6.36 km towards North-West direction from project site.		
32. Water Requirement	PURPOSE	REQUIREMENT (KLD)	
	Drinking water	0.44 KLD	
	Suppression of dust	3.06 KLD	
	Plantation	3.0 KLD	
	Others (if any)	-	
	Total	6.5 KLD (approx. )	
33. Name of QCI Accredited Consultant with QCI No And period of validity.	Environmental Research and Analysis, Lucknow (U.P) Certificate No. NABET/EIA/1922/RA 0200 and valid up to 30 Dec. 2022		
34. Any litigation pending against the project or land in any court	No		
35. Details of 500 m Cluster Map & certificate issued by Mining Officer	Letter No. 2936/Khanij/2021 date 30/12/2021		
36. Details of Lease Area in approved DSR	Letter No-375/M-228/2017(Khanij Niti-DSR) dated 02/06/2022		
37. Proposed EMP cost	Rs. 15,50,080/-		
38. Total Project cost	Rs. 95,00,000/-		
39. Length and breadth of Haul Road	170 m length and 6.0 m width		
40. No. of Trees to be Planted	3000		

41. Monitoring season	1 March 2022 to 31 May 2022
-----------------------	-----------------------------

3. The mining would be restricted to unsaturated zone only above the phreatic water table and will not intersect the ground water table at any point of time.
4. This project does not attract any of the general conditions applicable on mining projects specified in EIA Notification 14/09/2006.
5. The mining operation will not be carried out in safety zone of any bridge or embankment or in eco-fragile zone such as habitat of any wild fauna.
6. There is no litigation pending in any court regarding this project.
7. The project proposal falls under category-1(a) of EIA Notification, 2006 (as amended).

The consultant (EIA Coordinator) also submitted an affidavit dated 11/07/2022 mentioning is as follows:

1. I Dr. Vishnu Kumar Awasthi S/o Lt. R G Awasthi is EIA Coordinator of M/s Environmental Research and Analysis, Lucknow (U.P.), Accreditation Certificate No- NABET/ EIA/ 1922/RA 0200, valid till- 30/12/2022.
2. I have prepared TOR Project for the Proposal No. SIA/UP/MIN/70909/2022 (File No. - 6855) Proponent - Smt. Sushma Mishra W/o - Shri Rajesh Kumar Mishra of “Building Stone (Sand stone) Mining” located at Arajai No – 83 ऋ (Area- 2.424 Ha.) in Village: Bhushi Pathraha, Tehsil- Lalganj, District Mirzapur, Uttar Pradesh with my team.
3. I have personally visited the site of proposal.
4. I have satisfied with that all the necessary data/information required for TOR Project presentations are true and correct.
5. I certify that no mining activity has been undertaken on the project site for the present proposal.
6. I certify that this project has been uploaded for this first time on Parivesh portal. In case the project has been uploaded again due to any reason, the withdrawals of previous project have been accepted by SEIAA, UP on Parivesh Portal.
7. I certify that there is no mismatch between information/data provided on online application and hard copy/presentation submitted.

#### **RESOLUTION AGAINST AGENDA NO. 02**

**The committee discussed the matter and recommended to issue the standard terms of reference for the preparation of EIA as annexed at annexure-2 to the minutes. The committee also stipulated following additional TOR Points:**

#### **Additional TOR:**

1. To ensure proper monitoring, the project proponent/consultant should provide evidence in for of (A) Raw Data (B) Logbook of their site visit along with activities carried out during monitoring (C) Real time photographs showing monitoring machine, public, lab person etc.
2. EIA coordinator & FAE should give a photo affidavit during EIA presentation that they have personally visited the site & they have also taken all the mitigating measures for any critical issues involved in the project.
3. Combined KML of all mines in a cluster should be submitted at the time of EIA.
4. The details of equipment used for baseline monitoring alongwith its photograph mentioning date, time and geo coordinates for preparation of EIA report should be clearly displayed to the people present during public hearing and the complete details related to monitoring period must be mentioned in the minutes of public hearing.
5. The project proponent/Consultant should identify the core & buffer zone (2.5 km) of the mining site.

6. Agreement/ Consent between project proponent and competent authority/ landowner for haulage road from lease site to link road to be submitted at the time of EIA presentation.
7. Proponent/ Consultant should submit the plan/information along with technology (photographs of water sprinklers/ tankers) to be implemented for mitigating dust at source points in lease area and haulage road during operation activity/vehicular movement. Technology should be displayed at the time of EIA presentation.
8. Proposed plantation plan with area specific plant species, number of plants to be planted and place of plantation along with a proper map to be submitted at the time of EIA presentation.
9. Water requirement details along with source of water and the permission/ agreement with the concerning authority/ person to be submitted at the time of EIA presentation.
10. Proponent/consultant shall present TOR specific/additional conditions compliance, observation/suggestions raised during the public hearing and commitment made by the project proponent in a tabular form with a time bound plan at the time of EIA presentation.
11. Revised Corporate Social Responsibility (CSR) to be prepared as per the MoEF guidelines and present it at the time of EIA presentation.

**3. Stone, Khanda & Gitti, Boulder Mining at Arazi No.- 1097, Khand No. 6 Naya, 5 Purana, Village-Utiyan, Mahoba, Shri Rajendra Kumar Pandey., Area 0.809 Ha. File No. 6381/Proposal No. SIA/UP/MIN/ 64061/2021**

The committee noted that the matter was earlier listed in 649<sup>th</sup> SEAC meeting dated 05/05/2022 and the project proponent did not appear in the meeting and the committee directed that project file should be closed and be opened only after request from the project proponent. The project proponent through online portal on 14/06/2022 has requested to list the matter in next SEAC meeting and the matter was listed in 672<sup>nd</sup> SEAC meeting dated 18/07/2022.

The consultant informed the committee that they are strictly following the rules, regulations and other instructions of QCI/NABET. A presentation was made by the project proponent along with their consultant M/s Environmental Research and Analysis, Lucknow (U.P. Based on the documents submitted and presentation made by the project proponent along with the consultant, the following facts have emerged: -

1. The environmental clearance is sought for Stone, Khanda & Gitti, Boulder Mining at Arazi No.- 1097, Khand No. 6 Naya, 5 Purana, Village-Utiyan, Mahoba, U.P., (Leased Area 0.809 Ha.).
2. The terms of reference in the matter were issued by SEIAA, U.P. vide letter no. 279/Parya/SEIAA/6381/2021, dated 27/10/2021.
3. The public hearing was organized on 27/01/2022. Final EIA report submitted by the project proponent on 25/03/2022.
4. Salient features of the project as submitted by the project proponent:

1. On-line proposal No.	SIA/UP/MIN/64061/2021
2. File No. allotted by SEIAA, U.P	6381
3. Name of Proponent	Shri Rajendra Kumar Pandey S/o Shri Shiv Gopal Pandey
4. Full correspondence address of proponent and mobile no.	R/o - Azad Nagar, Kabrai District- Mahoba (U.P.)
5. Name of Project	Building Stone, Khanda, Boulder, Ballast (Gitti) Mining Project
6. Project location (Plot/Khasra/Gata No.)	Arazi No. 1097 (Khand No. – 6 Naya 5 Purana),
7. Name of River	NA
8. Name of Village	Utiyan
9. Tehsil	Sadar
10. District	Mahoba (U.P.)
11. Name of Minor Mineral	Building Stone, Khanda, Boulder, Ballast (Gitti) Mining Project
12. Sanctioned Lease Area (in Ha.)	0.809 Ha.
13. Mineable Area (in Ha.)	0.423 Ha. (Safety Margin 0.386 Ha. )

14. Zero level mRL	NA		
15. Max. & Min mrl within lease area	Maximum & Minimum mRL is 211 & 191 mRL respectively.		
16. Pillar Coordinates (Verified by DMO)	<b>Pillar</b>	<b>Latitude(N)</b>	<b>Longitude(E)</b>
	A	25°24'27.661"	79°56'08.017"
	B	25°24'27.380"	79°56'09.171"
	C	25°24'19.864"	79°56'08.588"
	D	25°24'19.902"	79°56'07.023"
17. Total Geological Reserves	1911242 m <sup>3</sup>		
18. Sanction Quantity as per LOI	40,000 m <sup>3</sup> per year as per LOI		
19. Total Proposed Production (in five year)	40,000 m <sup>3</sup> for one year		
20. Proposed Production/year	40,000 m <sup>3</sup> per year		
21. Sanctioned Period of Mine lease	10 Years as per LOI		
22. Proposed Production for 10 Years	4,00,000 m <sup>3</sup> for 10 years		
23. Proposed Production for 10 Years	4,00,000 m <sup>3</sup> for 10 years		
24. Production of mine/day	160.0 m <sup>3</sup> /day		
25. Method of Mining	Open cast, Semi Mechanized		
26. No. of working days	250		
27. Working hours/day	8 hours/day		
28. No. Of workers	18		
29. No. Of vehicles movement/day	13-15 Vehicles movement/day		
30. Type of Land	Building Stone(Khanda, Boulder, Ballast (Gitti) Mining Project		
31. Ultimate Depth of Mining	18.0 m as per approved mining plan		
32. Nearest metalled road from site	NH-76 is about 6.0 km towards South- East direction from the project site.		
33. Water Requirement	<b>PURPOSE</b>	<b>REQUIREMENT (KLD)</b>	
	Drinking water	0.28 KLD	
	Dust suppression	2.25 KLD	
	Plantation	1.0 KLD	
	Others (if any)	-	
	<b>Total</b>	<b>3.53 KLD Approx.</b>	
34. Name of QCI Accredited Consultant with QCI No And period of validity.	Environmental Research and Analysis, Lucknow (U.P) Certificate No. NABET/ EIA/ 1922/RA 0200 Valid up to 30 Dec, 2022		
35. Any litigation pending against the project or land in any court	No		
36. Details of 500 m Cluster Map & certificate issued by Mining Officer	Letter No. 7971/ MMC-30/2020-21 Date- 30/01/2021		
37. Details of Lease Area in approved DSR	DSR letter number: 1412/MMC-30-Khanij (2021-22) date- 26/08/2021		
38. Proposed EMP cost	Rs. 9,55,800/-		
39. Proposed Total Project cost	Rs. 1,20,00,000/-		
40. Length and breadth of Haul Road	250 m length and 6.0 m width		
41. No. of Trees to be Planted	1000		

5. The mining would be restricted to unsaturated zone only above the phreatic water table and will not intersect the ground water table at any point of time.
6. This project does not attract any of the general conditions applicable on mining projects specified in EIA Notification 14/09/2006.
7. The mining operation will not be carried out in safety zone of any bridge or embankment or in eco-fragile zone such as habitat of any wild fauna.
8. There is no litigation pending in any court regarding this project.
9. The project proposal falls under category-1(a) of EIA Notification, 2006 (as amended).

The consultant (EIA Coordinator) also submitted an affidavit dated 11/07/2022 mentioning is as follows:

1. I Vishnu Kumar Awasthi S/o Lt. R G Awasthi is EIA Coordinator of M/s Environmental Research and Analysis, Lucknow (U.P.), Accreditation Certificate No- NABET/ EIA/ 1922/RA 0200, valid till- 30/12/2022.
2. I have prepared EIA/EMP report for the Proposal No. SIA/UP/MIN/64061/2021 (File No. - 6381) Project Proponent- Shri Rajendra Kumar Pandey S/o Shri Shivgopal Pandey of Stone, Khanda & Gitti, Boulder Mining at Arazi No.- 1097, Khand No. 6 Naya, 5 Purana, Village-Utiyan, Mahoba, U.P., (Leased Area 0.809 Ha.) with my team.
3. I have personally visited the site of proposal.
4. I have satisfied with that all the necessary data/information required for EIA/EMP presentations are true and correct.
5. I certify that no mining activity has been undertaken on the project site for the present proposal.
6. I certify that this project has been uploaded for this first time on Parivesh portal. In case the project has been uploaded again due to any reason, the withdrawals of previous project have been accepted by SEIAA, UP on Parivesh Portal.
7. I certify that there is no mismatch between information/data provided on online application and hard copy/presentation submitted.
8. I state that all the TOR points have been complied and all the issues raised during public hearing have been properly addressed in EIA report.

**RESOLUTION AGAINST AGENDA NO. 03**

**The committee discussed the matter and recommended grant of environmental clearance for the project proposal along with general and specific conditions as annexed at Annexure-1 to these minutes. The committee also stipulated the following specific conditions:**

1. The project proponent shall install solar light in their site office.
2. During the submission of 6 monthly compliance reports, the project proponent should make sure that the periodically taken site photographs should also be annexed along with the compliance report.
3. Preference should be given to indigenous local species as per the consultation of the local district Forest Officer.
4. The maximum height of the bench should be 06 meters and the width of the bench should be at least twice the height of the bench as per the mine plan approval letter by DGM, U.P
5. In case the blasting is proposed during a mining operation, the project proponent needs to assess its impact on the displacement of human beings/wild animals/birds/other species, and the suitable measures proposed and taken for their rehabilitation and resettlement need to be clearly described in first 6 monthly compliance report.
6. The project proponent shall submit a final mine closure plan/Exit protocol for rehabilitation of mined-out land to match its surrounding land use 3years before the closure of the mine to SEIAA, UP and Department of Mines and Geology, UP for approval. The project proponent shall ensure the implementation of the approved plan under the supervision of the Dept. of Mines and Geology.
7. The project proponent shall plan and implement collection drain and siltation basins of adequate size to arrest the silt and sediment flow from the quarry area. The surface runoff rainwater harvesting and other water conservation measures on a long-term basis are to be taken in consultation with the Central/State Groundwater Board. The water so collected should be utilized for watering the haulage area, roads, and green belt development, etc.
8. The project proponent shall take all suitable measures to prevent pollution of groundwater and nearby water bodies in consultation with the State Pollution Control Board and consent to operate (if applicable) should be obtained from the State Pollution Control Board before the start of production from the mine.

9. Link Road from the quarry site to the main road shall be constructed as an all-weather road with blacktopping and maintained by the project proponent.
10. Vehicular emissions should be kept under control and regularly monitored. Suitable measures shall be taken for proper maintenance of vehicles used in a quarry operation and transportation.
11. The project proponent should explore the possibilities of rainwater harvesting.

**4. Stone, Khanda & Gitti, Boulder Mining at Arazi No. 935, Khand No. 02, Village - Makarbai, Tehsil-Sadar, Mahoba, Shri Rahul Singh., Area 3.643 Ha. File No. 7021/6366/Proposal No. SIA/UP/MIN/ 74509/2021**

The committee noted that the matter was earlier listed in 650<sup>th</sup> SEAC meeting dated 09/05/2022 and the project proponent did not appear in the meeting and the committee directed that project file should be closed and be opened only after request from the project proponent. The project proponent through online portal on 14/06/2022 has requested to list the matter in next SEAC meeting and the matter was listed in 672<sup>nd</sup> SEAC meeting dated 18/07/2022.

The consultant informed the committee that they are strictly following the rules, regulations and other instructions of QCI/NABET. A presentation was made by the project proponent along with their consultant M/s Environmental Research and Analysis, Lucknow, U.P. Based on the documents submitted and presentation made by the project proponent along with the consultant, the following facts have emerged: -

1. The environmental clearance is sought for Stone, Khanda & Gitti, Boulder Mining at Arazi No. 935, Khand No. 02, Village -Makarbai, Tehsil-Sadar, Mahoba, U.P., (Leased Area 3.643 Ha.).
2. The terms of reference in the matter were issued by SEIAA, U.P. vide letter no. 231/Parya/SEIAA/6366/2021, dated 11/10/2021.
3. The public hearing was organized on 27/01/2022. Final EIA report submitted by the project proponent on 30/03/2022.
4. Salient features of the project as submitted by the project proponent:

1. On-line proposal No.	SIA/UP/MIN/74509/2021		
2. File No. allotted by SEIAA, U.P	7021/6366		
3. Name of Proponent	Proponent- Shri Rahul Singh S/o Shri Rajendra Kr. Singh		
4. Full correspondence address of proponent and mobile no.	R/o- Raja Nivas ,Kalukuan, Thana-Kotwali,District-Banda (UP)		
5. Name of Project	Building Stone Khanda, Boulders, Ballast (Gitti) Mining		
6. Project location (Plot/Khasra/Gata No.)	Arazi No. 935 (Khand No. – 02),		
7. Name of River	NA		
8. Name of Village	Makarbai		
9. Tehsil	Sadar		
10. District	Mahoba (U.P.)		
11. Name of Minor Mineral	Building Stone Khanda, Boulders, Ballast (Gitti) Mining		
12. Sanctioned Lease Area (in Ha.)	3.643 Ha.		
13. Mineable Area (in Ha.)	2.554 Ha. (Safety Margin 1.089 Ha. )		
14. Zero level mRL	NA		
15. Max. & Min mrl within lease area	Maximum & Minimum mRL is 189 & 185 mRL respectively.		
16. Pillar Coordinates (Verified by DMO)	Pillar	Latitude(N)	Longitude(E)
	A	25° 19'52.249"N	79°58'52.887"E
	B	25° 19'55.013"N	79°58'57.198"E
	C	25° 19'54.962"N	79°58'59.697"E
	D	25° 19'52.439"N	79°59'2.139"E
	E	25° 19'47.117"N	79°58'58.906"E
	F	25° 19'47.996"N	79°58'56.756"E
	G	25° 19'49.448"N	79°58'55.399"E

**Minutes of 672<sup>nd</sup> SEAC-1 Meeting Dated 18/07/2022**

	H	25° 19'50.454"N	79°58'53.417"E
17. Total Geological Reserves	19,11,242 m <sup>3</sup>		
18. Sanction Quantity as per LOI	1,80,000 m <sup>3</sup> per year as per LOI		
19. Total Proposed Production	9,00,000 m <sup>3</sup> in five year		
20. Proposed Production/year	1,80,000 m <sup>3</sup> per year		
21. Sanctioned Period of Mine lease	10 Years as per LOI		
22. Monitoring Period	1 <sup>st</sup> March 2021- 31 <sup>st</sup> May 2021 (Summer Season)		
23. Method of Mining	Open cast, Semi Mechanized		
24. No. of working days	250		
25. Working hours/day	8 hours/day		
26. No. Of workers	22		
27. No. Of vehicles movement/day	56-58 Vehicles movement/day		
28. Type of Land	Building Stone Khanda, Boulders, Ballast (Gitti) Mining		
29. Ultimate Depth of Mining	54.0 m for 5 years as per approved mining plan		
30. Nearest metalled road from site	NH-86/76 is about 4.08 km towards West direction from the project site.		
31. Water Requirement	PURPOSE	REQUIREMENT (KLD)	
	Drinking water	0.42 KLD	
	Dust suppression	2.70 KLD	
	Plantation	3.64 KLD	
	Others (if any)	-	
	Total	6.76 KLD Approx.	
32. Name of QCI Accredited Consultant with QCI No And period of validity.	Environmental Research and Analysis, Lucknow (U.P) Certificate No. NABET/ EIA/ 1922/RA 0200 Valid up to 30 Dec, 2022		
33. Any litigation pending against the project or land in any court	No		
34. Details of 500 m Cluster Map & certificate issued by Mining Officer	Letter No. 7936/ MMC-30/2020-21 Date- 27/01/2021		
35. Details of Lease Area in approved DSR	Corrigendum Letter no:154/M.M.C-30-Khanij(2021-22) dated 12/05/2021		
36. Proposed EMP cost	Rs. 18,49,546/-		
37. Proposed Total Project cost	Rs. 1,70,00,000/-		
38. Length and breadth of Haul Road	300 m length and 6.0 m width		
39. No. of Trees to be Planted	3643		

- The mining would be restricted to unsaturated zone only above the phreatic water table and will not intersect the ground water table at any point of time.
- This project does not attract any of the general conditions applicable on mining projects specified in EIA Notification 14/09/2006.
- The mining operation will not be carried out in safety zone of any bridge or embankment or in eco-fragile zone such as habitat of any wild fauna.
- There is no litigation pending in any court regarding this project.
- The project proposal falls under category-1(a) of EIA Notification, 2006 (as amended).

The consultant (EIA Coordinator) also submitted an affidavit dated 11/07/2022 mentioning is as follows:

- I Vishnu Kumar Awasthi S/o Lt. R G Awasthi is EIA Coordinator of M/s Environmental Research and Analysis, Lucknow (U.P.), Accreditation Certificate No- NABET/ EIA/ 1922/RA 0200, valid till- 30/12/2022.
- I have prepared EIA/EMP report for the Proposal No. SIA/UP/MIN/74509/2021 (File No. - 7021/6366) Project Proponent- Shri Rahul Singh S/o Shri Rajendra Kr. Singh of Building Stone Khanda, Boulders, Ballast (Gitti) Mining of Arazi No. 935 (Khand No. – 02), Village- Makarbai, Tehsil- Sadar, District- Mahoba, Uttar Pradesh Total leased Area- 3.643 ha. with my team.



3. I have personally visited the site of proposal.
4. I have satisfied with that all the necessary data/information required for EIA/EMP presentations are true and correct.
5. I certify that no mining activity has been undertaken on the project site for the present proposal.
6. I certify that this project has been uploaded for this first time on Parivesh portal. In case the project has been uploaded again due to any reason, the withdrawals of previous project have been accepted by SEIAA, UP on Parivesh Portal.
7. I certify that there is no mismatch between information/data provided on online application and hard copy/presentation submitted.
8. I state that all the TOR points have been complied and all the issues raised during public hearing have been properly addressed in EIA report.

**RESOLUTION AGAINST AGENDA NO. 04**

**The committee discussed the matter and recommended grant of environmental clearance for the project proposal along with general and specific conditions as annexed at Annexure-1 to these minutes. The committee also stipulated the following specific conditions:**

1. The project proponent shall install solar light in their site office.
2. During the submission of 6 monthly compliance reports, the project proponent should make sure that the periodically taken site photographs should also be annexed along with the compliance report.
3. Preference should be given to indigenous local species as per the consultation of the local district Forest Officer.
4. The maximum height of the bench should be 06 meters and the width of the bench should be at least twice the height of the bench as per the mine plan approval letter by DGM, U.P
5. In case the blasting is proposed during a mining operation, the project proponent needs to assess its impact on the displacement of human beings/wild animals/birds/other species, and the suitable measures proposed and taken for their rehabilitation and resettlement need to be clearly described in first 6 monthly compliance report.
6. The project proponent shall submit a final mine closure plan/Exit protocol for rehabilitation of mined-out land to match its surrounding land use 3years before the closure of the mine to SEIAA, UP and Department of Mines and Geology, UP for approval. The project proponent shall ensure the implementation of the approved plan under the supervision of the Dept. of Mines and Geology.
7. The project proponent shall plan and implement collection drain and siltation basins of adequate size to arrest the silt and sediment flow from the quarry area. The surface runoff rainwater harvesting and other water conservation measures on a long-term basis are to be taken in consultation with the Central/State Groundwater Board. The water so collected should be utilized for watering the haulage area, roads, and green belt development, etc.
8. The project proponent shall take all suitable measures to prevent pollution of groundwater and nearby water bodies in consultation with the State Pollution Control Board and consent to operate (if applicable) should be obtained from the State Pollution Control Board before the start of production from the mine.
9. Link Road from the quarry site to the main road shall be constructed as an all-weather road with blacktopping and maintained by the project proponent.
10. Vehicular emissions should be kept under control and regularly monitored. Suitable measures shall be taken for proper maintenance of vehicles used in a quarry operation and transportation.
11. The project proponent should explore the possibilities of rainwater harvesting.

**5. Stone, Khanda & Gitti, Boulder Mining at Arazi No. 199 (Khand No.03), Village-Naigawan, Tehsil- Sadar, District-Mahoba, Shri Devendra Shivhare., Area-4.0 Ha. File No. 6703/Proposal No. SIA/UP/MIN/ 69479/2021**

The committee noted that the matter was earlier listed in 651<sup>st</sup> SEAC meeting dated 10/05/2022 and the project proponent did not appear in the meeting and the committee directed that project file should be closed and be opened only after request from the project proponent. The project proponent through online portal on 17/06/2022 has requested to list the matter in next SEAC meeting and the matter was listed in 672<sup>nd</sup> SEAC meeting dated 18/07/2022.

The consultant informed the committee that they are strictly following the rules, regulations and other instructions of QCI/NABET. A presentation was made by the project proponent along with their consultant M/s Environmental Research and Analysis, Lucknow (U.P. Based on the documents submitted and presentation made by the project proponent along with the consultant, the following facts have emerged: -

1. The environmental clearance is sought for Stone, Khanda & Gitti, Boulder Mining at Arazi No. 199 (Khand No.03), Village-Naigawan, Tehsil- Sadar, District-Mahoba, (Leased Area-4.0 Ha.).
2. The terms of reference in the matter were issued by SEIAA, U.P. vide letter no. 432/Parya/SEIAA/6703/2021, dated 07/01/2021.
3. The public hearing was organized on 24/03/2022. Final EIA report submitted by the project proponent on 25/04/2022.
4. Salient features of the project as submitted by the project proponent:

1. On-line proposal No.	SIA/UP/MIN/69479/2021		
2. File No. allotted by SEIAA, UP	6703		
3. Name of Proponent	Proponent- Shri Devendra Shivhare S/o Shri Ram Manohar Shivhare		
4. Full correspondence address of proponent and mobile no.	R/o – Mo. Indra Nagar, Kabrai, Tehsil & District- Mahoba(U.P)		
5. Name of Project	Building Stone, Khanda, Boulder, Ballast (Gitti) Mining Project		
6. Project location (Plot/Khasra/Gata No. / khand No.)	Arazi No. 199 (Khand No. – 03),		
7. Name of Village	Naigawan		
8. Tehsil	Sadar		
9. District	Mahoba (U.P)		
10. Name of Minor Mineral	Building Stone, Khanda, Boulder, Ballast (Gitti) Mining Project		
11. Sanctioned Lease Area (in Ha.)	4.0 Ha.		
12. Mineable Area (in Ha.)	3.38 Ha. (Safety Margin 0.62Ha.)		
13. Max. & Min mrl within lease area	Maximum & Minimum mRL is 211 & 181 mRL respectively.		
14. Pillar Coordinates (Verified by DMO)	Points	Latitude	Longitude
	A	25°20'14.003"N	79°59'48.707"E
	B	25°20'15.014"N	79°59'59.388"E
	C	25°20'10.075"N	80°00'00.036"E
	D	25°20'10.571"N	79°59'49.387"E
15. Total Geological Reserves	13,03,695 m <sup>3</sup>		
16. Total Mineable Reserves in LOI	1,24,000 m <sup>3</sup> per year		
17. Total Proposed Production	6,20,000 m <sup>3</sup> in five years		
18. Proposed Production/year	1,24,000 m <sup>3</sup> per year		
19. Sanctioned Period of Mine lease	10 Year		
20. Method of Mining	Open cast, semi mechanized		
21. No. of working days	250		
22. Working hours/day	8 hours/day		
23. No. Of workers	Approximately 38 workers		

24. No. Of vehicles movement/day	38-40 Vehicles movement/day	
25. Type of Land	Government Land	
26. Ultimate Depth of Mining	31.85 m for five years as per approved mining plan	
27. Nearest metalled road from site	NH-34 is about 4.22 km towards West direction from the project site.	
28. Water Requirement	PURPOSE	REQUIREMENT (KLD)
	Drinking	0.48 KLD
	Suppression of dust	4.59 KLD
	Plantation	4.0 KLD
	Others (if any)	-
	Total	9.07 or 9.0 KLD approx..
29. Name of QCI Accredited Consultant with QCI No And period of validity.	Environmental Research and Analysis, Lucknow (U.P) Certificate No. NABET/EIA/1229/RA 0200 valid up to 30/12/2022	
30. Any litigation pending against the project or land in any court	No	
31. Details of 500 m Cluster Map & certificate issued by Mining Officer	(Letter No. 1345/ MMC-30/2021-22) Date- 18/08/2021	
32. Details of Lease Area in approved DSR	Letter no. 8471/M.M.C-30 Khanij/2020-21 Mahoba dated 10/03/2021 serial no -13	
33. Proposed EMP cost	Rs 26,96,022/-	
34. Proposed Total Project cost	Rs. 3,00,00,000/-	
35. Length and breadth of Haul Road	510 m length and 6 m width	
36. No. of Trees to be Planted	4000	
37. Monitoring season	1st March, 2021 to 31st May, 2021(summer season).	

5. The mining would be restricted to unsaturated zone only above the phreatic water table and will not intersect the ground water table at any point of time.
6. This project does not attract any of the general conditions applicable on mining projects specified in EIA Notification 14/09/2006.
7. The mining operation will not be carried out in safety zone of any bridge or embankment or in eco-fragile zone such as habitat of any wild fauna.
8. There is no litigation pending in any court regarding this project.
9. The project proposal falls under category-1(a) of EIA Notification, 2006 (as amended).

The consultant (EIA Coordinator) also submitted an affidavit dated 07/05/2022 mentioning is as follows:

1. I Vishnu Kumar Awasthi S/o Lt. R G Awasthi is EIA Coordinator of M/s Environmental Research and Analysis, Lucknow (U.P.), Accreditation Certificate No- NABET/ EIA/ 1922/RA 0200, valid till- 30/12/2022.
2. I have prepared EIA/EMP report for the Proposal No. SIA/UP/MIN/64179/2021 (File No. - 6703) Project Proponent- Shri Devendra Shivhare S/o Shri Ram Manohar Shivhare of Stone, Khanda & Gitti, Boulder Mining at Arazi No. 199 (Khand No.03), Village-Naigawan, Tehsil- Sadar, District-Mahoba, (Leased Area-4.0 Ha.) with my team.
3. I have personally visited the site of proposal.
4. I have satisfied with that all the necessary data/information required for EIA/EMP presentations are true and correct.
5. I certify that no mining activity has been undertaken on the project site for the present proposal.
6. I certify that this project has been uploaded for this first time on Parivesh portal. In case the project has been uploaded again due to any reason, the withdrawals of previous project have been accepted by SEIAA, UP on Parivesh Portal.
7. I certify that there is no mismatch between information/data provided on online application and hard copy/presentation submitted.

8. I state that all the TOR points have been complied and all the issues raised during public hearing have been properly addressed in EIA report.

**RESOLUTION AGAINST AGENDA NO. 05**

**The committee discussed the matter and recommended grant of environmental clearance for the project proposal along with general and specific conditions as annexed at Annexure-1 to these minutes. The committee also stipulated the following specific conditions:**

1. The project proponent shall install solar light in their site office.
2. During the submission of 6 monthly compliance reports, the project proponent should make sure that the periodically taken site photographs should also be annexed along with the compliance report.
3. Preference should be given to indigenous local species as per the consultation of the local district Forest Officer.
4. The maximum height of the bench should be 06 meters and the width of the bench should be at least twice the height of the bench as per the mine plan approval letter by DGM, U.P
5. In case the blasting is proposed during a mining operation, the project proponent needs to assess its impact on the displacement of human beings/wild animals/birds/other species, and the suitable measures proposed and taken for their rehabilitation and resettlement need to be clearly described in first 6 monthly compliance report.
6. The project proponent shall submit a final mine closure plan/Exit protocol for rehabilitation of mined-out land to match its surrounding land use 3years before the closure of the mine to SEIAA, UP and Department of Mines and Geology, UP for approval. The project proponent shall ensure the implementation of the approved plan under the supervision of the Dept. of Mines and Geology.
7. The project proponent shall plan and implement collection drain and siltation basins of adequate size to arrest the silt and sediment flow from the quarry area. The surface runoff rainwater harvesting and other water conservation measures on a long-term basis are to be taken in consultation with the Central/State Groundwater Board. The water so collected should be utilized for watering the haulage area, roads, and green belt development, etc.
8. The project proponent shall take all suitable measures to prevent pollution of groundwater and nearby water bodies in consultation with the State Pollution Control Board and consent to operate (if applicable) should be obtained from the State Pollution Control Board before the start of production from the mine.
9. Link Road from the quarry site to the main road shall be constructed as an all-weather road with blacktopping and maintained by the project proponent.
10. Vehicular emissions should be kept under control and regularly monitored. Suitable measures shall be taken for proper maintenance of vehicles used in a quarry operation and transportation.
11. The project proponent should explore the possibilities of rainwater harvesting.

**6. Common Hazardous Waste Treatment, Storage, Disposal and Recycling Facility (CHWTSDF) at C-187, B.S Road, Industrial Area, Ghaziabad, M/s Steam Oil & General Industries. File No. 7155/Proposal No. SIA/UP/MIS/78413/2022**

**RESOLUTION AGAINST AGENDA NO. 06**

A presentation was made by the project proponent. The committee noted that the project proponent has not produce the required documents to the committee. Hence, the committee opined that a letter should be sent to RO, UPPCB, Ghaziabad to visit the plant and provide detailed factual report of the plant. The committee also directed the project proponent to submit chronological events of the plant along with supporting documents. The project proponent present their case before SEAC as per procedure laid down in violation SoP dated 07/07/2021 along with above information.

7. **Stone (Khandas/Boulder, Bailast & Gitti )Mining" Project at Gata No.-346, at Village- Umanniya, Tehsil-Rath, District-Hamirpur, Shri Srinivaas Budhaliya., area-0.5060 ha. File No. 6520/Proposal No. SIA/UP/MIN/ 226505/2021**

**RESOLUTION AGAINST AGENDA NO. 07**

The project proponent/consultant did not appear. The committee discussed and deliberated that the project file should be closed and be opened only after request from the project proponent. The file shall not be treated as pending at SEAC. The matter will be discussed only after submission of online request on prescribed online portal.

8. **Sand Stone Mine at Arazi No- 428 (Sl. No. 08), Village- Dhuria, Tehsil- Chunar, Mirzapur, Shri Manish Kumar, Area 2.02 ha. File No. 7027/Proposal No. SIA/UP/MIN/ 75031/2022**

The committee noted that the matter was earlier listed in 633<sup>rd</sup> SEAC meeting dated 04/03/2022 and the project proponent did not appear in the meeting and the committee directed that project file should be closed and be opened only after request from the project proponent. The project proponent through online portal on 07/06/2022 has requested to list the matter in next SEAC meeting and the matter was listed in 672<sup>nd</sup> SEAC meeting dated 18/07/2022.

The consultant informed the committee that they are strictly following the rules, regulations and other instructions of QCI/NABET. A presentation was made by the project proponent along with their consultant M/s Cognizance Research India Pvt. Ltd. Based on the documents submitted and presentation made by the project proponent along with the consultant, the following facts have emerged: -

1. The terms of reference is sought for Dhuria Building Stone Sand Stone Mine at Arazi No. 428 (Sl. No. 08), Village- Dhuria, Tehsil- Chunar, District- Mirzapur, U.P., (Leased Area 2.02 ha.).
2. Salient features of the project as submitted by the project proponent:

1. On-line proposal No.	SIA/UP/MIN/ 75031 /2022		
2. File No. allotted by SEIAA, UP	7027		
3. Name of Proponent	M/s Divyansh Enterprises Prop. Shri Manish Kumar S/o Shri Ram Chandra Keshari		
4. Full correspondence address of proponent and mobile No.	R/o Ward no. 23, Ahraura Main Market ke paas, District- Mirzapur (U.P.)		
	Mobile No-		
	Email-		
5. Name of Project	Dhuria Building stone Sand Stone Mining project		
6. Project location (Plot/Khasra/Gata No.)	Arazi No. 428 (Sl. No. 08)		
7. Name of River	-		
8. Name of Village	Dhuria		
9. Tehsil	Chunar		
10. District	Mirzapur		
11. Name of Minor Mineral	Building Stone Sand Stone		
12. Sanctioned Lease Area (in Ha.)	2.02 ha		
13. Max & Min mRL within lease area	Max- 112.0 mRL & 99.0 mRL		
14. Pillar Coordinates (Verified by DMO)	Sanctioned Mining Lease Area		
	Pillar No.	Latitude	Longitude
	A	25° 2'42.9"N	83°3'7.30"E
	B	25° 2'43.3"N	83°3'13.35"E
	C	25° 2'39.12"N	83°3'12.92"E

	D	25° 2'39.03"N	83°3'7.40"E
15. Total Geological Reserves	8,01,237 Cum		
16. Total Mineable Reserves in LOI	60,600 Cum/year		
17. Total Proposed Production	60,600 Cum/year		
18. Proposed Production/year	60,600 Cum/year		
19. Sanctioned Period of Mine lease	20 years		
20. Method of Mining	Open Cast Semi-mechanized Method		
21. No. of working days	260 days		
22. Working hours/day	8 hrs		
23. No. of workers	27		
24. No. of vehicles movement/day	33		
25. Type of Land	Government waste land		
26. Ultimate Depth of Mining	48		
27. Nearest metalled road from site	0.8 km		
28. Water Requirement	PURPOSE		REQUIREMENT (KLD)
	Drinking		0.27
	Suppression of dust		3.90
	Plantation		2.02
	Others (if any)		0.27
	Total		6.46
29. Name of QCI Accredited Consultant with QCI No and period of validity.	Cognizance Research India Pvt. Ltd. 1922, validity= 27-07-2022		
30. Any litigation pending against the project or land in any court	No		
31. Details of 500 m Cluster Map & certificate issued by Mining Officer	Yes, certified		
32. Details of Lease Area in approved DSR	Yes, given in the DSR		
33. Proposed CER cost	Rs 1,56,000/-		
34. Proposed EMP cost	Capital Cost-Rs 25,80,000/- including DSR Recurring Cost- 4,08,000/-		
35. Length and breadth of Haul Road	Length: 0.325 km, width: 6 m		
36. No. of Trees to be Planted	2020 plants		

- The mining would be restricted to unsaturated zone only above the phreatic water table and will not intersect the ground water table at any point of time.
- This project does not attract any of the general conditions applicable on mining projects specified in EIA Notification 14/09/2006.
- The mining operation will not be carried out in safety zone of any bridge or embankment or in eco-fragile zone such as habitat of any wild fauna.
- There is no litigation pending in any court regarding this project.
- The project proposal falls under category-1(a) of EIA Notification, 2006 (as amended).

The consultant (EIA Coordinator) also submitted an affidavit dated 09/05/2022 mentioning is as follows:

- I, Ankur Sharma S/o Lalit Mohan Sharma is EIA Coordinator of Cognizance Research India Pvt. Ltd.
- I have prepared TOR project for the Proposal (SIA/UP/MIN/75031/2022) File No. 7027 of Dhuria Building Stone Sand Stone Mine at Arazi No. 428 (Sl. No. 08), Village- Dhuria, Tehsil- Chunar, District- Mirzapur, U.P., (Leased Area 2.02 ha.) with my team.
- I have personally visited the site of proposal.
- I have satisfied with that all the necessary data/information required for TOR project preparations are true and correct.
- I certify that no mining activity has been undertaken on the project site for the present proposal.

6. I certify that this project has been uploaded for the first time on Parivesh Portal. In case the project has been uploaded again due to any reason, the withdrawal of previous project has been accepted by SEIAA, UP on Parivesh Portal.
7. I certify that there is no mismatch between information/data provided on online application and hard copy/presentation submitted.

**RESOLUTION AGAINST AGENDA NO. 08**

**The committee discussed the matter and recommended to issue the standard terms of reference for the preparation of EIA as annexed at annexure-2 to the minutes. The committee also stipulated following additional TOR Points:**

**Additional TOR:**

1. To ensure proper monitoring, the project proponent/consultant should provide evidence in for of (A) Raw Data (B) Logbook of their site visit along with activities carried out during monitoring (C) Real time photographs showing monitoring machine, public, lab person etc.
2. EIA coordinator & FAE should give a photo affidavit during EIA presentation that they have personally visited the site & they have also taken all the mitigating measures for any critical issues involved in the project.
3. Combined KML of all mines in a cluster should be submitted at the time of EIA.
4. The details of equipment used for baseline monitoring alongwith its photograph mentioning date, time and geo coordinates for preparation of EIA report should be clearly displayed to the people present during public hearing and the complete details related to monitoring period must be mentioned in the minutes of public hearing.
5. The project proponent/Consultant should identify the core & buffer zone (2.5 km) of the mining site.
6. Agreement/ Consent between project proponent and competent authority/ landowner for haulage road from lease site to link road to be submitted at the time of EIA presentation.
7. Proponent/ Consultant should submit the plan/information along with technology (photographs of water sprinklers/ tankers) to be implemented for mitigating dust at source points in lease area and haulage road during operation activity/vehicular movement. Technology should be displayed at the time of EIA presentation.
8. Proposed plantation plan with area specific plant species, number of plants to be planted and place of plantation along with a proper map to be submitted at the time of EIA presentation.
9. Water requirement details along with source of water and the permission/ agreement with the concerning authority/ person to be submitted at the time of EIA presentation.
10. Proponent/consultant shall present TOR specific/additional conditions compliance, observation/suggestions raised during the public hearing and commitment made by the project proponent in a tabular form with a time bound plan at the time of EIA presentation.
11. Revised Corporate Social Responsibility (CSR) to be prepared as per the MoEF guidelines and present it at the time of EIA presentation.

**9. Sand Stone Mine at Arazi No 37 (Sl. No. 14), Village- Dakahi, Tehsil- Chunar, Mirzapur, Shri Manish Kumar, Area 2.02 ha. File No. 7028/Proposal No. SIA/UP/MIN/ 75033/2022**

The committee noted that the matter was earlier listed in 633<sup>rd</sup> SEAC meeting dated 04/03/2022 and the project proponent did not appear in the meeting and the committee directed that project file should be closed and be opened only after request from the project proponent. The project proponent through online portal on 07/06/2022 has requested to list the matter in next SEAC meeting and the matter was listed in 672<sup>nd</sup> SEAC meeting dated 18/07/2022.

The consultant informed the committee that they are strictly following the rules, regulations and other instructions of QCI/NABET. A presentation was made by the project proponent along with their consultant M/s Cognizance Research India Pvt. Ltd. Based on the documents submitted and presentation made by the project proponent along with the consultant, the following facts have emerged: -

1. The terms of reference is sought for Dakahi Building Stone Sand Stone Mine at Arazi No. 37 (Sl. No. 14), Village- Dakahi, Tehsil- Chunar, District- Mirzapur, U.P., (Leased Area 2.02 ha.).
2. Salient features of the project as submitted by the project proponent:

1. On-line proposal No.	SIA/UP/MIN/ 75033 /2022		
2. File No. allotted by SEIAA, UP	7028		
3. Name of Proponent	M/s Divyansh Enterprises Prop. Shri Manish Kumar S/o Shri Ram Chandra Keshari		
4. Full correspondence address of proponent and mobile No.	R/o Ward no: 23, Ahraura Main Market ke paas, District- Mirzapur (U.P.)		
	Mobile No-		
	Email-		
5. Name of Project	Dakahi Building stone Sand Stone Mining project		
6. Project location (Plot/Khasra/Gata No.)	Arazi No. 37 (Sl. No. 14)		
7. Name of River	-		
8. Name of Village	Dakahi		
9. Tehsil	Chunar		
10. District	Mirzapur		
11. Name of Minor Mineral	Building Stone Sand Stone		
12. Sanctioned Lease Area (in Ha.)	2.02 ha		
13. Max & Min mRL within lease area	Max- 107.0 mRL & 94.0 mRL		
14. Pillar Coordinates (Verified by DMO)	Sanctioned Mining Lease Area		
	Pillar No.	Latitude	Longitude
	A	25° 2'7.60"N	83°3'38.60"E
	B	25° 2'9.19"N	83°3'42.63"E
	C	25° 2'4.10"N	83°3'44.26"E
	D	25° 2'2.20"N	83°3'40.40"E
15. Total Geological Reserves	6,60,020 Cum		
16. Total Mineable Reserves in LOI	60,600 Cum/year		
17. Total Proposed Production	60,600 Cum/year		
18. Proposed Production/year	60,600 Cum/year		
19. Sanctioned Period of Mine lease	20 years		
20. Method of Mining	Open Cast Semi-mechanized Method		
21. No. of working days	260 days		
22. Working hours/day	8 hrs		
23. No. of workers	27		
24. No. of vehicles movement/day	33		
25. Type of Land	Government waste land		
26. Ultimate Depth of Mining	48		
27. Nearest metalled road from site	0.8 km		
28. Water Requirement	PURPOSE		REQUIREMENT (KLD)
	Drinking		0.27
	Suppression of dust		2.80
	Plantation		2.02
	Others (if any)		0.27
	Total		5.36
29. Name of QCI Accredited Consultant with QCI No and period of validity.	Cognizance Research India Pvt. Ltd. 1922, validity= 27-07-2022		
30. Any litigation pending against the project or land in any court	No		



31. Details of 500 m Cluster Map & certificate issued by Mining Officer	Yes, certified
32. Details of Lease Area in approved DSR	Yes, given in the DSR
33. Proposed CER cost	Rs 1,56,000/-
34. Proposed EMP cost	Capital Cost-Rs 25,80,000/- including DSR Recurring Cost- 4,08,000/-
35. Length and breadth of Haul Road	Length: 0.232 km, width: 6 m
36. No. of Trees to be Planted	2020 plants

- The mining would be restricted to unsaturated zone only above the phreatic water table and will not intersect the ground water table at any point of time.
- This project does not attract any of the general conditions applicable on mining projects specified in EIA Notification 14/09/2006.
- The mining operation will not be carried out in safety zone of any bridge or embankment or in eco-fragile zone such as habitat of any wild fauna.
- There is no litigation pending in any court regarding this project.
- The project proposal falls under category-1(a) of EIA Notification, 2006 (as amended).

The consultant (EIA Coordinator) also submitted an affidavit dated 09/05/2022 mentioning is as follows:

- I, Ankur Sharma S/o Lalit Mohan Sharma is EIA Coordinator of Cognizance Research India Pvt. Ltd.
- I have prepared TOR project for the Proposal (SIA/UP/MIN/75033/2022) File No. 7028 of Dakahi Building Stone Sand Stone Mine at Arazi No. 37 (Sl. No. 14), Village- Dakahi, Tehsil- Chunar, District- Mirzapur, U.P., (Leased Area 2.02 ha.) with my team.
- I have personally visited the site of proposal.
- I have satisfied with that all the necessary data/information required for TOR project preparations are true and correct.
- I certify that no mining activity has been undertaken on the project site for the present proposal.
- I certify that this project has been uploaded for the first time on Parivesh Portal. In case the project has been uploaded again due to any reason, the withdrawal of previous project has been accepted by SEIAA, UP on Parivesh Portal.
- I certify that there is no mismatch between information/data provided on online application and hard copy/presentation submitted.

#### **RESOLUTION AGAINST AGENDA NO. 09**

**The committee discussed the matter and recommended to issue the standard terms of reference for the preparation of EIA as annexed at annexure-2 to the minutes. The committee also stipulated following additional TOR Points:**

#### **Additional TOR:**

- To ensure proper monitoring, the project proponent/consultant should provide evidence in for of (A) Raw Data (B) Logbook of their site visit along with activities carried out during monitoring (C) Real time photographs showing monitoring machine, public, lab person etc.
- EIA coordinator & FAE should give a photo affidavit during EIA presentation that they have personally visited the site & they have also taken all the mitigating measures for any critical issues involved in the project.
- Combined KML of all mines in a cluster should be submitted at the time of EIA.

4. The details of equipment used for baseline monitoring alongwith its photograph mentioning date, time and geo coordinates for preparation of EIA report should be clearly displayed to the people present during public hearing and the complete details related to monitoring period must be mentioned in the minutes of public hearing.
5. The project proponent/Consultant should identify the core & buffer zone (2.5 km) of the mining site.
6. Agreement/ Consent between project proponent and competent authority/ landowner for haulage road from lease site to link road to be submitted at the time of EIA presentation.
7. Proponent/ Consultant should submit the plan/information along with technology (photographs of water sprinklers/ tankers) to be implemented for mitigating dust at source points in lease area and haulage road during operation activity/vehicular movement. Technology should be displayed at the time of EIA presentation.
8. Proposed plantation plan with area specific plant species, number of plants to be planted and place of plantation along with a proper map to be submitted at the time of EIA presentation.
9. Water requirement details along with source of water and the permission/ agreement with the concerning authority/ person to be submitted at the time of EIA presentation.
10. Proponent/consultant shall present TOR specific/additional conditions compliance, observation/suggestions raised during the public hearing and commitment made by the project proponent in a tabular form with a time bound plan at the time of EIA presentation.
11. Revised Corporate Social Responsibility (CSR) to be prepared as per the MoEF guidelines and present it at the time of EIA presentation.

**10. Sand/Morrum Mining at Araj/Gata No. 328G, Village-Devidaspur, Tehsil-Kaiserganj, Bahraich, U.P., Shri Kartikey Mishra, M/s Katyayayni Construction, Area - 0.75 ha. File No. 7158/Proposal No. SIA/UP/MIN/279059/2022**

The consultant informed the committee that they are strictly following the rules, regulations and other instructions of QCI/NABET. A presentation was made by the project proponent along with their consultant M/s Paramarsh (Servicing Environment and Development), Lucknow, UP. Based on the documents submitted and presentation made by the project proponent along with the consultant, the following facts have emerged: -

1. The environmental clearance is sought for Sand Mining at Araj/Gata no.- 328 G, Village-Devidaspur, Tehsil-Kaiserganj, District-Bahraich, U.P., (Leased Area-0.75 ha.).
2. Salient features of the project as submitted by the project proponent:

1.	On-line proposal No.	SIA/UP/MIN/279059/2022
2.	File No. allotted by SEIAA, UP	7158
3.	Name of Proponent	M/s Katyayani construction, Prop. Shri Kartikey mishra S/o Shri Bhagwan prasad
4.	Full correspondence address of proponent and mobile no.	M/s Katyayani construction, Prop. Shri Kartikey mishra S/o Shri Bhagwan prasad R/o- 1146, Bharatpuri Awas vikas volony, Post badgawn, District gonda, Uttar Pradesh
		Mobile no.-
		E-mail Id-
5.	Project Location (Plot.Khasra/Gata No.)	Gata No. 328 G, Village –Devidaspur, Tehsil-Kaiserganj, District–Bahraich, Uttar Pradesh
6.	Name of River	NA
7.	Name of Village	Devidaspur
8.	Tehsil	Kaiserganj
9.	District	Bahraich
10.	Name of Minor Mineral	Sand Mining
11.	Sanctioned Lease Area (in Ha.)	0.75 ha

12.	Max. & Min mRL within lease area	Highest mRL is 108 & Lowest is 107mRL		
13.	Pillar Coordinates (Verified by DMO)	Pillars	N	E
		A	27° 13'43.20"N	81°39'37.65"E
		B	27° 13'48.49"N	81°39'37.06"E
		C	27° 13'48.96"N	81°39'35.20"E
		D	27° 13'44.52"N	81°39'35.68"E
14.	Total Geological Reserves	17351 m <sup>3</sup>		
15.	Total Mineable Reserve (as per Approved Mine Plan)	10000 m <sup>3</sup>		
16.	Total Proposed Production (In 5 Years)	10000 m <sup>3</sup> (In 6months)		
17.	Proposed Production/year	10,000 m <sup>3</sup> (In 6months)		
18.	Sanctioned Period of Mine lease	6 months		
19.	Method of Mining	Opencast, Semi-Mechanized		
20.	No. of working days	180		
21.	Working hours/day	8		
22.	No. of worker	35		
23.	No. of vehicles movement/day	6		
24.	Type of Land	private land		
25.	Ultimate of Depth of Mining	Upto 104.66mRL		
26.	Nearest metalled road from site	500m		
27.	Water Requirement	PURPOSE		REQUIREMENT (KLD)
		Drinking		0.35 KLD
		Suppression of dust		2.0 KLD
		Plantation		0.2 KLD
		Others (if any)		-
		Total		2.55 KLD
28.	Name of QCI Accredited Consultant with QCI No and period of validity.	PARAMARSH (Servicing Environment and Development) Lucknow UP Certificate no. NABET/EIA/2124/RA 0224 Valid Till May 01,2024		
29.	Any litigation pending against the project or land in any court	No		
30.	Details of 500 m Cluster Certificate verified by Mining Officer	vide letter no. 64/TEES-KHANAN/2022		
31.	Details of Lease Area in approved DSR	0.75 ha.		
32.	Proposed CER cost	Rs. 1.0 Lakhs		
33.	Proposed EMP cost	Total project cost- Rs. 50 Lakh		
34.	Length and breadth of Haul Road	500m & 6m		
35.	No. of Trees to be Planted	200		

- The mining would be restricted to unsaturated zone only above the phreatic water table and will not intersect the ground water table at any point of time.
- This project does not attract any of the general conditions applicable on mining projects specified in EIA Notification 14/09/2006.
- The mining operation will not be carried out in safety zone of any bridge or embankment or in eco-fragile zone such as habitat of any wild fauna.
- There is no litigation pending in any court regarding this project.
- The project proposal falls under category-1(a) of EIA Notification, 2006 (as amended).

The consultant (EIA Coordinator) also submitted an affidavit dated 14/07/2022 mentioning is as follows:

- I Surendra Vikram Ghavri S/o Shri Pratap Kumar is EIA Coordinator of M/s Paramarsh (Servicing Environment and Development, Lucknow).
- I have prepared EC application report for the (Proposal No. SIA/UP/MIN/279059/2022, sand mining by M/s Katayani Construction, Shri Kartikey Mishra with my team.

3. I have personally visited the site of proposal.
4. I have satisfied with that all the necessary data/information required for EC application preparation are true and correct.
5. I certify that no mining activity has been undertaken on the project site for the present proposal.
6. I certify that this project has been uploaded for this first time on Parivesh portal. In case the project has been uploaded again due to any reason, the withdrawals of previous project have been accepted by SEIAA, UP on Parivesh Portal.
7. I certify that there is no mismatch between information/data provided on online application and hard copy/presentation submitted.

**RESOLUTION AGAINST AGENDA NO. 10**

**The committee discussed the matter and recommended grant of environmental clearance for the project proposal along with general and specific conditions as annexed at Annexure-3 to these minutes. The committee also stipulated the following specific conditions:**

1. NOC from Irrigation Department/ Concerning Authority regarding river bed mining to be obtained before start of mining activity.
2. The project proponent shall install solar light in their site office.
3. During the submission of 6 monthly compliance reports, the project proponent should make sure that the periodically taken site photographs should also be annexed along with the compliance report.
4. Preference should be given to indigenous local species as per the consultation of the local district Forest Officer.
5. Link Road from the quarry site to the main road shall be constructed as an all-weather road with blacktopping and maintained by the project proponent.
6. Vehicular emissions should be kept under control and regularly monitored. Suitable measures shall be taken for proper maintenance of vehicles used in a quarry operation and transportation.
7. The project proponent should explore the possibilities of rainwater harvesting.
8. Agreement/ Consent between project proponent and competent authority/ landowner for haulage road from lease site to link road.
9. Latest technology (water sprinklers/ tankers) to be adopted for mitigating dust at source points in lease area and haulage road during operational activity/vehicular movement.
10. As per the proposed plan, plantation with area specific plant species, number of plants to be planted.
11. Water requirement details along with source of water and the permission/ agreement with the concerning authority/ water supplying agencies to be submitted.

**11. Sand Mining at Gata/Khand No. 01, Village- Nauraspur, Tehsil- Loni, Ghaziabad, Shri Jitendra Dhawan, Area-1.81 Ha. File No. 7160/Proposal No. SIA/UP/MIN/279453/2022**

**RESOLUTION AGAINST AGENDA NO. 11**

The project proponent/consultant did not appear. The committee discussed and deliberated that the project file should be closed and be opened only after request from the project proponent. The file shall not be treated as pending at SEAC. The matter will be discussed only after submission of online request on prescribed online portal.

**12. Proposed T-5 Commercial Project at Plot No. 5(T-5) at International Business Bay-1, Sushant Golf city, Hi-Tech Township, Sultanpur Road, Lucknow, U.P. Shri Rohit Agarwal, M/s SJP Hotel & Resort Pvt. Ltd. File No. 7079/Proposal No. SIA/UP/MIS/272355/2022**

The committee noted that the matter was earlier listed in 661<sup>st</sup> SEAC meeting dated 07/06/2022 and directed that the project proponent/director of the company was not present in the meeting. Therefore, the committee did not entertain the case. The project proponent requested to list the matter in next SEAC meeting and the matter was scheduled for appraisal in 672<sup>nd</sup> SEAC meeting dated 18/07/2022.

A presentation was made by the project proponent (Mr. Sunil Miglani, Director) along with their consultant M/s Ambiental Global Pvt. Ltd. During the presentation the committee observed that the EIA coordinator has been submitted an affidavit dated 06/06/2022 and as per affidavit no construction has been undertaken at the project site. The committee directed the project proponent to submit "No construction affidavit" and the consultant should submit the latest EIA coordinator affidavit prescribed by SEAC.

The matter shall be discussed after submission of above information through online portal.

**13. Expansion of Group Housing Project "Vilaasa" at Plot No.-GH-01B(2), Sector-ETA-2, Greater Noida., M/s Yamuna Builtech Pvt. Ltd. File No. 5506/4846/Proposal No. SIA/UP/MIS/ 49785/2019**

The committee noted that the matter was earlier discussed in 578<sup>th</sup> SEAC meeting dated 07/10/2021 and decided is as follows:

*"The Project Proponent/Consultant submitted an action taken report on the issue raised by MoEF&CC in the certified compliance report. Prima facie the committee is not fully satisfied with the reply of the project proponent/consultant. Because of delay by MoEF&CC, Regional Office the committee decided to constitute a committee to visit the site and examine the observation raised in MoEF&CC certified compliance report. This committee will consist of the following members:*

- 1. Dr. B.B. Awasthi, Member SEAC-1*
- 2. Shri U.C. Sharma, Member SEAC-1*
- 3. Regional Officer, Greater Noida, UPPCB*

*Based on the report of the committee appropriate decision will be taken by the committee."*

The SEIAA agreed with the recommendation of SEAC in its 517<sup>th</sup> meeting dated 20/11/2021. The SEIAA issued a letter no. 19/Parya/SEAC/5506/2020, dated 21/04/2022 to the members of joint committee for providing the site visit report of the project. A site visit was undertaken by the members of joint committee on dated 21/05/2022 (Copy enclosed) and site visit report send by the Regional Officer, UPPCB, Greater Noida vide letter no. 273/NOC-233/22, dated 31/05/2022 to the SEIAA. The conclusion recommendation of the joint committee is as follows:

*"Keeping in view the observation, compliance seems to be satisfactory. Some compliance may be verified with timely submission of six-monthly compliance report wrt EC issued.*

The committee discussed the matter on the basis of site visit report submitted by the joint committee, presentation made by the project proponent and recommended grant of environmental clearance on the proposal given at Para-A alongwith standard environmental clearance conditions prescribed by MoEF&CC, GoI and additional conditions given at Para-B :

**Para-A:**

1. The environmental clearance is sought for Expansion of Group Housing Project "Vilaasa" at Plot No. GH-01B (2), Sector- ETA-2, Greater Noida, District- Gautam Buddha Nagar, U.P., M/s Yamuna Builtech Pvt.
2. Environmental Clearance for the earlier proposal was issued by SEIAA, U.P, vide letter no. 417/Parya/SEAC/4324/2018 dated 29<sup>th</sup> October, 2018 for total plot area = 23,200.00 m<sup>2</sup> (5.73 acre) & Built-up area = 1,46,631.13 m<sup>2</sup>.
3. Project involves development of 6 towers including dedicated buildings for convenient shops and community centre. After the revision and expansion of the project, total number of dwelling units will be 1203.
4. Salient features of the project:

Description	Proposed
Plot Area	23,200.00 m <sup>2</sup>
Built-up Area	1,56,902.65 m <sup>2</sup>
Green Area	10,182.21 m <sup>2</sup> @ 43.88% of Total Plot Area
Total Water Requirement	548 KLD
Fresh Water Requirement	366 KLD
Wastewater Generation	441 KLD
Capacity of STP	450 KLD
Solid Waste Generation	3,047 kg/day
Parking Required & Provided	1211 ECS & 1432 ECS
Power Demand & Source	2240 kVA, Supplied by Uttar Pradesh Power Corporation Limited (UPPCL)
Back up	625 kVA (125 + 500 kVA)
RWH Pits	6 pits
Total Project Cost	INR 120 cr.
Expected Date of Completion	5 Years

5. Comparative area details of earlier and expansion project:

S.No.	Description	As Per Earlier EC (m <sup>2</sup> )	Post revision and expansion (m <sup>2</sup> )
1.	Total Plot Area	23,200.00	
2.	Permissible Ground Coverage	8120.00 (@35%)	
3.	Proposed Ground Coverage	7722.06 (@33.284%)	6126.19 (@26.405%)
4.	Total Permissible F.A.R.	96,860.00	
5.	Total Proposed F.A.R. Area	95,852.68	96,744.52
6.	Total Non F.A.R. Area	38,958.45	47,978.13
7.	Built Up Area	1,46,631.13	1,56,902.65
8.	Landscape Area	7,635.43 (@ 32.91%)	10,182.21 (@ 43.88%)
9.	Total Proposed Units	1201	1203
10.	Height of the highest building	82.8 m	82.8 m

6. Area details of the project:

S. No.	Particulars	Area (m <sup>2</sup> )
1.	Total Plot Area	23,200.00
2.	Permissible Ground Coverage (@ 35%)	8,120.00

3.	Proposed Ground Coverage (@26.405%)	6,126.19
4.	Total Permissible F.A.R. Permissible FAR for Housing @ 3.50 Additional FAR for Metro @ 0.50 Additional FAR for Green Building (5% of Permissible F.A.R. @ 2.5)	96,860.00 81,200.00 11,600.00 4060.00
5.	Total Proposed F.A.R. F.A.R. achieved for Housing F.A.R. achieved for Commercial F.A.R. achieved for Meter Room Extra Facility Area in main F.A.R.	96,744.52 94,265.66 808.68 11.97 1,658.21
6.	Permissible FAR for Facility (15% of Permissible F.A.R)	12,180.00
7.	Total Achieved Facility Area (Fire Stair Case + Lift Lobby + Mumty + Machine Room + Lift Shafts + Service Shafts + Cupboard + Guard Room + Over head tank + S.T.P. + L.T. Panel Room + Guard & Visitor Toilets + Community Hall)	13,838.21
8.	Total Non-F.A.R. Lower Basement Area Upper Basement Area Stilt Area Podium Area	47,978.13 18,343.65 17,074.90 3,845.85 8,713.73
9.	Total Built-up Area	1,56,902.65
10.	Green Area @43.88% of Total Plot Area	10,182.21
11.	Total Open Area (73.59%)	17,073.81
12.	Proposed No. of Dwelling Units	1203
13.	Height of the highest building	82.8 m

**7. Population details:**

S. No.	Unit Type	D.U./FAR (m <sup>2</sup> )	PPU	Total Population
1.	Residential			
	Residents	1203	4.5	5414
	Staff	@5% of residential population		271
	Visitors	@10% of residential population		541
2.	Commercial area (Lower Ground floor):	493.26	@ 1 person/3 m <sup>2</sup>	164
	Staff		@ 20%	33
	Visitors		@ 80%	131
	Commercial area (Upper Ground floor):	315.42	@ 1 person/6 m <sup>2</sup>	53
	Staff		@ 20%	11
	Visitors		@ 80%	42
3.	Community Centre	1357.71	@ 1 person/1.5 m <sup>2</sup>	905
	Staff		@ 20%	181
	Visitors		@ 80%	724
Grand Total				7,348

**8. Water requirement details;**

S. No.	Description	Occupancy	Rate of water demand(lpcd)	Total Water Requirement (KLD)
A.	Domestic Water			
1)	Residential			
	Residents	5414	86	465.6
	Maintenance Staff	271	30	8.13
	Visitor/Floating	541	15	8.11
2)	Commercial			
	Staff	44	30	1.32
	Visitors	173	15	2.59
3)	Community			
	Staff	181	30	5.43
	Visitors	724	15	10.86
	Total Domestic Water Demand			502.04 say 502 KLD
B.	Horticulture	10,182.21	3 lt./m <sup>2</sup> /day	31

C.	Filter Backwash			10
D.	Make up water for swimming pool			5
Total Water Requirement (A + B + C + D)				548 KLD

**9. Solid waste generation details:**

S. No.	Category	Norms (kg/c/day)	Total Waste (kg/day)
1.	Domestic Waste:		
	Residents (5414)	@ 0.5	2,707
	Total Staff (496)	@ 0.25	124
	Total Visitors (1438)	@ 0.15	215.7
2.	Landscape waste (2.51 acre)	@ 0.2 kg/acre/day	0.502
	TOTAL SOLID WASTE GENERATED		3,047.202 say 3,047 kg/day

**10. Parking details:**

Category	FAR (m <sup>2</sup> )	Parking Required	No. of ECS Required
Upper Basement Parking	13,708.07	1 ECS/30 m <sup>2</sup> F.A.R	456
Lower Basement Parking	13,634.80	1 ECS/30 m <sup>2</sup> F.A.R	454
Stilt Parking	3,845.85	1 ECS/30 m <sup>2</sup> F.A.R	128
Podium Parking	8,618.65	1 ECS/30 m <sup>2</sup> F.A.R	287
Open Parking (including visitor's parking)	2,143.00	1 ECS/20 m <sup>2</sup> F.A.R	107
Total Required Parking			1432 ECS

11. The project proposal falls under category-8(b) of EIA Notification, 2006 (as amended).

**Para-B:**

**Additional Conditions:**

1. In compliance to Hon'ble Supreme Court order dated 13/01/2020 in IA no. 158128/2019 and 158129/2019 in Writ petition no. 13029/1985 (MC Mehta Vs. GoI and others) anti-smog guns shall be installed to reduce dust during excavation.
2. The project proponent shall comply the use of fuel for backup power as per guidelines by "Commission of Air Quality Management in NCR", directions of courts and CPCB shall be strictly adhered regarding DG sets (cleaner fuel as PNG/CNG/permissible fuel in NCR). The project proponent shall follow the orders/guidelines issued by Hon'ble Court(s)/Competent authorities from time to time.
3. The proponent should provide the electric vehicle charging points and also allocate the safe and suitable place in the premises for the same.
4. Project Proponent should adopt 02 villages & develop them as model village.

**Standard Environmental Clearance Conditions prescribed by MoEF&CC:**

1. Statutory compliance:
  1. The project proponent shall obtain all necessary clearance/ permission from all relevant agencies including town planning authority before commencement of work. All the construction shall be done in accordance with the local building byelaws.
  2. The approval of the Competent Authority shall be obtained for structural safety of buildings due to earthquakes, adequacy of firefighting equipment etc as per National Building Code including protection measures from lightning etc.
  3. The project proponent shall obtain forest clearance under the provisions of Forest (Conservation) Act, 1986, in case of the diversion of forest land for non-forest purpose involved in the project.
  4. The project proponent shall obtain clearance from the National Board for Wildlife, if applicable.



5. The project proponent shall obtain Consent to Establish / Operate under the provisions of Air (Prevention & Control of Pollution) Act, 1981 and the Water (Prevention & Control of Pollution) Act, 1974 from the concerned State Pollution Control Board/ Committee.
6. The project proponent shall obtain the necessary permission for drawl of ground water / surface water required for the project from the competent authority.
7. A certificate of adequacy of available power from the agency supplying power to the project along with the load allowed for the project should be obtained.
8. All other statutory clearances such as the approvals for storage of diesel from Chief Controller of Explosives, Fire Department, Civil Aviation Department shall be obtained, as applicable, by project proponents from the respective competent authorities.
9. The provisions of the Solid Waste (Management) Rules, 2016, e-Waste (Management) Rules, 2016, and the Plastics Waste (Management) Rules, 2016 shall be followed.
10. The project proponent shall follow the ECBC/ECBC-R prescribed by Bureau of Energy Efficiency, Ministry of Power strictly.
2. Air quality monitoring and preservation:
  1. Notification GSR 94(E) dated 25.01.2018 of MoEF&CC regarding Mandatory Implementation of Dust Mitigation Measures for Construction and Demolition Activities for projects requiring Environmental Clearance shall be complied with.
  2. A management plan shall be drawn up and implemented to contain the current exceedance in ambient air quality at the site.
  3. The project proponent shall install system to carryout Ambient Air Quality monitoring for common/criterion parameters relevant to the main pollutants released (e.g. PM10 and PM25) covering upwind and downwind directions during the construction period.
  4. Construction site shall be adequately barricaded before the construction begins. Dust, smoke & other air pollution prevention measures shall be provided for the building as well as the site. These measures shall include screens for the building under construction, continuous dust/ wind breaking walls all around the site (at least 3 meter height). Plastic/tarpaulin sheet covers shall be provided for vehicles bringing in sand, cement, murrum and other construction materials prone to causing dust pollution at the site as well as taking out debris from the site.
  5. Sand, murrum, loose soil, cement, stored on site shall be covered adequately so as to prevent dust pollution.
  6. Wet jet shall be provided for grinding and stone cutting.
  7. Unpaved surfaces and loose soil shall be adequately sprinkled with water to suppress dust.
  8. All construction and demolition debris shall be stored at the site (and not dumped on the roads or open spaces outside) before they are properly disposed. All demolition and construction waste shall be managed as per the provisions of the Construction and Demolition Waste Rules 2016.
  9. The diesel generator sets to be used during construction phase shall be low sulphur diesel type and shall conform to Environmental (Protection) prescribed for air and noise mission standards.
  10. The gaseous emissions from DG set shall be dispersed through adequate stack height as per CPCB standards. Acoustic enclosure shall be provided to the DG sets to mitigate the noise pollution. The location of the DG set and exhaust pipe height shall be as per the provisions of the Central Pollution Control Board (CPCB) norms.
  11. For indoor air quality the ventilation provisions as per National Building Code of India.
3. Water quality monitoring and preservation:
  1. The natural drain system should be maintained for ensuring unrestricted flow of water. No construction shall be allowed to obstruct the natural drainage through the site, on wetland and

- water bodies. Check dams, bio-swales, landscape, and other sustainable urban drainage systems (SUDS) are allowed for maintaining the drainage pattern and to harvest rain water.
2. Buildings shall be designed to follow the natural topography as much as possible. Minimum cutting and filling should be done.
  3. Total fresh water use shall not exceed the proposed requirement as provided in the project details.
  4. The quantity of fresh water usage, water recycling and rainwater harvesting shall be measured and recorded to monitor the water balance as projected by the project proponent. The record shall be submitted to the Regional Office, MoEF&CC along with six monthly Monitoring reports.
  5. A certificate shall be obtained from the local body supplying water, specifying the total annual water availability with the local authority, the quantity of water already committed, the quantity of water allotted to the project under consideration and the balance water available. This should be specified separately for ground water and surface water sources, ensuring that there is no impact on other users.
  6. At least 20% of the open spaces as required by the local building bye-laws shall be pervious. Use of Grass pavers, paver blocks with at least 50% opening, landscape etc. would be considered as pervious surface.
  7. Installation of dual pipe plumbing for supplying fresh water for drinking, cooking and bathing etc and other for supply of recycled water for flushing, landscape irrigation car washing, thermal cooling, conditioning etc. shall be done.
  8. Use of water saving devices/ fixtures (viz. low flow flushing systems; use of low flow faucets tap aerators etc) for water conservation shall be incorporated in the building plan.
  9. Use of water saving devices/ fixtures (viz. low flow flushing systems; use of low flow faucets tap aerators etc) for water conservation shall be incorporated in the building plan.
  10. Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices referred.
  11. The local bye-law provisions on rain water harvesting should be followed. If local byelaw provision is not available, adequate provision for storage and recharge should be followed as per the Ministry of Urban Development Model Building Byelaws, 2016. Rain water harvesting recharge pits/storage tanks shall be provided for ground water recharging as per the CGWB norms.
  12. A rain water harvesting plan needs to be designed where the recharge bores of minimum one recharge bore per 5,000 square meters of built up area and storage capacity of minimum one day of total fresh water requirement shall be provided. In areas where ground water recharge is not feasible, the rain water should be harvested and stored for reuse. The ground water shall not be withdrawn without approval from the Competent Authority.
  13. All recharge should be limited to shallow aquifer.
  14. No ground water shall be used during construction phase of the project.
  15. Any ground water dewatering should be properly managed and shall conform to the a approvals and the guidelines of the CGWA in the matter. Formal approval shall be taken from the CGWA for any ground water abstraction or dewatering.
  16. The quantity of fresh water usage, water recycling and rainwater harvesting shall be measured and recorded to monitor the water balance as projected by the project proponent. The record shall be submitted to the Regional Office, MoEF&CC along with six monthly Monitoring reports.

17. Sewage shall be treated in the STP with tertiary treatment. The treated effluent from STP shall be recycled/re-used for flushing, AC make up water and gardening. As proposed, not related water shall be disposed in to municipal drain.
18. No sewage or untreated effluent water would be discharged through storm water drains.
19. Onsite sewage treatment of capacity of treating 100% waste water to be installed. The installation of the Sewage Treatment Plant (STP) shall be certified by an independent expert and a report in this regard shall be submitted to the Ministry before the project is commissioned for operation. Treated waste water shall be reused on site for landscape, flushing, cooling tower, and other end-uses. Excess treated water shall be discharged as per statutory norms notified by Ministry of Environment, Forest and Climate Change. Natural treatment systems shall be promoted.
20. Periodical monitoring of water quality of treated sewage shall be conducted. Necessary measures should be made to mitigate the odor problem from STP.
21. Sludge from the onsite sewage treatment, including septic tanks, shall be collected, conveyed and disposed as per the Ministry of Urban Development, Centre Public Health and Environmental Engineering Organization (CPHEEO) Manual on Sewerage and Sewage Treatment Systems, 2013.
4. Noise monitoring and prevention:
  1. Ambient noise levels shall conform to residential area/commercial area/industrial area/silence zone both during day and night as per Noise Pollution (Control and Regulation) Rules, 2000. Incremental pollution loads on the ambient air and noise quality shall be closely monitored during construction phase. Adequate measures shall be made to reduce ambient air and noise level during construction phase, so as to conform to the stipulated standards by CPCB / SPCB.
  2. Noise level survey shall be carried as per the prescribed guidelines and report in this regard shall be submitted to Regional Officer of the Ministry as a part of six-monthly compliance report.
  3. Acoustic enclosures for DG sets, noise barriers for ground-run bays, ear plugs for operating personnel shall be implemented as mitigation measures for noise impact due to ground sources.
5. Energy Conservation measures:
  1. Compliance with the Energy Conservation Building Code (ECBC) of Bureau of Energy Efficiency shall be ensured. Buildings in the States which have notified their own ECBC, shall comply with the State ECBC.
  2. Outdoor and common area lighting shall be LED.
  3. Concept of passive solar design that minimize energy consumption in buildings by using design elements, such as building orientation, landscaping, efficient building envelope, appropriate fenestration, increased day lighting design and thermal mass etc. shall be incorporated in the building design. Wall, window, and roof u-values shall be as per ECBC specifications.
  4. Energy conservation measures like installation of CFLs/ LED for the lighting the area outside the building should be integral part of the project design and should be in place before project commissioning.
  5. Solar, wind or other Renewable Energy shall be installed to meet electricity generation equivalent to 1% of the demand load or as per the state level/ local building bye-laws requirement, whichever is higher.
  6. Solar power shall be used for lighting in the apartment to reduce the power load on grid. Separate electric meter shall be installed for solar power. Solar water heating shall be

provided to meet 20% of the hot water demand of the commercial and institutional building or as per the requirement of the local building bye-laws, whichever is higher. Residential buildings are also recommended to meet its hot water demand from solar water heaters, as far as possible.

**6. Waste Management :**

1. A certificate from the competent authority handling municipal solid wastes, indicating the existing civic capacities of handling and their adequacy to cater to the M.S.W. generated from project shall be obtained.
2. Disposal of muck during construction phase shall not create any adverse effect on the neighboring communities and be disposed taking the necessary precautions for general safety and health aspects of people, only in approved sites with the approval of competent authority.
3. Separate wet and dry bins must be provided in each unit and at the ground level for facilitating segregation of waste. Solid waste shall be segregated into wet garbage and inert materials.
4. Organic waste compost/ Vermiculture pit/ Organic Waste Converter within the premises with a minimum capacity of 0.3 kg /person/day must be installed.
5. All non-biodegradable waste shall be handed over to authorized recyclers for which a written tie up must be done with the authorized recyclers.
6. Any hazardous waste generated during construction phase, shall be disposed off as per applicable rules and norms with necessary approvals of the State Pollution Control Board.
7. Use of environment friendly materials in bricks, blocks and other construction materials, shall be required for at least 20% of the construction material quantity. These include Fly Ash bricks, hollow bricks, AACs, Fly Ash Lime Gypsum blocks, Compressed earth blocks, and other environment friendly materials.
8. Fly ash should be used as building material in the construction as per the provision of Fly Ash Notification of September, 1999 and amended as on 27th August, 2003 and 25<sup>th</sup> January, 2016. Ready mixed concrete must be used in building construction.
9. Any wastes from construction and demolition activities related thereto shall be managed so as to strictly conform to the Construction and Demolition Rules, 2016.
10. Used CFLs and TFLs should be properly collected and disposed off/sent for recycling as per the prevailing guidelines/ rules of the regulatory authority to avoid mercury contamination.

**7. Green Cover:**

1. No tree can be felled/transplant unless exigencies demand. Where absolutely necessary, tree felling shall be with prior permission from the concerned regulatory authority. Old trees should be retained based on girth and age regulations as may be prescribed by the Forest Department. Plantations to be ensured species (cut) to species (planted).
2. A minimum of 1 tree for every 80 sqm of land should be planted and maintained. The existing trees will be counted for this purpose. The landscape planning should include plantation of native species. The species with heavy foliage, broad leaves and wide canopy cover are desirable. Water intensive and/or invasive species should not be used for landscaping.
3. Where the trees need to be cut with prior permission from the concerned local Authority, compensatory plantation in the ratio of 1:10 (i.e. planting of 10 trees for every 1 tree that is cut) shall be done and maintained. Plantations to be ensured species (cut) to species (planted). Area for green belt development shall be provided as per the details provided in the project document.
4. Topsoil should be stripped to a depth of 20 cm from the areas proposed for buildings, roads, paved areas, and external services. It should be stockpiled appropriately in designated areas and reapplied during plantation of the proposed vegetation on site.

8. Transport:
  1. A comprehensive mobility plan, as per MoUD best practices guidelines (URDPFI), shall be prepared to include motorized, non-motorized, public, and private networks. Road should be designed with due consideration for environment, and safety of users. The road system can be designed with these basic criteria.
    - a. Hierarchy of roads with proper segregation of vehicular and pedestrian traffic.
    - b. Traffic calming measures.
    - c. Proper design of entry and exit points.
    - d. Parking norms as per local regulation.
  2. Vehicles hired for bringing construction material to the site should be in good condition and should have a pollution check certificate and should conform to applicable air and noise emission standards be operated only during non-peak hours.
  3. A detailed traffic management and traffic decongestion plan shall be drawn up to ensure that the current level of service of the roads within a 05 kms radius of the project is maintained and improved upon after the implementation of the project. This plan should be based on cumulative impact of all development and increased habitation being carried out or proposed to be carried out by the project or other agencies in this 05 Kms radius of the site in different scenarios of space and time and the traffic management plan shall be duly validated and certified by the State Urban Development department and the P.W.D./ competent authority for road augmentation and shall also have their consent to the implementation of components of the plan which involve the participation of these departments.
9. Human health issues :
  1. All workers working at the construction site and involved in loading, unloading, carriage of construction material and construction debris or working in any area with dust pollution shall be provided with dust mask.
  2. For indoor air quality the ventilation provisions as per National Building Code of India.
  3. Emergency preparedness plan based on the Hazard identification and Risk Assessment (HIRA) and Disaster Management Plan shall be implemented.
  4. Provision shall be made for the housing of construction labour within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, crèche etc. The housing may be in the form of temporary structures to be removed after the completion of the project.
  5. Occupational health surveillance of the workers shall be done on a regular basis.
  6. A First Aid Room shall be provided in the project both during construction and operations of the project.
10. Corporate Environment Responsibility:
  1. The project proponent shall comply with the provisions contained in this Ministry's OM vide F.No. 22-65/2017-IA.III dated 1st May 2018, as applicable, regarding Corporate Environment Responsibility.
  2. The company shall have a well laid down environmental policy duly approved by the Board of Directors. The environmental policy should prescribe for standard operating procedures to have proper checks and balances and to bring into focus any infringements/deviation/violation of the environmental / forest / wildlife norms / conditions. The company shall have defined system of reporting infringements / deviation / violation of the environmental / forest / wildlife norms / conditions and / or shareholders / stake holders. The copy of the board resolution in this regard shall be submitted to the MoEF&CC as a part of six-monthly report.
  3. A separate Environmental Cell both at the project and company head quarter level, with qualified personnel shall be set up under the control of senior Executive, who will directly to the head of the organization.
  4. Action plan for implementing EMP and environmental conditions along with responsibility matrix of the company shall be prepared and shall be duly approved by competent authority. The year wise funds earmarked for environmental protection measures shall be kept in separate account and not to be diverted for any other purpose. Year wise progress of implementation of action plan shall be reported to the Ministry/Regional Office along with the Six Monthly Compliance Report.

11. Miscellaneous:

1. The project proponent shall prominently advertise it at least in two local newspapers of the District or State, of which one shall be in the vernacular language within seven days indicating that the project has been accorded environment clearance and the details of MoEFCC/SEIAA website where it is displayed.
2. The copies of the environmental clearance shall be submitted by the project proponents to the Heads of local bodies, Panchayats and Municipal Bodies in addition to the relevant offices of the Government who in turn has to display the same for 30 days from the date of receipt.
3. The project proponent shall upload the status of compliance of the stipulated environment clearance conditions, including results of monitored data on their website and update the same on half-yearly basis.
4. The project proponent shall submit six-monthly reports on the status of the compliance of the stipulated environmental conditions on the website of the ministry of Environment, Forest and Climate Change at environment clearance portal.
5. The project proponent shall submit the environmental statement for each financial year in Form-V to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently and put on the website of the company.
6. The project proponent shall inform the Regional Office as well as the Ministry, the date of financial closure and final approval of the project by the concerned authorities, commencing the land development work and start of production operation by the project.
7. The project authorities must strictly adhere to the stipulations made by the State Pollution Control Board and the State Government.
8. The project proponent shall abide by all the commitments and recommendations made in the EIA/EMP report, commitment made during Public Hearing and also that during their presentation to the Expert Appraisal Committee.
9. No further expansion or modifications in the plant shall be carried out without prior approval of the Ministry of Environment, Forests and Climate Change (MoEF&CC).
10. Concealing factual data or submission of false/fabricated data may result in revocation of this environmental clearance and attract action under the provisions of Environment (Protection) Act, 1986.
11. The Ministry may revoke or suspend the clearance, if implementation of any of the above conditions is not satisfactory.
12. The Ministry reserves the right to stipulate additional conditions if found necessary. The Company in a time bound manner shall implement these conditions.
13. The Regional Office of this Ministry shall monitor compliance of the stipulated conditions. The project authorities should extend full cooperation to the officer (s) of the Regional Office by furnishing the requisite data / information/monitoring reports.
14. The above conditions shall be enforced, inter-alia under the provisions of the Water (Prevention & Control of Pollution) Act, 1974, the Air (Prevention & Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986, Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 and the Public Liability Insurance Act, 1991 along with their amendments and Rules and any other orders passed by the Hon'ble Supreme Court of India / High Courts and any other Court of Law relating to the subject matter.
15. Any appeal against this EC shall lie with the National Green Tribunal, if preferred, within a period of 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.

**14. Sand/Morrum Mining at Plot No.381, 378, 383, 382, 384, 385, 386 Mi, 391, (Khand-2) Near Village: Korra Kanak, Tehsil: Fatehpur, Fatehpur., Shri K.P. Singh, M/s Kanwar Enterprises Pvt. Ltd. area 40.48 ha. File No. 4691\4379/Proposal No. SIA/UP/MIN/ 31813/2018**

The committee noted that the matter was earlier discussed in 617<sup>th</sup> SEAC meeting dated 06/01/2022 and directed is as follows:

*“The committee discussed the matter in depth and opined that a letter should be sent to District Magistrate, Fatehpur for providing the factual report (area & quantity) in view of inspection report of the joint committee. The copy of the letter should also be sent to Geology and Mining Department, U.P.”*

The SEIAA in its 557<sup>th</sup> meeting dated 17/01/2022 agreed with the recommendation of SEAC. The Secretariat sent a letter dated 04/03/2022 to District Magistrate, Fatehpur to provide a factual report of the mining site. District Magistrate, Fatehpur vide letter dated 10/05/2022 form a joint committee to inspect the site and provide factual report. The joint committee inspect the site on 24/05/2022 and District Magistrate, Fatehpur vide letter dated 06/01/2021 send a factual report to Director, Directorate of Environment for necessary action. As per factual report only 17.50 ha area is available for mining activity and 350000 m<sup>3</sup> Sand/Moram available at the mining site.

The committee also noted that the project proponent sent a letter dated 18/07/2022 along with factual report and requested to direct the authority/DGM to revise the mining plan as per factual report.

The committee discussed the matter in light of factual report and project proponent letter dated 18/07/2022 and directed the project proponent to revise the mining plan from District Administration/Directorate of Geology and Mining as per factual report provided by District Magistrate, Fatehpur. A letter should also be sent to Directorate of Geology and Mining, Lucknow and copy to District Magistrate, Fatehpur for necessary action.

**(Dr. Brij Bihari Awasthi)**  
Member

**(Umesh Chandra Sharma)**  
Member

**(Dr. Ratan Kar)**  
Member

**(Om Prakash Srivastava)**  
Member

**(Dr. Ajai Mishra)**  
Member

**(Ashish Tiwari)**  
Member-Secretary, SEAC-1

**(Rajive Kumar)**  
Chairman

**Nodal, SEAC-1**

MoM prepared by Secretariat in consultation with Chairman & Members on the basis of decisions taken by SEAC-1 during the meeting.

**Annexure-1**

**General and Specific Conditions for Gitti, Patthar & Boulder Mining Projects: -**

**A. General Conditions:**

1. This environmental clearance is subject to allotment of mining lease in favour of project proponent by District Administration/Mining Department.
2. Forest clearance shall be taken by the proponent as necessary under the law.
3. Any addition of the mining area, change of Khasra numbers, enhancement of capacity, change in mining technology, modernization, and scope of working shall again require prior environmental clearance as per EIA notification, 2006.
4. No change in the calendar plan including excavation, the quantum of mineral and waste shall be made.
5. Mining will be carried out as per the approved mining plan. In case of any violation of the mining plan, the Environmental Clearance given by SEIAA will stand cancelled.
6. Four ambient air quality monitoring stations shall be established in the core zone as well as in the buffer zone for RSPM, SPM, SO<sub>2</sub>, NO<sub>x</sub> monitoring. The location of the stations should be decided based on the meteorological data, topographical features, and environmentally and ecologically sensitive targets and frequency of monitoring should be undertaken in consultation with the State Pollution Control Board. The monitored data for criteria pollutants shall be regularly uploaded on the company's website and also displayed on the website.
7. Data on ambient air quality (RPM, SPM, SO<sub>2</sub>, NO<sub>x</sub>) should be regularly submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and the State Pollution Control Board / Central Pollution Control Board once in six months.
8. Ambient air quality at the boundary of the mine premises shall conform to the norms prescribed in MoEF notification no. GSR/826(E) dated 16.11.09.
9. Fugitive dust emissions from all the sources shall be controlled regularly. Water spraying arrangement on haul roads, loading and unloading, and at transfer points shall be provided and properly maintained.
10. Measures shall be taken for control of noise levels below 85 dBA in the work environment. Workers engaged in operations of HEMM, etc. shall be provided with earplugs/muffs and health records of the workers shall be maintained.
11. Industrial wastewater (workshop and wastewater from the mine) should be properly collected, treated to conform to the standards prescribed under GSR 422 (E) dated 19th May 1993 and 31st December 1993 or as amended from time to time. Oil and grease traps shall be installed before the discharge of workshop effluents.
12. Personnel working in areas shall be provided with protective respiratory devices like masks and they shall also be imparted adequate training and information on safety and health aspects.
13. Special measures shall be adopted to prevent the nearby settlements from the impacts of mining activities.
14. The transportation of the materials shall be limited to the day hours' time only.
15. Provision shall be made for housing the laborers within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, safe drinking water, medical health care, crèche, etc. The housing may be in the form of temporary structures to be removed after the completion of the project.
16. A separate Environmental Management Cell with suitably qualified personnel shall be setup under the control of a Senior Executive, who will report directly to the Head of the Organization.
17. The Project Proponent shall inform the Integrated Regional Office, MoEF&CC, GoI, Lucknow and State Pollution Control Board regarding the date of financial closures and final approval of the project by the concerned authorities and the date of start of land development work.



18. The funds earmarked for environmental protection measures shall be kept in a separate account and shall not be diverted for other purposes. The year-wise expenditure shall be reported to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and State Pollution Control Board
19. The Integrated Regional Office, MoEF&CC, GoI, Lucknow and State Pollution Control Board shall monitor compliance with the stipulated conditions. A complete set of documents including Environment Impact Assessment Report, Environmental Management Plan, Public hearing, and other documents information should be given to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and State Pollution Control Board
20. A copy of the environmental clearance shall be submitted by the Project Proponent to the Heads of the Local Bodies, Panchayat, and Municipal Bodies as applicable in the matter.
21. The Project Proponent shall advertise at least in two local newspapers widely circulated, one of which shall be in the vernacular language of the locality concerned, within 7 days of the issue of the clearance letter informing that the project has been accorded environmental clearance and a copy of the clearance letter is available with the State Level Environment Impact Assessment Authority (SEIAA).
22. The Project Proponent has to submit a regular half-yearly compliance report of the stipulated prior environmental clearance terms and conditions in hard and soft copy to the SEIAA, U.P. on 1<sup>st</sup> June and 1<sup>st</sup> December of each calendar year.
23. The SEIAA may alter/modify the above conditions or stipulate any further condition in the interest of environmental protection.
24. Concealing factual data or submission of false/fabricated data and failure to comply with any of the conditions mentioned above may result in withdrawal of this clearance and attract action under the provisions of the Environment (Protection) Act, 1986.

**B. Specific Conditions:**

1. At the time of operation, the project proponent will comply with all the guidelines issued by the Government of India/State Govt./District Administration related to Covid-19.
2. This environmental clearance does not create or verify any claim of the applicant on the proposed site/activity.
3. In case it has been found that the E.C. obtained by providing incorrect information, submitting that the distance between the two adjoining mines is greater than 500mt. and the area is less than 05ha, but factually the distance is less than 500 mt, and the mine is located in the cluster of area equal to or more than 05ha, the E.C issued will stand revoked.
4. This environmental clearance shall be subject to a valid lease in favor of the project proponent for the proposed mining proposals. In case, the project proponent does not have a valid lease, this environmental clearance shall automatically become null and void.
5. The Environmental clearance will be co-terminus with the mining lease period/Mining Plan whichever is less. The Mining plan approved by the Dept. of Mines and Geology shall be strictly implemented and shall not be operated beyond the validity period.
6. Explosive cannot be stored on the site. The Project proponent shall take approval from Chief Controller of Explosive, if applicable for use or storage of explosive or any such materials.
7. A comprehensive EIA including mining areas within 15 K.M. to assess the impact of the mining activity on the surrounding area shall be undertaken and a report submitted to this Authority within one year.
8. No two pits shall be simultaneously worked i.e. before the first is exhausted and reclamation work completed, no mineral bearing area shall be worked.
9. After exhausting the first mine pit and before starting mining operations in the next pit, reclamation and plantation work in the exhausted pit shall be completed to ensure that reclamation, forest cover, and vegetation are visible during the first year of mining operations in the next pit. This process will follow till the last pit is exhausted. Adequate rehabilitation of mined pit shall be completed before any new ore-bearing area is worked for expansion.
10. An adequate buffer zone shall be maintained between two consecutive mineral-bearing deposits.
11. The sprinkling of water on haul roads to control dust will be ensured by the project proponent.

12. Green belt development shall be carried out considering CPCB guidelines including the selection of plant species and in consultation with the local DFO / Agriculture Department. Herbs and shrubs shall also form a part of the afforestation programme besides tree plantation. The company shall involve local people in the plantation programme. Details of year-wise afforestation programme including rehabilitation of mined-out area shall be submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow every year.
13. Blast vibrations study shall be conducted and an observation report submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and UPPCB within six months. The report shall also include measures for the prevention of blasting associated impact on nearby houses and agricultural fields.
14. Controlled blasting techniques with sequential blasting shall be adopted. The blasting shall be carried out in the daytime only. The project proponent shall ensure prevention of displacement of human beings/wild animals/birds etc. and in case any such displacement is caused due to blasting/mining operation by any chance the project proponent shall take suitable measures for their rehabilitation and resettlement.
15. Appropriate arrangement for shelter and drinking water for the mining workers has to be ensured at the mining site.
16. Maintenance of village roads used for transportation of minerals is to be done by the company regularly at its own expenses. The link roads from mining area to main road shall be constructed as all-weather road with black topping and maintained by the project proponent.
17. The surface runoff rain water harvesting/rain water recharge and water conservation measures will be taken by project proponent in consultation with central /State ground water Board .The project proponent shall plan and implement collection drain and siltation basins of adequate size to arrest the silt and sediment flows from the mining area. The supernatant of the siltation basin and rain water harvested water shall be utilized for watering the haulage area, roads and green belt development etc.
18. Status of implementation shall be submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and UP Pollution Control Board within six months and thereafter every year from the next consequent year.
19. The self-environmental audit shall be conducted annually. Every three years third-party environmental audit shall be carried out.
20. Measures for prevention and control of soil erosion and management of silt shall be undertaken. Protection of dumps against erosion shall be carried out with geotextile matting or other suitable material, and thick plantations of native trees and shrubs shall be carried out at the dump slopes. Dumps shall be protected by retaining walls.
21. Trenches/garland drains shall be constructed at foot of dumps and coco filters installed at regular intervals to arrest silt from being carried to water bodies. An adequate number of Check Dams and Gully Plugs shall be constructed across seasonal/perennial nallahs if any flowing through the ML area and silts arrested. De silting at regular intervals shall be carried out.
22. Garland drain of appropriate size, gradient, and length shall be constructed for both mine pit and waste dump and sump capacity shall be designed keeping 50% safety margin over and above peak sudden rainfall (based on 50 years data) and maximum discharge in the area adjoining the mine site. Sump capacity shall also provide an adequate retention period to allow proper settling of silt material. Sedimentation pits shall be constructed at the corners of the garland drains and de silted at regular intervals.
23. Ground and surface water, if any in and near the core zone (within 5.0 km of the lease) shall be regularly monitored for contamination and depletion due to mining activity and records maintained. The monitoring data shall be submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and U.P. Pollution Control Board regularly. Further, monitoring points shall be located between the mine, and drainage in the direction of flow of groundwater shall be set up and records maintained.
24. Fugitive dust generation shall be controlled. Fugitive dust emission shall be regularly monitored at locations of nearest human habitation (including schools and other public amenities located nearest to sources of dust generation as applicable) and records submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and U.P. Pollution Control Board regularly.

25. Baseline data for ambient air quality shall be generated and maintained and RSPM level in ambient air in the nearby human habitation (villages) shall also be monitored along with other parameters.
26. Corporate Environmental Responsibility (CER) shall be by the project proponent and the details of the various heads of expenditure are to be submitted as per the guidelines provided in the recent CER notification No. 22-65/2017-IA.III dated 01/05/2018. Work to be executed with the installation of five hand pumps for drinking water, solar light in villages of streets, construction of two numbers of toilets at the primary school with name displayed and address and details of the beneficiary and gram Pradhan along with phone number, photographs should be submitted to Directorate as well as to the District Magistrate / Chief Development officers.
27. Transportation of minerals shall be done by covering the trucks with tarpaulin or other suitable mechanisms so that no spillage of mineral/dust takes place.
28. Occupational health and safety measures for the workers including identification of work-related health hazards, training on malaria eradication, HIV, and health effects on exposure to mineral dust, etc. shall be carried out. Periodic monitoring for exposure to respirable mineral dust on the workers shall be conducted and records maintained including the health records of the workers. Awareness programmes for workers on the impact of mining on their health and precautionary measures like the use of personal protective equipment etc. shall be carried out periodically. A review of the impact of various health measures shall be conducted followed by follow-up action wherever required.
29. The project proponent will ensure for employing local people as per requirement, necessary protection measures around the mine pit and waste dump, and garland drain around the mine pit and waste dump.
30. Topsoil / solid waste shall be stacked properly with proper slope and adequate safeguards and shall be utilized for backfilling (wherever applicable) for reclamation and rehabilitation of the mined-out area. Topsoil shall be separately stacked for utilization later for reclamation and shall not be stacked along with overburden.
31. Overburden (OB) shall be stacked at the earmarked dump site(s) only and shall not be kept active for long period. The maximum height of the dump shall not exceed 20 m, each stage shall preferably be of a maximum of 10 m and the overall slope of the dump shall not exceed 35°. The OB dump shall be backfilled. The OB dumps shall be scientifically vegetated with suitable native species to prevent erosion and surface runoff.
32. Monitoring and management of rehabilitated areas shall continue until the vegetation becomes self-sustaining. Compliance status shall be submitted to the Regional Office, Ministry of Environment & Forests, GoI, Lucknow, and U.P. Pollution Control Board on a six-monthly basis.
33. The slope of the mining bench and ultimate pit limit shall be as per the mining scheme approved by the Indian Bureau of Mines.
34. Permission for the abstraction of groundwater shall be taken from Central Ground Water Board. Regular monitoring of ground and surface water sources for level and quality shall be carried out by establishing a network of existing wells and constructing new piezometers during the mining operation. The monitoring shall be carried out four times in a year i.e., premonsoon (April/May), monsoon (August), post-monsoon (November), and winter (January), and the data thus collected shall be regularly sent to MoEF&CC, Central Ground Water Authority, and Regional Director, Central Ground Water Board.
35. The wastewater from the mine shall be treated to conform to the prescribed standards before discharging into the natural stream. The discharged water from the Tailing Dam, if any shall be regularly monitored and report submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow, Central Pollution Control Board, and the State Pollution Control Board.
36. Hydrogeological study of the area shall be reviewed by the project proponent annually. In case the adverse effect on groundwater quality and quantity is observed mining shall be stopped and resumed only after mitigating steps to contain any adverse impact on groundwater is implemented.
37. Vehicular emissions shall be kept under control and regularly monitored. Vehicles used for transportation of minerals and others shall have valid permissions as prescribed under Central Motor Vehicle Rules, 1989 and its amendments. The vehicles transporting minerals shall be

- covered with a tarpaulin or other suitable enclosures so that no dust particles / fine matters escape during the period of transportation. No overloading of minerals for transportation shall be committed. The trucks transporting minerals shall not pass through the wildlife sanctuary if any in the study area.
38. Prior permission from the Competent Authority shall be obtained for the extraction of groundwater if any.
  39. A final mine closure plan, along with details of Corpus Fund, shall be submitted to the Integrated Regional Office, MoEF&CC, GoI, Lucknow and U.P. Pollution Control Board 5 years in advance of final mine closure for approval.
  40. Project Proponent shall explore the possibility of using solar energy where ever possible.
  41. Commitment towards CER has to be followed strictly.
  42. Regular health checkup record of the mineworkers has to be maintained at the site in a proper register. It should be made available for inspection whenever asked.
  43. Project Proponent has to strictly follow the direction/guidelines issued by MoEF&CC, CPCB, and other Govt. Agencies from time to time.
  44. The blasting will be done only after getting permission from the Mining Department.

**Annexure-2**

**Standard Terms of Reference for the Mining Project prescribed by MoEF&CC, GoI**

- 1) Year-wise production details since 1994 should be given, clearly stating the highest production achieved in any one year prior to 1994. It may also be categorically informed whether there had been any increase in production after the EIA Notification 1994 came into force, w.r.t. the highest production achieved prior to 1994.
- 2) A copy of the document in support of the fact that the proponent is the rightful lessee of the mine should be given.
- 3) All documents including approved mine plan, EIA and Public Hearing should be compatible with one another in terms of the mine lease area, production levels, waste generation and its management, mining technology etc. and should be in the name of the lessee.
- 4) All corner coordinates of the mine lease area, superimposed on a High Resolution Imagery/ toposheet, topographic sheet, geomorphology and geology of the area should be provided. Such an Imagery of the proposed area should clearly show the land use and other ecological features of the study area (core and buffer zone).
- 5) Information should be provided in Survey of India Toposheet in 1:50,000 scale indicating geological map of the area, geomorphology of land forms of the area, existing minerals and mining history of the area, important water bodies, streams and rivers and soil characteristics.
- 6) Details about the land proposed for mining activities should be given with information as to whether mining conforms to the land use policy of the State; land diversion for mining should have approval from State land use board or the concerned authority.
- 7) It should be clearly stated whether the proponent Company has a well laid down Environment Policy approved by its Board of Directors? If so, it may be spelt out in the EIA Report with description of the prescribed operating process/procedures to bring into focus any infringement/deviation/ violation of the environmental or forest norms/ conditions? The hierarchical system or administrative order of the Company to deal with the environmental issues and for ensuring compliance with the EC conditions may also be given. The system of reporting of non-compliances / violations of environmental norms to the Board of Directors of the Company and/or shareholders or stakeholders at large, may also be detailed in the EIA Report.
- 8) Issues relating to Mine Safety, including subsidence study in case of underground mining and slope study in case of open cast mining, blasting study etc. should be detailed. The proposed safeguard measures in each case should also be provided.
- 9) The study area will comprise of 10 km zone around the mine lease from lease periphery and the data contained in the EIA such as waste generation etc. should be for the life of the mine / lease period.
- 10) Land use of the study area delineating forest area, agricultural land, grazing land, wildlife sanctuary, national park, migratory routes of fauna, water bodies, human settlements and other ecological features should be indicated. Land use plan of the mine lease area should be prepared to encompass preoperational, operational and post operational phases and submitted. Impact, if any, of change of land use should be given.
- 11) Details of the land for any Over Burden Dumps outside the mine lease, such as extent of land area, distance from mine lease, its land use, R&R issues, if any, should be given.
- 12) A Certificate from the Competent Authority in the State Forest Department should be provided, confirming the involvement of forest land, if any, in the project area. In the event of any contrary claim by the Project Proponent regarding the status of forests, the site may be inspected by the State Forest Department along with the Regional Office of the Ministry to ascertain the status of forests, based on which, the Certificate in this regard as mentioned above be issued. In all such cases, it would be desirable for representative of the State Forest Department to assist the Expert Appraisal Committees.
- 13) Status of forestry clearance for the broken up area and virgin forestland involved in the Project including deposition of net present value (NPV) and compensatory afforestation (CA) should be indicated. A copy of

the forestry clearance should also be furnished.

- 14) Implementation status of recognition of forest rights under the Scheduled Tribes and other Traditional Forest Dwellers (Recognition of Forest Rights) Act, 2006 should be indicated.
- 15) The vegetation in the RF / PF areas in the study area, with necessary details, should be given.
- 16) A study shall be got done to ascertain the impact of the Mining Project on wildlife of the study area and details furnished. Impact of the project on the wildlife in the surrounding and any other protected area and accordingly, detailed mitigative measures required, should be worked out with cost implications and submitted.
- 17) Location of National Parks, Sanctuaries, Biosphere Reserves, Wildlife Corridors, Ramsar site Tiger/ Elephant Reserves/(existing as well as proposed), if any, within 10 km of the mine lease should be clearly indicated, supported by a location map duly authenticated by Chief Wildlife Warden. Necessary clearance, as may be applicable to such projects due to proximity of the ecologically sensitive areas as mentioned above, should be obtained from the Standing Committee of National Board of Wildlife and copy furnished.
- 18) A detailed biological study of the study area [core zone and buffer zone (10 km radius of the periphery of the mine lease)] shall be carried out. Details of flora and fauna, endangered, endemic and RET Species duly authenticated, separately for core and buffer zone should be furnished based on such primary field survey, clearly indicating the Schedule of the fauna present. In case of any scheduled- I fauna found in the study area, the necessary plan alongwith budgetary provisions for their conservation should be prepared in consultation with State Forest and Wildlife Department and details furnished. Necessary allocation of funds for implementing the same should be made as part of the project cost.
- 19) Proximity to Areas declared as 'Critically Polluted' or the Project areas likely to come under the 'Aravali Range', (attracting court restrictions for mining operations), should also be indicated and where so required, clearance certifications from the prescribed Authorities, such as the SPCB or State Mining Department should be secured and furnished to the effect that the proposed mining activities could be considered.
- 20) R&R Plan/compensation details for the Project Affected People (PAP) should be furnished. While preparing the R&R Plan, the relevant State/National Rehabilitation & Resettlement Policy should be kept in view. In respect of SCs /STs and other weaker sections of the society in the study area, a need based sample survey, family-wise, should be undertaken to assess their requirements, and action programmes prepared and submitted accordingly, integrating the sectoral programmes of line departments of the State Government. It may be clearly brought out whether the village(s) located in the mine lease area will be shifted or not. The issues relating to shifting of village(s) including their R&R and socio-economic aspects should be discussed in the Report.
- 21) One season (non-monsoon) [i.e. March-May (Summer Season); October-December (post monsoon season) ; December-February (winter season)] primary baseline data on ambient air quality as per CPCB Notification of 2009, water quality, noise level, soil and flora and fauna shall be collected and the AAQ and other data so compiled presented date-wise in the EIA and EMP Report. Site-specific meteorological data should also be collected. The location of the monitoring stations should be such as to represent whole of the study area and justified keeping in view the pre-dominant downwind direction and location of sensitive receptors. There should be at least one monitoring station within 500 m of the mine lease in the pre-dominant downwind direction. The mineralogical composition of PM10, particularly for free silica, should be given.
- 22) Air quality modeling should be carried out for prediction of impact of the project on the air quality of the area. It should also take into account the impact of movement of vehicles for transportation of mineral. The details of the model used and input parameters used for modeling should be provided. The air quality contours may be shown on a location map clearly indicating the location of the site, location of sensitive receptors, if any, and the habitation. The wind roses showing pre-dominant wind direction may also be indicated on the map.
- 23) The water requirement for the Project, its availability and source should be furnished. A detailed water balance should also be provided. Fresh water requirement for the Project should be indicated.
- 24) Necessary clearance from the Competent Authority for drawl of requisite quantity of water for the Project should be provided.
- 25) Description of water conservation measures proposed to be adopted in the Project should be given.

- 26) Details of rainwater harvesting proposed in the Project, if any, should be provided.
- 27) Impact of the Project on the water quality, both surface and groundwater, should be assessed and necessary safeguard measures, if any required, should be provided.
- 28) Based on actual monitored data, it may clearly be shown whether working will intersect groundwater.
- 29) Necessary data and documentation in this regard may be provided. In case the working will intersect groundwater table, a detailed Hydro Geological Study should be undertaken and Report furnished. The Report inter-alia, shall include details of the aquifers present and impact of mining activities on these aquifers. Necessary permission from Central Ground Water Authority for working below ground water and for pumping of ground water should also be obtained and copy furnished.
- 30) Details of any stream, seasonal or otherwise, passing through the lease area and modification / diversion proposed, if any, and the impact of the same on the hydrology should be brought out.
- 31) Information on site elevation, working depth, groundwater table etc. Should be provided both in AMSL and bgl. A schematic diagram may also be provided for the same.
- 32) A time bound Progressive Greenbelt Development Plan shall be prepared in a tabular form (indicating the linear and quantitative coverage, plant species and time frame) and submitted, keeping in mind, the same will have to be executed up front on commencement of the Project. Phase-wise plan of plantation and compensatory afforestation should be charted clearly indicating the area to be covered under plantation and the species to be planted. The details of plantation already done should be given. The plant species selected for green belt should have greater ecological value and should be of good utility value to the local population with emphasis on local and native species and the species which are tolerant to pollution.
- 33) Impact on local transport infrastructure due to the Project should be indicated. Projected increase in truck traffic as a result of the Project in the present road network (including those outside the Project area) should be worked out, indicating whether it is capable of handling the incremental load. Arrangement for improving the infrastructure, if contemplated (including action to be taken by other agencies such as State Government) should be covered. Project Proponent shall conduct Impact of Transportation study as per Indian Road Congress Guidelines.
- 34) Details of the onsite shelter and facilities to be provided to the mine workers should be included in the EIA Report.
- 35) Conceptual post mining land use and Reclamation and Restoration of mined out areas (with plans and with adequate number of sections) should be given in the EIA report.
- 36) Occupational Health impacts of the Project should be anticipated and the proposed preventive measures spelt out in detail. Details of pre-placement medical examination and periodical medical examination schedules should be incorporated in the EMP. The project specific occupational health mitigation measures with required facilities proposed in the mining area may be detailed.
- 37) Public health implications of the Project and related activities for the population in the impact zone should be systematically evaluated and the proposed remedial measures should be detailed along with budgetary allocations.
- 38) Measures of socio economic significance and influence to the local community proposed to be provided by the Project Proponent should be indicated. As far as possible, quantitative dimensions may be given with time frames for implementation.
- 39) Detailed environmental management plan (EMP) to mitigate the environmental impacts which, should inter-alia include the impacts of change of land use, loss of agricultural and grazing land, if any, occupational health impacts besides other impacts specific to the proposed Project.
- 40) Public Hearing points raised and commitment of the Project Proponent on the same along with time bound Action Plan with budgetary provisions to implement the same should be provided and also incorporated in the final EIA/EMP Report of the Project.
- 41) Details of litigation pending against the project, if any, with direction /order passed by any Court of Law against the Project should be given.
- 42) The cost of the Project (capital cost and recurring cost) as well as the cost towards implementation of EMP should be clearly spelt out.
- 43) A Disaster management Plan shall be prepared and included in the EIA/EMP Report.
- 44) Benefits of the Project if the Project is implemented should be spelt out. The benefits of the Project shall

clearly indicate environmental, social, economic, employment potential, etc.

45) Besides the above, the below mentioned general points are also to be followed:-

- a) Executive Summary of the EIA/EMP Report
- b) All documents to be properly referenced with index and continuous page numbering.
- c) Where data are presented in the Report especially in Tables, the period in which the data were collected and the sources should be indicated.
- d) Project Proponent shall enclose all the analysis/testing reports of water, air, soil, noise etc. using the MoEF&CC/NABL accredited laboratories. All the original analysis/testing reports should be available during appraisal of the Project.
- e) Where the documents provided are in a language other than English, an English translation should be provided.
- f) The Questionnaire for environmental appraisal of mining projects as devised earlier by the Ministry shall also be filled and submitted.
- g) While preparing the EIA report, the instructions for the Proponents and instructions for the Consultants issued by MoEF&CC vide O.M. No. J-11013/41/2006-IA.II(I) dated 4th August, 2009, which are available on the website of this Ministry, should be followed.
- h) Changes, if any made in the basic scope and project parameters (as submitted in Form-I and the PFR for securing the TOR) should be brought to the attention of MoEF&CC with reasons for such changes and permission should be sought, as the TOR may also have to be altered. Post Public Hearing changes in structure and content of the draft EIA/EMP (other than modifications arising out of the P.H. process) will entail conducting the PH again with the revised documentation.
- i) As per the circular no. J-11011/618/2010-IA.II(I) dated 30.5.2012, certified report of the status of compliance of the conditions stipulated in the environment clearance for the existing operations of the project, should be obtained from the Regional Office of Ministry of Environment, Forest and Climate Change, as may be applicable.
- j) The EIA report should also include: (i) surface plan of the area indicating contours of main topographic features, drainage and mining area, (ii) geological maps and sections and (iii) sections of the mine pit and external dumps, if any, clearly showing the land features of the adjoining area.