

टीएचडीसी इंडिया लिमिटेड (भारत सरकार एवं उ.प्र. सरकार का संयुक्त उपक्रम) शेड्यूल 'ए' मिनी रत्न कम्पनी

THDC INDIA LIMITED

(A Joint Venture of Govt. of India & Govt. of U.P.) Schedule-'A'- Mini Ratna Company NCR Office: Plot No. 20, Sector-14, Kaushambi, Ghaziabad-201010 (U.P.)

Phones : 0120-2816800,0120-2816900, Fax : 0120-2776499

Ref: 150/ THDCIL/KAU/Th-D/1912

Date:30/01/2017

0

Director

IA -Division (Thermal Power) Ministry of Environment,Forest & CC, Jorbagh Road, Lodhi Road, New Delhi-110003

Subject: Clarifications Sought during EAC Meeting Held on 28th December, 2016/Item No. 2.11 regarding EC for Khurja Super Thermal Power Project (2 x 660 MW) at Khurja, District Bulandshahr, UP

Ref: MOEF&CC File NO. J-13012/100/2011-IA II (T)

With reference to the above subject, we are hereby submitting the clarifications sought during EAC meeting for environmental appraisal of the proposed project by the Hon'ble committee of Thermal Power Projects, in hard copy as well as in soft copy.

We request your good self to kindly consider the same and recommend the Environmental Clearance for our above referred project.

Thanking You

Yours Sincerely

(U.C Kannaujia)

General Manager (SP) Mob. No. 9411103637

Attachments: Reply of ADS generated for the proposed project.

कारपोरेट कार्यालय ः गंगा भवन, बाई पास रोड, प्रगतिपुरम, ऋषिकेश–249201, दूरमाष ः 2431517, 2431457, 2431522 फैक्स ः 0135-2431520 Corporate Office : Ganga Bhawan, By-Pass Road, Pragatipuram, Rishikesh - 249 201, Tel.: 2431517, 2431457, 2431522 Fax: 0135-2431520

> पंजीकृत कार्यालयः भागीरथी भवन, (टॉप टेरिस), भागीरथीपुरम, टिहरी गढ़वाल–249001 Regd. Office : BHAGIRATHI BHAWAN, (TOP TERRACE), BHAGIRATHIPURAM, TEHRI GARHWAL-249001

Clarifications sought by the EAC on EIA of Thermal Power Projects

Project: Proposed 2 x 660 MW Khurja Super Thermal Power Project

<u>Clarifications of the observations of the 1stEAC (Thermal) meeting held on</u> <u>28th December, 2016</u>

1. The EIA prepared by Mantec Consultants (P) Ltd, is not comprehensive. PP could not provide the quantity of fly ash generated and concrete disposal plan. All the maps and layouts provided in the EIA are not legible.

Reply:

Mantec Consultants (P) Ltd., New Delhi has prepared the EIA Report as per TOR prescribed by MOEF&CC. However, the clarifications sought during the EAC meeting are submitted as follows.

(a) The detail of fly ash generation is covered in Section 1.5, Chapter-1 of Annexure-XIII of the EIA Report. The details of Fly Ash generation and disposal plan are given below:

The proposed power plant will consume approx. 5.4 million TPA coal, with average ash content less than 34%. Therefore, the maximum quantity of ash generation will be 1.836 million TPA. Out of this, the quantity of bottom ash will be approx. 0.3672 MTPA (@20%) and the fly ash quantity will be approx.1.469 million TPA (@80%).

Annual coal consumption	: 5.4 million TPA
Maximum ash content	: 34%
Total ash generation, max.	: 1.836 million TPA
Fly ash generation, max. (@80%)	: 1.469 million TPA
Bottom ash generation, max. (@20%)	: 0.367 million TPA

Ash Handling & Disposal system

Ash Handling System: The bottom ash shall be extracted and disposed-off with Wet Disposal or High Concentration Slurry Disposal (HCSD) system. The fly ash along with air pre-heater ash shall be conveyed in dry form from the ash collection hoppers. This dry fly as ash shall be taken to buffer hoppers for its onward transportation in dry form to storage silos near plant boundary for utilization. In case of non-utilization during first four years of operation, fly ash shall be disposed-off as high concentration slurry in the Ash Dyke.

Bottom Ash Handling System: Bottom ash shall be extracted either by using a continuously operating submerged scraper chain conveyor system or by using intermittently operating jet pumps in conjunction with a water-impounded hopper. Dry type bottom ash hoppers shall be used in case of the submerged scraper chain conveyor 1 | Page

system. In case of continuous bottom ash extraction system involving submerged scrapper conveyors, the bottom ash from both units is pumped to the dewatering bin and mixing tank of HCSD system for disposal to the dyke In case of the intermittently operating jet pump system, the jet pumps would convey the bottom ash slurry from water impounded bottom ash hoppers to the dewatering bin and mixing tank of HCSD system for disposal to the dyke. Economizer ash shall be handled in wet form. Coarse ash slurry from economizer hoppers shall also be led to bottom ash hopper for disposal with bottom ash. No pits will be permitted in the boiler bottom area to accommodate the water impound hoppers.

Fly Ash Handling System: Pneumatic conveying system shall be employed for conveying of fly ash and air pre-heater ash from the electrostatic precipitator hoppers and air pre-heater hoppers in dry form. This dry ash shall be taken to buffer hoppers provided separately for each unit. The dry ash buffer hoppers shall be located adjacent to the ESP. Dry ash from buffer hoppers shall be transported to main storage silos near the plant boundary. In case of non-utilization of fly ash, the dry ash from buffer hoppers shall be transferred to HCSD ash silos. The dry ash transfer system shall be provided for each unit for transportation from buffer hoppers to the either set of silos. The user industries shall take the dry fly ash from the main storage silos either in closed tankers or in open tankers. These silos shall also have rail loading facility.

Ash slurry disposal: The bottom ash and coarse ash slurry from both the units shall be transported through HCSD system. Dewatering bin and belt conveyer system shall be provided for transportation of bottom ash to mixing tank of HCSD system. Two numbers (one working and one standby) ash slurry pump with all accessories and ash water sump shall be provided for pumping bottom ash to dewatering bin. Un-utilized fly ash collected in HCSD silos shall be mixed with water in an agitator tank at controlled rate to obtain the desired high concentration with Bottom Ash. This high concentration slurry comprising bottom & coarse ash as well as any unutilized fly ash shall be pumped to ash dyke located adjacent to the plant. There shall be four (4) working and two (2) standby HCSD stream for all units. Each stream will consist of one (1) no. HCSD pump. All the pumping streams shall be provided with their individual disposal pipes.

Ash Water Recirculation System: It is proposed to provide ash water re-circulation system to meet the requirements of environmental authority. Decanted water of about 1150 m3/hr from the ash pond shall be led to the plant area using 2x 100 % capacity ash water recirculation pumps and the same shall be conveyed through pipes from ash dyke to plant area. This water will be used further in the ash handling system. Normal make up to the ash water system shall be from CW blow down water. However, provision shall also be kept for operating ash water system on "Once Through" mode also i.e. when ash water is not available for recirculation. During "Once Through" mode operation, additional makeup shall be met from the plant raw water supply.

Ash Pond Fugitive Dust Suppression System: Suppression of fugitive dust from the ash pond area shall be done by spraying decanted ash water, using sprinklers mounted on banks at intervals along the periphery of ash dyke. Water will be pumped from the ash

water recirculation pump house through dust suppression water header to the sprinkler nozzles. 2×100 % pumps are provided for this purpose to cater to the requirements of both lagoons. The sprinklers shall be of swiveling type mounted at a height to ensure sufficient coverage for mitigating the fugitive dust problem.

Fly Ash Utilization

As per the applicable guidelines issued by MoEF& CC, the facility has targeted to utilize 50% of the total fly ash generated during the first year of operation, 70% & 90% in 2nd & 3rd year respectively and 100% utilization by end of the fourth year of operation. An ash pond, covering approx. 276 acres of land located within the project area, is proposed for disposal of bottom ash as well as any un-utilized fly ash during the first 4 years of operation. Fly ash generation and year wise action plan has been presented below:

S.N o.	Target Date (By end of)	Percentage Utilization of Fly Ash	Fly Ash disposed through user industries (Million TPA)	Bottom Ash disposed through user industries (Million TPA)	Ash disposed in Ash Pond (Million TPA)		n Ash TPA)
					Fly Ash	Bottom Ash	Total
1	1 st Year	50%	0.735	0.184	0.73 5	0.184	0.919
2	2 nd Year	70%	1.028	0.257	0.44 1	0.110	0.551
3	3 rd Year	90%	1.322	0.330	0.14 7	0.037	0.184
4	4 th Year	100%	1.469	0.367	0	0.000	0.00

Year wise target for Ash Utilization as per MoEF notification

During the Market Survey for Ash Utilization Study sponsored by THDC India Ltd., potential users such as Cement Industries, Concrete Plants, Bricks and Blocks Manufacturers for utilization of Fly Ash and bottom ash located within the 100 Km periphery of the project were identified. The following four entrepreneurs working in the area of manufacturing and supply of ready mix concrete (RMC), have expressed their willingness to utilize fly ash from the proposed plants for making RMC.

S.No.	Industries/Companies Utilization	for	Fly	Ash	Quantity required (Tonnes/day)
1	Adycon Infrastructures Pvt Ltd			1500	
2	Ficus E-Logic Pvt Ltd				1100
3	Mahesh Enterprises				2250
4	Star Corporation				2000
Total Ash Utilization Tie-ups			6850		

As suggested by EAC, MoEF during presentation of Khurja STPP on 28.12.2016, Cement manufacturing industries located near Project area were approached for utilization of Fly Ash and Bottom Ash.

Subsequently, following agencies have expressed their interest to utilize the Fly Ash/Bottom Ash:

			Fly Ash
S.No.	Agency	User Type	Requirement (tons
			per day)
1	J K Lakshmi Cement Ltd., Sikandrabad	Cement Manufacturers	Agreed for Lifting
	Unit		
2	Ambuja Cement Ltd., Dadri Unit	Cement Manufacturers	Agreed for Lifting
3	Mangalam Cement Ltd., Aligarh Unit	Cement Manufacturers	400-500
4	J K Cement	Cement Manufacturers	Not mentioned
5	Ashtech(India) Pvt. Ltd.	Fly Ash Distributor	4000 (Fly Ash)
			1500 (Bottom Ash)

Note: 4000 tons (Approx.) of Fly Ash and 1500 tons (Approx.) of Bottom Ash shall be generated per day from the proposed Plant.

All Letter of Intents for ash utilization are enclosed as **Enclosure-1(a)-1(i)**.

Hence, THDCIL will be able to achieve 100% fly ash utilization.

(b) All the maps and layout plans of the EIA/EMP report have been prepared in A-3 size and are attached as **Enclosure 2(a) – 2 (i)**.

2. A natural drain (Aligarh Nallah) is passing through the project site. Justification for diverting this nallah has not been provided. Hydrology report prepared by NIH, Roorkee and their recommendations have not been provided.

Reply:

Aligrah Nallah passing through the site is required to be diverted to accommodate the plant layout and optimum utilization of the land. The nallah shall be diverted through the existing ditch along the side of NH-91 only in the stretch of plant facilities without alternating natural topography and ecological balance.

The Hydrology study carried out by NIH Roorkee, envisages identification of various flooding sources and estimation of maximum flood level. Further, this study also includes study of local drainage pattern and modification of existing Aligarh drain. The main conclusions of the report are as follows:

- The Digital Elevation Model (DEM) of the study area is prepared from surveyed contour (0.5 m) for the plant area, spot heights; contour digitized from the SOI toposheets and SRTM data. The basin boundary and drainage networks are delineated manually from the DEM and SOI toposheets inside ArcGIS.
- 2. The catchment area of Aligarh drain up to proposed plant boundary, its length and slope are

4 | Page

used to derive unit hydrograph using the guideline provided by CWC.

- 3. The 1-day annual maximum rainfall for various return periods are estimated for the site Aligarh, Bulandshahr, Khurja by rainfall frequency analysis using L-moments approach. Similarly the regional 1-day annual maximum rainfall for various return periods are also estimated.
- 4. The regional L-moments based approach resulted in maximum rainfall value based on the data of three stations for 100 year return period rainfall. Hence, regional 1-day annual maximum rainfalls for 100 year return period is used for design flood estimation and drain design. The regional rainfall estimated using the rainfall data of three rain gauge stations are 20.71 cm, 24.65 cm and 28.99 cm respectively for 25, 50 and 100 year return periods respectively.
- 5. The Peak discharge (m3/s) in Aligarh drain for 2, 10, 25, 50 and 100 year return periods are found to be 20.13 m3/s, 44.06 m3/s, 59.1 m3/s, 71.59 m3/s and 85.88m3/s respectively from its catchment area of 10.5 km2.
- 6. It is observed that the existing cross-section of Aligarh drain is unable to carry design discharge. Hence, modified lined trapezoidal cross-sections is proposed. Moreover, possible re-alignment of Aligarh drain is also proposed. However, the width is limited to 10 m and overflow has been allowed.
- 7. The potential source of flooding at the plant site is due to the local rainfall and overflow from the Aligarh drain also.
- 8. The land formation level should be based on the computed maximum flood elevation for severe most flooding scenario (100 year return period), model uncertainty and limitation of data availability. Considering these aspects, it is suggested to have the safe grade level in the plant area higher than RL 193.5 m and the plinth levels should be higher than 194.1 m or 194.4 m to avoid any drainage congestion due to highway alignment. The land development work within the plant site should be carried out to maintain the natural slope to facilitate the drainage in the area and divert any entry of excess water through plant boundary.
- 9. The peak flow for 25 and 50 year return period rainfall is estimated for various local and periphery drain sections and the trapezoidal drains are designed using Manning's formula and free board is provided as per BIS standard IS 10430-2000.
- 10. The local and periphery drains are designed for trapezoidal section with a side slope of 1.5:1 (H:V) and longitudinal slope of 0.001 m/m (1.0 m/km) to carry the discharge generated locally. Moreover, the drain sections are designed for velocity less than 2 m/s and Manning's roughness coefficient (n) values of 0.015.

A copy of the report is attached as **Enclosure-3**.

3. It is observed that EIA which was submitted to the Ministry post public hearing and the EIA which has been circulated to EAC Members for meeting has some difference in baseline data. Baseline data for March-May, 2016 has also been collected in addition to October-December, 2012 and incorporated the same in the EIA. However, the same has not been clarified in the report, why additional baseline data has been provided.

Reply:

The EIA report, based on baseline data collected during October-December, 2012 and taking care of the issues raised during public hearing held on 1st August 2012, was submitted to MoEF&CC on 6th October, 2015. Appraisal of the project was held up due to non-availability of firm coal linkage – which was finally received vide Ministry of Coal letter dated 29thAugust 2016. Meanwhile, with notification of Environment (Protection) Amendment Rules, 2015 dated 7th December, 2015, water consumption and emission norms for thermal power plants were changed significantly. These factors required some changes in the EIA report. As a period of 3 years had elapsed since generation of baseline data in October – December, 2012, it was considered worthwhile to revalidate the same by repeating it for 1 more season, i.e., March – May, 2016.

4. In the EIA, baseline data for NOx and SO2 results have been shown in the Ozone values. The whole EIA report has been prepared in qualitative manner.

Reply:

Although the observed mean values of pollutants mentioned under sub-section 4.5.4 (Data analysis & Conclusion) are correct, mention of "SO2" under discussions on NOx and ozone are typographical errors.

The corrected sub-section 4.5.4 Data Analysis and Conclusion is as follows.

Data Analysis& Conclusion

- Suspended Particulate Matter (SPM): During post-monsoon season of 2012, the maximum observed SPM concentration was 196µg/m³ at Jawal village, while the same during pre-monsoon season of 2016 was 198µg/m³ at all the four locations. Average values of SPM concentrations were in the range 173.7-177.1µg/m³ during post-monsoon season of 2012 and 186.7-189.5µg/m³ during pre-monsoon season of 2016. During both seasons, the lowest concentrations were observed at Bhogpur RF.
- **Respirable Particulate Matter (PM₁₀):** During post-monsoon season of 2012, the maximum observed PM₁₀ concentration was 84µg/m³ at Bhogpur RF, while the same during pre-monsoon season of 2016 was 92µg/m³ at Bhogpur RF. These concentrations are well within the applicable limit of 100µg/m³ for industrial, residential, rural and other areas. Average values of PM₁₀ concentrations were in the range 68.5-70.9µg/m³ during 2012 and 75.5-77.9µg/m³ during 2016.
- Particulate Matter 2.5 (PM_{2.5}): During post-monsoon season of 2012, the maximum observed PM_{2.5} concentration was 42μg/m³ at Bhogpur RF, while the same during premonsoon season of 2016 was 24 hours 48 μg/m³ at Bhogpur RF. These concentrations are well within the applicable limit of 60 μg/m³ for industrial, residential, rural and other areas. Average values of PM_{2.5}concentrations were in the range 34.3-35.6 μg/m³ during 2012 and 38.5-39.8 μg/m³ during 2016.

- **Sulphur Dioxide (SO₂):** During post-monsoon season of 2012, the maximum observed SO₂ concentration was 17.2 μ g/m³ at Gwarauli village, while the same during premonsoon season of 2016 was 19 μ g/m³ at Gwarauli village. These concentrations are well within the applicable limit of 80 μ g/m³ for industrial, residential, rural and other areas. Average values of SO₂ concentrations were in the range 11.5 to 12.7 μ g/m³ during 2012 and 12.8-13.9 μ g/m³ during 2016.
- **Nitrogen Oxides (NO_x):** During post-monsoon season of 2012, the maximum observed NOx concentration was 32 μ g/m³ at Gwarauli village, while the same during premonsoon season of 2016 was 35 μ g/m³ at Bhogpur RF, Gwarauli & Jawal villages. These concentrations are well within the applicable limit of 80 μ g/m³ for industrial, residential, rural and other areas. Average values of NO₂ concentrations were in the range 24.3 to 26.8 μ g/m³ during 2012 and 26.8-29.4 μ g/m³ during 2016.
- **Ozone (O**₃): During post-monsoon season of 2012, the maximum observed O₃ concentration was $31.8\mu g/m^3$ at Jawal village, while the same during pre-monsoon season of 2016 was $35\mu g/m^3$ at Jawal village. These concentrations are well within the applicable limit of 100 $\mu g/m^3$ for industrial, residential, rural and other areas. Average values of O₃concentrations were in the range of 25.8 to 26.7 $\mu g/m^3$ during 2012 and 28.4 to 29.4 $\mu g/m^3$ during 2016.
- **Mercury (Hg):** The value of mercury was found to be below detectable limit (bdl) at all 4 monitoring locations during the two seasons of survey.

Conclusion: The existing levels of monitored air pollutants in the study area are well within the prescribed limits and the area can accommodate further development with controlled emissions.

5. Details of Quantitative Risk Assessment and credible failure scenarios for Hazardous Chemical containers such as Fuel Oil, Transformer Oil, Chlorine, etc have not been provided in the EIA

Reply: Separate Report for Quantitave Risk Assessment and credible failure scenarios for Hazardous Chemical containers such as Fuel Oil, Transformer Oil, Chlorine, etc for the proposed project is given as **Enclosure- 4**.

Consequence analysis was carried out for identified selected failure cases given in the report. Damage distances for the accidental release of hazardous materials have been computed at 2F, 3D and 5D weather conditions. In these conditions, 2, 3 and 5 are wind velocities in m/s and F and D are atmospheric stability classes. Credible Failure scenarios considered are given below:

- 1. 25 mm, 50 mm Leak and Catastrophic rupture in LDO & Transformer Oil Storage Tank
- 2. 10 mm leak & catastrophic rupture from Hydrogen Cylinder & compressor
- 3. 2mm leak from Flange of Chlorine tonner

4. 10mm leak & catastrophic rupture from Ammonia Bullet storage tank

Risk evaluation shows individual risk to be 8.274×10^{-6} /yr and societal risk to be 1.234×10^{-5} /yr, which are both in the acceptable region as per HSE UK.

Hence, proposed project is safe to be operated as Impact distance due to failure scenario and Overall risk calculated are well within the limits.

6. Native and indigenous species have not been proposed in the EIA which shall be part of green belt development plan.

Reply: Native and indigenous species have been proposed for greenbelt development as per guideline of CPCB 2000. 26 Trees, 5 small trees, and 14 shrub species were proposed. Species for plantation were selected according to the agro climatic zone and subzones mentioned in the guideline. Detailed Green Belt Development Plan including native and indigenous species is given as **Enclosure-5**.

S.No.	Description of Enclosure				
1	Agreement letters for Ash Util	lization			
	Maps and Layout plans of the EIA/EMP report				
	Maps/Layout	Cross-referencing with EIA/EMP Report Page No.			
	Buffer Map of Study Area	36			
	Satellite Map of Study Area	84			
	Landuse Map of Study Area	85			
2	Soil Monitoring Location Map of Study Area	89			
	Water Monitoring Location Map of Study Area	93			
	Air Monitoring Location Map of Study Area	103			
	Noise Monitoring Location Map of Study Area	113			
	Water Balance Diagram				
	Layout Plan of the Project Site				
3	Hydrographical Area Draina Roorkee	nge Study Report by NIH,			
4	Quantitave Risk Assessme scenarios Report	nt and credible failure			
5	Green Belt Development Plan				

ENCLOSURE-1(a)-1(i)

Enclosure-1(a)



NS-EN ISO 9001:2000/ISO 9001:2000



Adycon Infrastructures Pvt. Ltd.

Head Office : KG-18, NEW KAVI NAGAR, GHAZIABAD - 20 1002 (U.P.) Plant : GHAZIABAD • INDIRAPURAM • NOIDA • GREATER NOIDA Mobile : 9891776363, 9810349868 Telefax : 0120-4330472 E-mail : adycon.infrastructures@gmail.com • Web. : adyconrmc.com

Sept 25, 2012

THDC India Limited Design-Thermal Department Plot No. 20, Sector-14 Kaushambi, Ghaziabad-201 010, U. P.

Sub. Regarding utilization of Fly Ash Produced by Upcoming Coal based Khurja Super Thermal Power Project (2 x 660 MW) in Khurja, Dist. Bulandshahar, U. P.

Dear Sir,

We have been informed by M/S Mantec Consultants Pvt. Ltd., the agency engaged by you for Ash Utilization Study, that THDC India Ltd. is planning to set up 2 X 660 MW coal based super thermal power project, at Khurja, Distt. Buland shaher (U.P.).

During discussions, it was also informed that about 7400 tonnes of Fly Ash is expected to be produced daily, once the project is commissioned in the year 2017.

With regard to possibility of utilization of the produced ash, we would like to inform as follows:

- We are in the business of Ash utilization and the company profile is enclosed as Annexure A.
- ii.) We Adycon Infrastructures Pvt. Limites, Ghaziabad are intend to utilize 1500 tones per day of fly ash produced by Khurja STPP on mutually agreeable terms and condition.

Looking forward to associate with THDC.

Thanking you,

Yash Gupta

Director Adycon Infrastructures Pvt. Limited

Enclosure-1(b)

Ficus E-Logic Pvt Ltd

A-16, Sector-65, Noida- 201301 Phone: 0120-4227924, Email: Info@ficuslogic.co.in

Reference No. FEL/Fly Ash/0121

THDC India Limited Design-Thermal Department Plot No. 20, Sector-14 Kaushambi, Ghaziabad-201 010, U. P.

October 1, 2012

Sub. Regarding utilization of Fly Ash Produced by Upcoming Coal based Khurja Super Thermal Power Project (2 x 660 MW) in Khurja, Dist. Bulandshahar, U. P.

Dear Sir,

We have been informed by M/S Mantec Consultants Pvt. Ltd., the agency engaged by you for Ash Utilization Study, that THDC India Ltd. is planning to set up 2 X 660 MW coal based super thermal power project, at Khurja, Distt. Buland shaher (U.P.).

During discussions, it was also informed that about 7400 tonnes of Fly Ash is expected to be produced daily, once the project is commissioned in the year 2017.

With regard to possibility of utilization of the produced ash, we would like to inform as follows:

- i.) We are in the business of fly ash utilization and marketing fly ash products from fly ash.
- ii.) We M/s Ficus E-logic Pvt. Ltd., Noida are intend to utilize 1100 tones per day of fly ash produced by Khurja STPP on mutually agreeable terms and condition.

'n

Thanking you,

Yours faithfully,

Ashab

Ashok Suyal Executive Director Ficus E-logic Pvt. Ltd.

Enclosure-1 (c)







THDC India Limited Design-Thermal Department Plot No. 20, Sector-14 Kaushambi, Ghaziabad-201 010, U. P. Oct. 5th, 2012

Sub. Regarding utilization of Fly Ash Produced by Upcoming Coal based Khurja Super Thermal Power Project (2 x 660 MW) in Khurja, Dist. Bulandshahar, U. P.

Dear Sir,

We have been informed by M/S Mantec Consultants Pvt. Ltd., the agency engaged by you for Ash Utilization Study, that THDC India Ltd. is planning to set up 2 X 660 MW coal based super thermal power project, at Khurja, Distt. Buland shaher (U.P.). During discussions, it was also informed that about 7400 tones of Fly Ash is expected to be produced daily, once the project is commissioned in the year 2017.

With regard to possibility of utilization of the produced ash, we would like to inform as follows:

- i.) We are in the business of Ash utilization through RMC Plant, Bricks etc.
- ii.) We M/s Mahesh Enterprises, Ghaziabad are intend to utilize 2250 tones per day of fly ash produced by Khurja STPP on mutually agreeable terms and condition.

With regards,

For MAHESH ENTERPRISES

Hayash Signator

39, Naya Ganj, Ghaziabad - 201001 Ph. : 95-120-2730042, 2834462
 III-B-3, Nehru Nagar, Ghaziabad Telefax : 95-120-4115562, 4115563

Enclosure-1 (d)



STAR CORPORATION

Deals In All Kind of Building Material OFFICE: 5/689, SECTOR-5, VAISHALI, GHAZIABAD (U.P.) TELEFAX: 0120-4136771 GODOWN: MANDOLA STOCK, LONI BAGHPAT ROAD, MANDOLA (U.P.)

Ref. No. SC/2012 / CM

Dated.....

Sept 29, 2012

THDC India Limited Design-Thermal Department Plot No. 20, Sector-14 Kaushambi, Ghaziabad-201 010, U. P.

Sub. Regarding utilization of Fly Ash Produced by Upcoming Coal based Khurja Super Thermal Power Project (2 x 660 MW) in Khurja, Dist. Bulandshahar, U. P.

Dear Sir,

We have been informed by M/S Mantec Consultants Pvt. Ltd., the agency engaged by you for Ash Utilization Study, that THDC India Ltd. is planning to set up 2 X 660 MW coal based super thermal power project, at Khurja, Distt. Buland shaher (U.P.).

During discussions, it was also informed that about 7400 tonnes of Fly Ash is expected to be produced daily, once the project is commissioned in the year 2017.

With regard to possibility of utilization of the produced ash, we would like to inform as follows:

- We are in the business of Ash utilization and the company profile is enclosed as Annexure A.
- ii.) We Adycon Infrastructures Pvt. Limites, Ghaziabad are intend to utilize 2000 tones per day of fly ash produced by Khurja STPP on mutually agreeable terms and condition.

We are now looking forward to associate with THDC,

Thanking you,

Vikas Gupta Partner Star Corporation

Enclosure-1 (e)





6th January 2017

JKLCL: PUR: 2016-17

THDC India Limited Plot No. 20, Sec-14, Kaushambi, Ghaziabad-201010, U.P.

Kind Attn : <u>Mr. Sanjay Kher, Addl GM (Th D)</u>

Sub. : Supply of Fly Ash for manufacturing of PPC Grade Cement

Dear Sir

With reference to your letter ref. no. 302/THDCIL/KAU/T-D/ dt. 03.01.2017 on the above subject, we, are presently manufacturing both OPC as well as PPC cement at our grinding units located at Jhajjar & Sikandrabad.

From the above letter we have been given to understand that you are proposing to set up coal based power plants at Khurja in District Bulandshahr and this unit would generate around 4000 Tonnes of fly ash per day. We are working on the logistics feasibility from this location to cater to our grinding units located at Jhajjar (Haryana) & Sikandrabad (U.P.) and we would be in a position to utilize the fly ash from your proposed power plant for producing PPC Cement at these units. This letter can be considered as EOI from our side and would like to convert the same into long term supply contract by way of MoU on mutually agreed terms.

Thanking you,





Admn. Office: Nehru House, 4, Bahadur Shah Zafar Marg, New Delhi 110 002; Phone: 33001142 / 33001112; Fax: 91-011-23722251/ 23722021; E-Mail: jklc.customercare@jkmail.com; Website: www.jklakshmi.com, CIN L74999RJ1938PLC019511 Regd. & Works Office: Jaykaypuram, Distt. Sirohi, Rajasthan; Phone: 02971-244409/ 244410; Fax: 02971-244417; E-Mail: lakshmi_cement@lc.jkmail.com

IK LAKSHMI





Ambuja Cement

Dated 10/01/2017

Ref. No; ACL /DADRI/COMM/01

Shri Sanjay Kher

Addl GM (Th D), THDCIL (A Joint Venture of Govt of India & Govt of U.P.) Plot-20, Sector -14, Kushambi, Gaziabad-10

Sub: Lifting Fly Ash

Dear Shri Kher,

Reference to the letter ; 302/THDCIL/KAU/T-D/ dated 04/01/2017 ;We would like to congratulate to THDC India Limited (THDCIL) a Central PSU under Ministry of Power, Govt of India for implementing the 2X660 MW Coal based Super Thermal Power Project at Khurja in district Bulandshahr UP which is expected to be commissioned in 2021-22.

Kindly be informed that we have cement grinding unit 1.5 MT at Dadri. Fly ash is core raw material for producing cement and we would require fly ash once you

start your production on mutual agreed terms & conditions.

Thanking you

Regards

For Ambuja Cement Ltd Unit : Dadri Sanjay Nigam (Commercial Head)

AMBUJA CEMENTS LTD.

Village : Dhoom Manik Pur & Badpura, NTPC Road, Dadri, Distt: Gautam Budh Nagar - 203207 (U.P.) Tel.: (0120) 2809941 - 44 Fax : (0120) 2809909 (Regd.Offi.: P.O. Ambuja Nagar, Taluka : Kodinar, Junagadh, Gujarat - 361 415)

Enclosure- 1(g)

CIN I L26543PJ1976PLC001705 Teletax 07459-232156 Website www.mangatamcement.com E-mail email@mangatamcement.co



MANGALAM CEMENT LTD.

MCL/2016-17/ 16.01.2017

Sh. Sanjay Kher Addl General Manager, THDC India Limited, Gangha Bhawan, By Pass Road, Pragatipuram, Rishikesh-249201

Sub:- Utilization of Fly Ash from your upcoming coal based Greenfield 2 x 660 MW Khurja STPP in District Bulandsahar (UP).

Dear Sir,

We would like to inform you that we are having Cement Grinding Unit of capacity 2200 TPD at UPSIDC industrial state, CDF Complex, Chherat Aligarh for which we are taking Dry Fly Ash from HTPS, Kasimpur.

We may utilize tentatively around 400-500 Tons per day Dry Fly Ash from your New Upcoming coal based Greenfield 2 x 660 MW Khurja STPP in District Bulandsahar (UP) for our proposed future expansion of Grinding Unit at Aligarh as per requirement.

Thanking You,

Yours faithfully For Mangalam Cement Limited,

S. S. Jain President

 Kota Office
 : "Mangalam" 93, Dashera Scheme, P.O. Dadabari, KOTA - 324 009 (Rajasthan) Tel. No. : 0744 - 2500266, 3098600, Fax : 0744 - 2500178, E-mail : mclkta@kappa.net.in

 Deihi Office
 : UCO Bank Building (4[®] Floor), 5, Parliament Street, New Deihi - 110 001 Tel. No. : 011- 23730854, 30680258, 30680259, Fax : 011- 23730856 E-mail : delhi.purchase@mangalamcement.com, delhi.marketing@mangalamcement.com

 Jaipur Office
 2^m Floor, Geelgarh Tower, Hawa-Sarak, Jaipur - 302 006 (Rajasthan)

Tel. : 0141 - 2218933, 2218931, E-mail : jaipur.marketing@mangalamcement.com

Enclosure- 1(h)



Phone +91-11-49220000 Fax +91-11-49220044 E-mail jkcement.delhi@jkcement.com Web www.jkcement.com

Padam Tower, 19, DDA Community Centre Phase -1, Okhla, New Delhi - 110020 INDIA

Ref. No. JK/DELHI/DFA/06

Dated 09th Jan 2017

General Manager Khurja Super Thermal Power Project (KSTPP)

Villagr-Dushahara Tehsil-Khurja Distt-Bulandshahar Uttar Pradesh

Sub: Expression of Interest for setting of grinding unit at your Khurja Super Thermal Power Project site for the manufacturing of Ash based Cement

Dear Shri S.P. Singh

At the outset, we are thankful for giving us the opportunity to have meeting with you to discuss our interest for setting of grinding unit at your Khurja Super Thermal Power Project site.

We understand that Khurja Super Thermal Power Project (KSTPP) is going to setup 3X660 MW of power from coal and commissioning is expected by year 2021. Fly Ash generation is an integral process of thermal plant operation and being hazardous category, its disposal is to be made with at most care normally in secured land unless it is used by the selected trades like cement manufacturing.

JK Cement Ltd is an affiliate of the multi-disciplinary industrial conglomerate of J.K. Organization & partnered India's multi-sectorial infrastructure needs on the strength of its product excellence, customer orientation and technology leadership. The Company has over four decades of experience in cement manufacturing and willing to extend its full support in environmental responsive utilization of Fly Ash by expending its business activity composed with Khurja Super Thermal Power Project (THDC India Limited).

We intent to collaborate with you and propose for setting of cement grinding unit of 1.0 Million Ton Per Annum at your premise and to move



Cere

Corporate & Registered Office : Kamla Tower, Kanpur-208001, (U. P.) INDIA Phone : +91-512-2371478 to 81 Fax : +91-512-2399854 E-mail: ho.grey@jkcement.com

> J.K. Cement Works, Nimbahera J.K. Cement Works, Mangrol J.K. Cement Works, Gotan J.K. Cement Works, Jharli

J.K. Power, Bamania J.K. Cement Works, Muddapur J.K. White Cement Works, Gotan J.K. White, Katni





(CIN: L17229UP1994PLC017199) ISO 9001 & ISO 14001 CERTIFIED COMPANY Phone : +91-11-49220000 Fax : +91-11-49220044 E-mail : jkcement.delhi@jkcement.com Web : www.jkcement.com

Padam Tower, 19, DDA Community Centre Phase -1, Okhla, New Delhi - 110020 INDIA

forward collectively for the development of Region in environment friendly manner. In order to set the grinding unit at "KSTPP" site we will appreciate your support for allocation of the following resources to us:

- Dry Fly Ash (DFA) approx. 4.0 Lacs MT Per Annum.
- Land approx. 20 Acres.
- Railway siding connectivity.
- Power approx. 8-10 MW
- Water for construction and operation on grinding unit.

Shall appreciate to enter into long term agreement on above with first right of refusal basis for fly ash.

Thanks in advance & with best regards,

Yagyesh Kumar Gupta Chief Procurement Officer, JMC Company, INP. Padam Tower

19 DDA Community Centre, Okhla Phase - 1, Delhi - 110020, INDIA



Corporate & Registered Office : Kamla Tower, Kanpur-208001, (U. P.) INDIA Phone : +91-512-2371478 to 81 Fax : +91-512-2399854 E-mail: ho.grey@jkcement.com

J.K. Cement Works, Nimbahera J.K. Cement Works, Mangrol J.K. Cement Works, Gotan J.K. Cement Works, Jharli J.K. Power, Bamania J.K. Cement Works, Muddapur J.K. White Cement Works, Gotan J.K. White, Katni





ASHTECH (INDIA) PRIVATE LIMITED





FLY ASH DISTRIBUTORS

"Ashtech House" 30, Popatwadi, Kalbadevi Road, Princess Street, Mumbai - 400 002. Tel.: 91-22-2219 0200 • Fax: 91-22-2206 2211 • E-mail: sales@ashtechindia.net • website: www.ashtechindia.net

Date:- January 5, 2017

To, M/S THDC INDIA LIMITED Plot No. 20, Sector 14, Kaushambi, Gaziabad - 201010

Kind Attention: Sanjay Kher, Additional GM, ThD

Subject: ASSOCIATION FOR FLY ASH COLLECTION AND DISTRIBUTION SYSTEM

Dear Sir,

ASHTECH (INDIA) P. LTD is a fast growing infrastructure company having its product line as "Materials for infrastructure"

ASHTECH (INDIA) P. LTD is in the business for last 21 years. The company started its main line of business as Fly ash collection, transportation and distribution. To increase the business volume of fly ash, company hired technical personnel to research, experiment, formulate and demonstrate the need, advantages and applications of fly ash.

Fly ash collection systems are owned & installed and/or operated by ASHTECH (INDIA) P. LTD at some power stations in India based on the long term agreements signed by power plants for making fly ash available to us as single party. These agreements are for a duration of 12 to 20 years. These power stations are:

- 1. Ennore Thermal Power Station of TNEB at Chennai
- 2. Badarpur thermal power station of NTPC at Delhi
- 3. Dahanu Thermal power station of Reliance energy Limited.
- 4. Vedanta Limited. Jharsuguda.
- 5. HPPCL, Vishakhapatinam.
- 6. Reliance Industries Limited, Dahej, Gujarat.
- 7. Reliance Industries Limited, Hazira, Gujarat.

In addition to the above power stations, ASHTECH (INDIA) P. LTD is operating at many other power stations for only collection and distribution of fly ash without investment in the collecting systems.

ASHTECH (INDIA) P. LTD has forward integration in RMC plants for creating its own utilization of fly ash by investing nearly 350 million INR and is owning and operating 7 RMC plants.

ASHTECH (INDIA) P. LTD is handling nearly 11000 MT of fly ash daily.

At present, ASHTECH (INDIA) P. LTD uses fly ash from Dadri TPS, Jajjar TPS, Rosa TPS and uses 2000 TPS in NCR region. This region has consistently increasing potential for utilization of fly ash in line with development of infrastructure.

ASHTECH (INDIA) P. LTD has now ventured into CEMENT business and is in franchisee production. It intends to start its own manufacture of PPC Cement shortly.

Page 1 of 2



ASHTECH (INDIA) PRIVATE LIMITED





CIN: U74999MH2002PTC135081

"Ashtech House" 30, Popatwadi, Kalbadevi Road, Princess Street, Mumbai - 400 002. Tel.: 91-22-2219 0200 • Fax: 91-22-2206 2211 • E-mail: sales@ashtechindia.net • website: www.ashtechindia.net

For all communication relating to the business with THDC INDIA LIMITED, following will be the address and the contact person: ASHTECH (INDIA) PVT. LTD. Ashford Centre" Lower Parel – West, MUMBAI 400013 Authorised Person: 1. Mr. Sanjay H Mandhania (Director) Telephone No.: 022 61490200 Ext. 208 / Cell Nos. 9223051303 Fax No.: 022 22062211 Email.: sanjay@ashtechindia.net

2. Mr. Vipin Dave Vice President Telephone No. 022 61490200 Ext. 227 / Cell No. 9223550931 Email.: <u>vipindav@ashtechindia.net</u>

Considering various aspects of availability of quantity of fly ash and quality of fly ash, potential of use need to be created by forming the team of persons with specific knowledge in the line to create usage and promote systematic market intervention. We are presently operating in this region, and hence can create utilization of 4000 MT of fly ash and 1500 MT of Bottom Ash easily.

ASHTECH (INDIA) P. LTD is interested to take away entire fly ash from THDC INDIA LIMITED at the commercial terms to be decided at the time of agreement and in line with the guidelines of MOEF.

ASHTECH (INDIA) P. LTD expresses its interest to associate with THDC INDIA LIMITED.

Thanking you, Yours sincerely,

Mr. Vipin Dave Vice President ASHTECH (INDIA) P. LTD

Page 2 of 2

ENCLOSURE-2 (a) to 2 (i)

Enclosure-1(a) Toposheet Map Showing the Site and Surroundings (10 km



radius)

Study Area



Project Site

Railway Line

National Highway

Water Bodies

Villages near to Project location

Dashahara Kherli

Jahanpur

Nagilia Udhaybhan

Naiphal Urf Uchangaon

Rukanpur

TOPOSHEET MAP WITH 10 KM RADIUS STUDY AREA

KHURJA SUPER THERMAL POWER PROJECT

Project Capacity -: 2 X 660 MW

Village - Dushhara - Kherli, Jahanpur, Naiphal(Unchagaon), Rukunpur

Project Proponent -: THDC INDIA LIMITED

5

10

Prepared by:- GIS DIVISION Mantec Consultants Pvt.Ltd Noida UP



77°51'30"E

77°57'0'E

Enclosure-1(b) Satellite Map Showing the Project Site (10 km radius)

Study Area

Project Site

SATELLITE IMAGE WITH 10 KM

KHURJA SUPER THERMAL POWER PROJECT

Project Capacity -: 2 X 660 MW

Village - Dushhara - Kherli, Jahanpur,

Project Proponent -: <u>THDC INDIA LIMITED</u>

Satllite Imagery :- Landsat 4.5 MSS

10









5 10
FHDC INDIA LIMITED
lhar h
- Kherli, Jahanpur,), Rukunpur
-: 2 X 660 MW
THERMAL POWER PROJECT
ORING LOCATION MAP RADIUS STUDY AREA
1
ION 📥
ject Site
dy Area







Study Area
Project Site
ATION 🔺
rauli Village al Village la Shakhu gpur RF
ORING LOCATION MAP I RADIUS STUDY AREA
THERMAL POWER PROJECT
ry -: 2 X 660 MW
a - Kherli, Jahanpur, on), Rukunpur
hahar esh
THDC INDIA LIMITED
5 10
kn



Enclosure-1(g) Noise Quality Monitoring Location Map (10 km radius)

dy Area			
ject Site			
	\triangle		
n a Kheri			
r RF i			
urd			
akhu			

FORING LOCATION	MAP
RADIUS STUDY AR	<u>EA</u>
THERMAL POWER PRO	JECT
y -: 2 X 660 MW	
- Kherli, Jahanpur, n), Rukunpur	
ahar	
sh	
THDC INDIA LIMITED	
5	10
	km





ENCLOSURE-3

Project Report on

Hydrographical Area Drainage Study for 2x660MW coal based Super Thermal Power Project Khurja

Sponsored by







NATIONAL INSTITUTE OF HYDROLOGY ROORKEE – 247 667 UTTARAKHAND September, 2013

Study Group

Director R. D. Singh

Study Group	Rakesh Kumar, Scientist F & Principal Investigator
	J. P. Patra, Scientist B
	Pankaj Mani, Scientist D
	R. D. Singh, Director
Technical Assistance	T. R. Sapra, RA
	N.K. Bhatnagar, PRA

Contents

1		ABOUT THE PROJECT	1
2		DESCRIPTION OF STUDY AREA	2
	2.1	General	2
	2.2	Topography and Drainage	2
	2.3	Climate	2
	2.4	Rainfall	3
3		DATA AVAILABILITY	5
	3.1	Data Availability for Unit Hydrograph Analysis	5
	3.2	Data Availability for Rainfall frequency Analysis	6
	3.3	Topographic and Drainage Network	7
4		METHODOLOGY	8
	4.1	Estimation of Rainfalls of Various Return Periods Using L-Moments Based Rainfall	
		Frequency Analysis	8
	4.1.	Probability weighted moments (PWMs) and L-moments	8
	4.1.	2 Data screening and missing value correction	11
	4.1.	3 Test of regional homogeneity	13
	4.1.4	4 Frequency distributions used	14
	4.1.	5 Goodness of fit measures	18
	4.2	Preparation of Digital Elevation Model	20
	4.3	Catchment Delineation and Estimation of Catchment Characteristics	21
	4.4	Derivation of Synthetic Unit Hydrograph	21
	4.5	Estimation of Flood Hydrographs	22
	4.5.	Design loss rate	22
	4.5.	2 Base flow for design flood	22
	4.5.	1 ime adjustment of design rainfall	22
	4.5.	Design storm duration	23
	4.0	Estimation of Design Flood Hydrographs	23
	4./	Flow Simulation and Flood Modelling	23
	4./.	Two Dimensional flow modelling by Mike 21 HD model	23 72
	4./	Elood inundation modelling by MIKE ELOOD	<i>21</i> 20
	4./	Safa Grade Elevation	20 20
	+.0		29
	4.9	Drainage Design	29
---	-------	--	----------------
5		ANALYSIS AND RESULTS	31
	5.1	Estimation of 1-day Annual Maximum Rainfall	31
	5.2	Estimation of 1-Day Rainfall of Various Return Periods using L-Moments Based Frequency Analysis	Rainfall 32
	5.2.	1 Identification of robust distribution for 1-day maximum rainfall	32
	5.3	Estimation of Synthetic Unit Hydrograph	
	5.3.	Base flow for design flood	42
	5.3.2	2 Temporal Distribution	42
	5.4	Estimation of Flood Hydrographs	42
	5.4.	1 Estimation of Flood hydrographs using 1-day annual maximum rainfall	42
	5.5	Flood simulation	45
	5.5.	1 Flow through Aligarh drain	45
	5.5.2	2 Modification of the Aligarh drain	46
	5.5.3	Combined flooding due to rainfall and flow through Aligarh drain	49
	5.6	Safe Grade Elevation	62
	5.7	Proposed Drainage Network	63
	5.7.	1 Drainage layout	63
	5.7.2	2 Design of drain section	66
	5.8	Limitation of the Study	68
6		CONCLUSIONS	69
R	EFERI	ENCES	71
A	NNEX	URE	73

List of Figures

Figure 2.1: Index map of the study Area	3
Figure 2.2: Drainage pattern around the Plant area	4
Figure 3.1: Layout of toposheets used in this study.	5
Figure 3.2: Rain-gauge stations with Thiessen Polygon	6
Figure 3.3 Topographical features of study area	7
Figure 4.1: Digital elevation model of proposed plant area.	20
Figure 4.2 : MIKE 11 computational grids	24
Figure 4.3 : Drainage network in MIKE-11	25
Figure 4.4: Typical Cross-section of the drain.	30
Figure 5.1 : Annual 1-day maximum rainfall	31
Figure 5.2: L-moments ratio diagram for Aligarh for 1-day annual maximum rainfall	34
Figure 5.3: L-moments ratio diagram for Bulandshar for 1-day annual maximum rainfal	1135
Figure 5.4: L-moments ratio diagram for Khurja for 1-day annual maximum rainfall	36
Figure 5.5: L-moments ratio diagram for Regional for 1-day annual maximum rainfall .	37
Figure 5.6: Delineated Catchment area	39
Figure 5.7: 1-h unit hydrograph	41
Figure 5.8: Time duration curve for the 24-h rainfall	43
Figure 5.9: Rainfall hyetograph for 1-day maximum rainfall	43
Figure 5.10: Design flood hydrographs for various return periods resulting from 1-day annual maximum rainfall.	44
Figure 5.11: Mike-11 setup of Aligarh drain	45
Figure 5.12: Existing and proposed re aligned Aligarh drain	47
Figure 5.13: Existing cross-section of Aligarh drain at inlet and outlet	48
Figure 5.14: Proposed modified drain sections	48
Figure 5.15: Elevation profile along the realigned section of Aligarh drain	49
Figure 5.16 Bathymetry of the plant area	50
Figure 5.17: Flood water depth due to 100 year return period rainfall.	51
Figure 5.18: Longitudinal profile of modified Aligarh drain	52

Figure 5.19: Water depths at selected grids for 100 year return period flood	53
Figure 5.20: Water levels at selected grids for 100 year return period flood	54
Figure 5.21: Flood water depth due to 50 year return period rainfall	.55
Figure 5.22: Flood water depth due to 25 year return period rainfall	56
Figure 5.23: Flood water depth due to 10 year return period rainfall	.57
Figure 5.24 : Water levels for various return period flood. (a) to (g) for grid point 1 to 7	.61
Figure 5.25: Percentage of area in existing levels.	63
Figure 5.26 : Proposed drainage layout	64
Figure 5.27: Proposed drainage network with contributing runoff area	65

List of Tables

Table 3.1 Details of rainfall data availability	6
Table 4.1 Critical values of discordancy statistic, D _i	12
Table 4.2 Relationships for estimating 2-h UH parameters for the study area	21
Table 5.1 Z_i^{dist} – Statistic of various distributions for 1-day annual maximum rainfall	32
Table 5.2 Parameters of various distributions for 1-day annual maximum rainfall	33
Table 5.3 Values of growth factors (R_T / \overline{R}) for 1-day annual maximum rainfall	38
Table 5.4 1-day annual maximum rainfall (mm) for various return periods	38
Table 5.5 Catchment characteristics	40
Table 5.6 Parameters of Synthetic Unit Hydrograph.	40
Table 5.7 Ordinates of 1-h unit hydrograph.	41
Table 5.8: Details of selected grids	53
Table 5.9 : Maximum water level at selected grids for various return periods	61
Table 5.10 Length, drainage area and peak flow of various sections	66
Table 5.11 Design details of drain section for 50 year and 25 year return period	67

List of Annexure

Annexure No	Particulars	Page No
Ι	Scope of Work of the study as per THDCIL work order.	73
II	Annual Maximum rainfall at various stations.	74
III	Effective rainfall and Runoff for various sub basins.	75

Preface

THDC India Limited (formerly known as Tehri Hydro Development Corporation Ltd.), a Joint Venture of Govt. of India and Govt. of Uttar Pradesh was incorporated in July 1988 to develop, operate and maintain the 2400 MW Tehri Hydro Power Complex and other hydro projects. The object clause of the Company has been amended to incorporate development of Conventional/ Non-conventional/ Renewable sources of Energy and River Valley Projects. Towards diversification of the company into other energy areas. THDCIL has been entrusted with a coal based super thermal power station at Khurja in the state of Uttar Pradesh. The THDCIL approached NIH, Roorkee for carrying out the hydrographical area drainage study for the above mentioned coal based STPP at Khurja in distt. Bulandshahar (U.P). The THDCIL has offered NIH, Roorkee this study titled **"Hydrographical Area Drainage Study for 2x660MW coal based Super Thermal Power Project Khurja"** vide letter No Ref:/ 904 /THDC/KAU/T-D/231 dated 17.02.2012.

The study envisages identification of various flooding sources, estimation of maximum floods and their routing to the proposed plant site for estimating the maximum flood level. Further, this study also includes study of local drainage pattern and modification of existing Aligarh drain. The digital elevation model (DEM) has been prepared from the levels and contours extracted from topographical maps and the contour map provided by THDCIL. The catchment area has been delineated from this DEM. The rainfall data have been obtained from IMD. The L-moments based rainfall frequency analysis has been performed to estimate 1 day maximum rainfall for various return periods. The synthetic unit hydrographs are derived from catchment characteristics of the study area and the flood hydrographs for 25, 50 and 100 year return periods have been computed. Maximum flood has been estimated by the L-moments based rainfall frequency analysis and unit hydrograph approach. The flood routing study has been carried out using MIKE FLOOD package (a coupled 1D and 2-D flow analysis). The bathymetry of the flood plain around the plant site at 5 m grid size has been created from DEM. The spills from Aligarh drain and local rainfall (100 year return period) have been simulated in coupled MILE-11 and MIKE-21. The flooding due to 50, 25 and 10 year return period rainfall has been also considered and inundation depths as well as flood levels have been computed. The

maximum flood inundation area due to passing of design discharge in Aligarh drain and 100 year return period local rainfall is analysed for safe grade level estimation. The local and peripheral drains for the plant site are designed for 25 and 50 year return period rainfall.

The study has been carried out by Dr. Rakesh Kumar, Scientist F; Shri Jagadish Prasad Patra, Scientist B; Shri Pankaj Mani, Scientist D; Shri R.D. Singh, Director NIH Roorkee. Technical assistance has been provided by Shri T.R. Sapra, RA and Shri N.K. Bhatnagar, PRA of National Institute of Hydrology, Roorkee. It is expected that the study would fulfil the desired requirements of the THDCIL.

Raj Deva Jinf (R. D. Singh) Director National Institute of Hydrology, Roorkee

Acknowledgement

The study group at National Institute of Hydrology, Roorkee have made their best efforts in carrying out the study entitled **"Hydrographical Area Drainage Study for 2x660MW coal based Super Thermal Power Project Khurja"** sponsored by the THDC India Ltd., Kaushambi, Ghaziabad. I acknowledge sincere thanks to U.P. Irrigation Department for providing design discharge of Aligarh drain. I am also grateful to IMD for providing historical rainfall data for this study. I express gratefulness towards the officials of THDC India Ltd. for providing encouragement, help and support throughout the study. Specially, I am thankful to Shri R.K. Bhat, Addl. G.M. (Design-Thermal); Shri Praveen Saxena, Dy. G.M. (Design- Thermal); Shri R.S.Tomar Sr. Manager (Design-Thermal); Shri A.K. Mittal Sr. Manager (Design-Thermal); and Shri Ravindra Singh Dy Manager (Design-Thermal); for their constant supervision, coordination and support during field visits and for providing necessary information regarding the project.

Rakeshler

(Dr. Rakesh Kumar) Principal Investigator Scientist F & Head, Surface Water Hydrology Division National Institute of Hydrology, Roorkee THDC India Limited, a Schedule 'A' Mini Ratna Company has signed a memorandum of understanding with Govt. of U.P to set up a 1320 MW super thermal power plant at Khurja, Distt. Bulandshahar (U.P). For the preparation of Detailed Feasibility Report, apart from various other studies a study on Hydrographical Area Drainage system of the proposed area is essential. THDC India Limited, Ghaziabad requested National Institute of Hydrology, Roorkee to undertake the study to access natural drainage pattern and to decide upon the drainage system in and around the plant area and to access the measures to be adopted to address modification of existing natural drainage pattern. The original scopes of work are:

- 1. Study of existing natural drainage pattern/system with available information in the form of reports, literature, satellite imageries, etc. for proposed project and its adjoining areas. The study shall include review of topographical features of the proposed site for the Power Project and its surrounding area.
- 2. Review and analysis of rainfall information to arrive at design storm scenarios.
- 3. Review and analysis of relevant Survey of India Topographical Sheets, topographical survey and satellite imageries.
- 4. Estimation of flood hydrographs considering historical as well as design rainfall to suggest complete scheme for storm water drainage of project and its adjoining areas including diversion of existing nalas/streams, if any. In case short interval observed rainfall runoff data would be not available then the standard regional approaches will be used for design flood estimation.
- 5. Estimation and routing of design flood hydrograph through the drainage system of concerned catchments considering appropriate boundary conditions including pre-project scenario as well as post-project scenario for suggesting Safe Grade Elevation for the plant.
- 6. Suggesting final disposal point for the storm water & plant drainage.
- 7. Site visit for acquaintance of prevailing conditions and collection of available data at site.
- 8. Visit to THDC Office for discussions regarding the studies.

The scope of work as per the project proposal is given in Annexure-I.

2.1 General

The Plant site is located near village Dasehri, Dasehri Khrli, along NH 91 in Bulandshahr district of the state of Uttar Pradesh. The geographical extent of the proposed plant site is from 77°53.783'E to 77°55.373'E longitude and from 28°08.586'N to 28°10.417'N latitude approximately and covered in Survey of India toposheet no. 53H16 of 1:50000 scale. The project site is surrounded by villages namely: Dashara Khrli & Dashara in north; Rukanpur in south; Naiphal in east and Jawal in west. The majority area is uncultivated land and brick klin area. The geographical area of the plant site is about 5.3 km². The location of the site is given in Figure 2.1.

2.2 Topography and Drainage

The plant site is located in upper Indo- Ganga plains. The Aligarh drain and NH-91 passes through the proposed plant area. The general topography of the area is and elevation in the proposed plant area varies from 189.5 m to 196 m. The general land slope is towards South. The existing drainage in and around the site is given in Figure 2.2. The Aligarh drain is the main drain passing through the site. As per the information available the Aligarh drain starts from Agaura branch cut. Total length of the Aligarh drain is 121.204 km and the length of the drain up to entry to plant boundary is about 6.5 m. The Malgosa branch cut and Nagla shaikhu drain joins Aligarh drain in its upstream of plant boundary. The Ghatal branch cut joins to Aligarh drain from other side of Aligarh drain joins to Aligarh drain inside plant boundary. Further one small drain after crossing the highway and another drain from other side of Aligarh drain joins to Aligarh drain inside plant boundary area. Apart from these there are two culverts in highway, to drain the runoff generated from the west side of highway area and join to Aligarh drain.

2.3 Climate

Bulandhshahr is located in the Meerut division of Uttar Pradesh, between the Ganga and Yamuna rivers. The climate of Bulandshahr is extreme and tropical. The district average temperature in summer and winter season is 33.52°C and 14.33°C respectively. The summers are extremely hot and the maximum temperature goes as high as 45° C, while the winters remain cold, with temperature dipping to 2° C.

2.4 Rainfall

The normal annual rainfall of the district is about 673.5 mm (Department of Agriculture & Cooperation, 2012). However in last five year during monsoon season deficit from normal has been observed (IMD, 2012).



Figure 2.1: Index map of the study Area



Figure 2.2: Drainage pattern around the Plant area

This chapter describes data availability for design flood estimation using the deterministic approach based on unit hydrograph method and L-moments based rainfall and flood frequency analysis.

3.1 Data Availability for Unit Hydrograph Analysis

The observed data for application of the unit hydrograph approach were not available. Hence, in this study the synthetic unit hydrograph was derived using the Flood Estimation Report for the Upper Indo-Ganga plains Subzone-1(e) (CWC, 1984). The CWC report is based on the detailed synthetic unit hydrograph studies carried out by utilizing the data of 23 representative catchments. Total two available Survey of India toposheets of 1:50,000 scales (Figure 3.1) were used with surveyed contour map and SRTM DEM for deriving catchment characteristics.



Figure 3.1: Layout of toposheets used in this study.

The design storm depth and its time distribution has been adopted from flood estimation report of the CWC (1984) Upper Indo-Ganga plains Subzone-1(e).

3.2 Data Availability for Rainfall frequency Analysis

Daily rainfalls for three rain gauge stations namely: Aligarh, Bulandshahr and Khurja (Figure 3.2) were obtained from IMD. The Thiessen Polygon (Figure 3.2) were created using "Create Thiessen Polygons" tool in ArcToolbox of ArcGIS 10. The details of rainfall data available with missing value are given in Table 3.1.



Figure 3.2: Rain-gauge stations with Thiessen Polygon

Rainfall Station	Type of data	Period of availability	Missing value in year	Length of data available
Aligarh	Daily	1951 to 2006	1993,1998	54
Bulandshahr	Daily	1970 to 1982	Nil	13
Khurja	Daily	1951 to 2009	1973,1974,1977,1978,1983,	53
			1984	

Table 3.1 Details of rainfall data availability

3.3 Topographic and Drainage Network

The topographic survey in the proposed plant area was carried out by THDC and the contours were provided for this study (Figure 3.3). Further, cross-section of Aligarh drain and other drains were also measured during survey. The bathymetry is prepared from SRTM DEM, contour and spot height of SOI toposheet and surveyed contour elevation.



The methodology used for estimation of design flood using the synthetic unit hydrograph approach and methodologies for analyzing flood inundation this flood described as follows.

4.1 Estimation of Rainfalls of Various Return Periods Using L-Moments Based Rainfall Frequency Analysis

The following aspects of methodology of L-moments based regional frequency relationship for gauged catchments as well as ungauged catchments are discussed as follows.

- (i) Probability weighted moments (PWMs) and L-moments,
- (ii) Data screening and missing value correction,
- (iii) Test of regional homogeneity,
- (iv) Frequency distributions used,
- (v) Goodness of fit measures, and
- (vi) Development of relationship between mean annual peak flood and catchment area.

In this study at-site rainfall frequency analysis and regional frequency analysis (Kumar and Chatterjee, 2005; Kumar et al., 2011) has been applied as discussed in Chapter 5.1.

4.1.1 Probability weighted moments (PWMs) and L-moments

L-moments of a random variable were first introduced by Hosking (1990). Hosking and Wallis (1997) state that L-moments are an alternative system of describing the shapes of probability distributions. Historically they arose as modifications of the probability weighted moments' (PWMs) of Greenwood et al. (1979).

4.1.1.1 Probability weighted moments (PWMs)

Probability weighted moments are defined by Greenwood et al. (1979) as:

$$M_{i,j,k} = \int_{0}^{1} x(F)^{i} (F)^{j} (1-F)^{k} dF$$
(1)

where, $F = F(x) = \int_{-x}^{x} f(x) dx$ is the cumulative density function and x (F) is the inverse of it; i, j, k are the real numbers. The particularly useful special cases of the PWMs α_k and β_j . are:

$$\alpha_{k} = M_{1,0,k} = \int_{0}^{1} x(F) (1-F)^{k} dF$$
(2)

$$\beta_{j} = M_{1,j,0} = \int_{0}^{1} x(F) (F)^{j} dF$$
(3)

These equations are in contrast with the definition of the ordinary conventional moments, which may be written as:

$$E(X^{r}) = \int \{x(F)\}^{r} dF$$
(4)

The conventional moments or "*product moments*" involve higher powers of the quantile function x(F); whereas, PWMs involve successively higher powers of non-exceedance probability (F) or exceedance probability (1-F) and may be regarded as integrals of x(F) weighted by the polynomials F^r or $(1-F)^r$. As the quantile function x(F) is weighted by the probability F or (1-F), hence these are named as probability weighted moments.

However, PWMs are difficult to interpret as measures of scale and shape of a probability distribution. This information is carried in certain linear combinations of the PWMs. These linear combinations arise naturally from integrals of x(F) weighted not by polynomials F^{r} or $(1-f)^{r}$ but by a set of orthogonal polynomials (Hosking and Wallis, 1997).

4.1.1.2 L-moments

Hosking (1990) defined L-moments as linear combination of probability weighted moments. In general, in terms of α_k and β_i , L-moments are defined as:

$$\lambda_{r+1} = (-1)^r \sum_{k=0}^r p_{r,k}^* \alpha_k = \sum_{k=0}^r p_{r,k}^* \beta_k$$
(5)

where, $p_{r,k}^{r}$ is an orthogonal polynomial (shifted Legender polynomial) expressed as:

$$p_{r,k}^{*} = (-1)^{r-k} C_{k}^{r+k} C_{k} = \frac{(-1)^{r-k} (r+k)!}{(k!)^{2} (r-k)!}$$
(6)

L-moments are easily computed in terms of probability weighted moments (PWMs) as given below.

$$\lambda_1 = \alpha_0 \qquad \qquad = \beta_0 \tag{7}$$

$$\lambda_2 = \alpha_0 - 2\alpha_1 \qquad \qquad = 2\beta_1 - \beta_0 \tag{8}$$

$$\lambda_3 = \alpha_0 - 6\alpha_1 + 6\alpha_2 \qquad \qquad = 6\beta_2 - 6\beta_1 + \beta_0 \tag{9}$$

$$\lambda_4 = \alpha_0 - 12\alpha_1 + 30\alpha_2 - 20\alpha_3 = 20\beta_3 - 30\beta_2 + 12\beta_1 + \beta_0$$
(10)

The procedure based on PWMs and L-moments are equivalent. However, L-moments are more convenient, as these are directly interpretable as measures of the scale and shape of probability distributions. Clearly λ_1 , the mean, is a measure of location, λ_2 is a measure of scale or dispersion of random variable. It is often convenient to standardise the higher moments so that they are independent of units of measurement.

$$\tau_r = \frac{\lambda_r}{\lambda_2} \quad \text{for} \quad r = 3, 4 \tag{11}$$

Analogous to conventional moment ratios, such as coefficient of skewness τ_3 is the L-skewness and reflects the degree of symmetry of a sample. Similarly τ_4 is a measure of peakedness and is referred to as L-kurtosis. These are defined as:

L-coefficient of variation (L-CV),
$$(\tau) = \lambda_2 / \lambda_1$$

L-coefficient of skewness, L-skewness $(\tau_3) = \lambda_3 / \lambda_2$
L-coefficient of kurtosis, L-kurtosis $(\tau_4) = \lambda_4 / \lambda_2$

Symmetric distributions have $\tau_3 = 0$ and its values lie between -1 and +1. Although the theory and application of L-moments is parallel to that of conventional moments, L-moments have several important advantages. Since sample estimators of L-moments are always linear combination of ranked observations, they are subject to less bias than ordinary product moments. This is because ordinary product moments require squaring, cubing and so on of observations. This causes them to give greater weight to the observations far from the mean, resulting in substantial bias and variance.

Zafirakou-Koulouris et al. (1998) mention that like ordinary product moments, Lmoments summarise the characteristics or shapes of theoretical probability distributions and observed samples. Both moment types offer measures of distributional location (mean), scale (variance), skewness (shape), and kurtosis (peakedness). The authors further mention that L-moments offer significant advantages over ordinary product moments, especially for environmental data sets, because of the following:

i. L-moment ratio estimators of location, scale and shape are nearly unbiased, regardless of the probability distribution from which the observations arise (Hosking, 1990).

- ii. L-moment ratio estimators such as L-C_v, L-skewness, and L-kurtosis can exhibit lower bias than conventional product moment ratios, especially for highly skewed samples.
- iii. The L-moment ratio estimators of L- C_v and L-skewness do not have bounds which depend on sample size as do the ordinary product moment ratio estimators of C_v and skewness.
- iv. L-moment estimators are linear combinations of the observations and thus are less sensitive to the largest observations in a sample than product moment estimators, which square or cube the observations.
- v. L-moment ratio diagrams are particularly good at identifying the distributional properties of highly skewed data, whereas ordinary product moment diagrams are almost useless for this task (Vogel and Fennessey, 1993).

4.1.2 Data screening and missing value correction

In flood frequency analysis, the data collected at various sites should be true representative of the annual maximum peak flood measured and must be drawn from the same frequency distribution. The first step in flood frequency analysis is to verify that the data are appropriate for the analysis. The preliminary screening of the data must be carried out to ensure that the above requirements are satisfied. Errors in data may occur due to incorrect recording or transcription of the data values or due to shifting of the gauging site to a different location as well as due to changes in the measuring practices or as a result of water resources development activities. Tests for outliers and trends are well established in the statistical literature (e.g., Barnett and Lewis, 1994; W.R.C., 1981; Kendall, 1975). For comparison of data observed from different sites, some techniques such as double mass plots or quantile-quantile plots are commonly used.

Hosking and Wallis (1997) mention that in the context of regional frequency analysis using L-moments, useful information can be obtained by comparing the sample L-moment ratios for different sites, incorrect data values, outliers, trends and shifts in the mean of a sample can all be related to L-moments of the sample. A convenient amalgamation of the L-moment ratios into a single statistic, a measure of discordancy between L-moment ratios of a site and the average L-moment ratios of a group of similar sites, has been termed as "discordancy measure", D_i .

4.1.2.1 Discordancy measure

The aim of the discordancy measure is to identify those sites from a group of given sites that are grossly discordant with the group as a whole. Discordancy is measured in terms of

the L-moments of the data of the various sites as defined below (Hosking and Wallis, 1997). Suppose that there are N sites in the group. Let $u_i = [t^{(i)} t_3^{(i)} t_4^{(i)}]^T$ be a vector containing the t, t₃ and t₄ values for site i: T denotes transposition of a vector or matrix. Let

$$\bar{u} = N^{-1} \sum_{i=1}^{N} u_i$$
(12)

be (unweighted) group average. The matrix of sums of squares and cross products is defined as:

$$A = \sum_{i=1}^{N} (u_i - \bar{u})(u_i - \bar{u})^T$$
(13)

The discordancy measure for site i is defined as:

$$D_{i} = \frac{1}{3} N(u_{i} - \overline{u})^{T} A^{-1}(u_{i} - \overline{u})$$
(14)

The site i is declared to be discordant if D_i is larger than the critical value of the discordancy statistic D_i given in Table 4.1.

No. of sites in region	Critical value	No. of sites in region	Critical value
5	1.333	10	2.491
6	1.648	11	2.632
7	1.917	12	2.757
8	2.140	13	2.869
9	2.329	14	2.971
		≥15	3

Table 4.1 Critical values of discordancy statistic, D_i (Adapted from Hosking and Wallis, 1997)

For a discordancy test with significance level α an approximate critical value of max_i D_i is (N-1)Z/(N-4+3Z), where Z is the upper 100 α /N percentage point of an F distribution with 3 and N-4 degrees of freedom. This critical value is a function of α and N, where $\alpha = 0.10$. D_i is likely to be useful only for regions with N \geq 7.

4.1.3 Test of regional homogeneity

A test statistic H, termed as heterogeneity measure has been proposed by Hosking and Wallis (1993). It compares the inter-site variations in sample L-moments for the group of sites with what would be expected of a homogeneous region. The inter-site variation of L-moment ratio is measured as the standard deviation (V) of the at-site LCV's weighted proportionally to the record length at each site. To establish what would be expected of a homogeneous region, simulations are used. A number of, say 500 data regions are generated based on the regional weighted average statistics using a four parameter distribution e.g. Kappa or Wakeby distribution. The inter-site variation of each generated region is obtained and the mean (μ_v) and standard deviation (σ_v) of the computed inter-site variation is obtained.

Let the proposed region has N sites with site i having record length n_i and sample L-moment ratios $t^{(i)}$, $t_3^{(i)}$, and $t_4^{(i)}$. The regional average L-CV, L-Skewness and L-Kurtosis weighted proportionally to the sites' record length for example, t^R mentioned below. The various steps involved in computation of heterogeneity measure (H) are mentioned below.

(i) Compute the weighted regional average L moment ratios

$$t^{R} = \sum_{i=1}^{N_{s}} n_{i} t^{(i)} / \sum_{i=1}^{N_{s}} n_{i}$$
(15)

The value of t_3^R and t_4^R can also be computed similarly by replacing $t^{(i)}$ by $t_3^{(i)}$, and $t_4^{(i)}$.

(ii) Compute the weighted standard deviation of at site LCV's (t⁽ⁱ⁾)

$$\mathbf{V} = \left[\sum_{i=1}^{N} n_{i} \left(t^{(i)} - t^{R}\right)^{2} / \sum_{i=1}^{N} n_{i}\right]^{\frac{1}{2}}$$
(16)

- (iii) Fit a general 4-parameter distribution (Kappa or 4 parameter Wakeby etc.) to the regional average L-moment ratios, t^R , t^R_3 and t^R_4 .
- (iv) Simulate a large number of regions say 500 having same record lengths as the observed data of the proposed region.

- (v) Repeat steps 1 and 2 for each of the 500 simulated regions and calculate the weighted standard deviations for each simulated region and take it as v_1 , v_2 , v_3 ,...., v_{500} .
- (vi) Compute the mean (μ_v) and standard deviation (σ_v) of the values obtained in step (v).
- (vii) Compute the Heterogeneity measure H as given below.

$$H = \frac{V - \mu_v}{\sigma v}$$
(17)

The criteria established by Hosking and Wallis (1993) for assessing heterogeneity of a region is as follows.

If $H < 1$	Region is acceptably homogeneous.
If $1 \le H \le 2$	Region is possibly heterogeneous.
If $H \ge 2$	Region is definitely heterogeneous.

4.1.4 Frequency distributions used

The following twelve frequency distributions have been used in this study.

- i. Extreme value (EV1)/ Gumbel distribution
- ii. General extreme value (GEV)
- iii. Logistic (LOS)
- iv. Generalized logistic (GLO)
- v. Normal (NOR)
- vi. Generalized Pareto (GPA)
- vii. Generalized normal (GNO)
- viii. Uniform (UNF)
- ix. Pearson Type-III (PT3)
- x. Kappa (KAP) and
- xi. Wakeby (WAK)
- xii. Exponential (EXP)

The details about these distributions and relationships among parameters of these distributions and L-moments are available in literature (e.g. Hosking and Wallis, 1997) and the same are summarized below.

4.1.4.1 Extreme value type-I distribution (EV1)

Extreme Value Type-I distribution (EV1) is a two parameter distribution and it is popularly known as Gumbel distribution. The quantile function or the inverse form of the distribution is expressed as:

$$x(F) = u - \alpha \ln(-\ln F)$$
(18)

Where, u and α are the location and scale parameters respectively, F is the non-exceedence probability viz. (1-1/T) and T is return period in years.

4.1.4.2 General extreme value distribution (GEV)

General Extreme Value distribution (GEV) is a generalized three parameter extreme value distribution. Its theory and practical applications are reviewed in the Flood Studies Report (NERC,1975). The quantile function or the inverse form of the distribution is expressed as:

$$x(F) = u + \alpha \{1 - (-\ln F)^k\} / k; \qquad k \neq 0$$
(19)

$$x(F) = u - \alpha \ln(-\ln F)$$
 $k = 0$ (20)

Where, u, α and k are location, scale and shape parameters of GEV distribution respectively. EV1 distribution is the special case of the GEV distribution, when k = 0.

4.1.4.3 Logistic distribution (LOS)

Inverse form of the Logistic distribution (LOS) is expressed as:

$$x(F) = u - \alpha \ln \{(1-F)/F\}$$
(21)

Where, u and α are location and scale parameters respectively.

4.1.4.4 Generalized logistic distribution (GLO)

Inverse form of the Generalized Logistic distribution (GLO) is expressed as:

$$x(F) = u + \alpha [1 - {(1-F)/F}^{k}]/k; \qquad k \neq 0$$
(22)

$$x(F) = u - \alpha \ln \{(1-F)/F\};$$
 $k = 0$ (23)

Where, u, α and k are location, scale and shape parameters respectively. Logistic distribution is the special case of the Generalized Logistic distribution, when k = 0.

4.1.4.5 Generalized Pareto distribution (GPA)

Inverse form of the Generalized Pareto distribution (GPA) is expressed as:

$$x(F) = u + \alpha \{ 1 - (1 - F)^k \} / k; \qquad k \neq 0$$
(24)

$$x(F) = u - \alpha \ln (1-F)$$
 $k = 0$ (25)

where, u, α and k are location, scale and shape parameters respectively. Exponential distribution is special case of Generalized Pareto distribution, when k = 0.

4.1.4.6 Generalized normal distribution (GNO)

The cumulative density function of the three parameter Generalized normal distribution (GNO) is given below.

$$F(x) = \phi \left[-k^{-1} \log \{ 1 - k(x - \xi) / \alpha \} \right]$$
(26)

where, ξ , α and k are its location, scale and shape parameters respectively. When k = 0, it becomes normal distribution with parameters ξ and α . This distribution has no explicit analytical inverse form.

4.1.4.7 Pearson Type-III distribution (PT-III)

The inverse form of the Pearson type-III distribution is not explicitly defined. Hosking and Wallis (1997) mention that the Pearson type-III distribution combines Gamma distributions (which have positive skewness), reflected Gamma distributions (which have negative skewness) and the normal distribution (which has zero skewness). The authors parameterize the Pearson type-III distribution by its first three conventional moments viz. mean μ , the standard deviation σ , and the skewness γ . The relationship between these parameters and those of the Gamma distribution is as follows. Let X be a random variable with a Pearson type-III distribution with parameters μ , σ and γ . If $\gamma > 0$, then X - $\mu + 2 \sigma/\gamma$ has a Gamma distribution with parameters $\alpha = 4/\gamma^2$, $\beta = \sigma \gamma/2$. If $\gamma = 0$, then X has normal distribution with mean μ and standard deviation σ . If $\gamma < 0$, then -X + μ - 2 σ/γ has a Gamma distribution with parameters $\alpha = 4/\gamma^2$, $\beta = |\sigma \gamma/2|$.

If $\gamma \neq 0$, let $\alpha = 4/\gamma^2$, $\beta = |\sigma \gamma/2|$, and $\xi = \mu - 2\sigma/\gamma$ and Γ (.) is Gamma function. If $\gamma > 0$, then the range of x is $\xi \le x < \infty$ and the cumulative distribution function is:

$$F(x) = G\left(\alpha, \frac{x-\xi}{\beta}\right) / \Gamma(\alpha)$$
(27)

If $\gamma < 0$, then the range of x is $-\infty < x \le \xi$ and the cumulative distribution function is:

$$F(x) = 1 - G\left(\alpha, \frac{\xi - x}{\beta}\right) / \Gamma(\alpha)$$
(28)

4.1.4.8 Kappa distribution (KAP)

The kappa distribution is a four parameter distribution that includes as special cases the Generalized logistic (GLO), Generalized extreme value (GEV) and Generalized Pareto distribution (GPA).

$$x(F) = \xi + \alpha \left[1 - \left\{ (1 - F)^{h} / h \right\}^{k} \right] / k$$
(29)

where, ξ is the location parameter, α is the scale parameter.

When h = -1, it becomes Generalized logistic (GLO) distribution; h = 0 is the Generalized extreme value (GEV) distribution; and h = 0 is the Generalized Pareto (GPA) distribution. It is useful as a general distribution with which to compare the fit of two and three parameter distributions and for use in simulating artificial data in order to assess the accuracy of statistical methods (Hosking and Wallis, 1997).

4.1.4.9 Wakeby distribution (WAK)

Inverse form of the five parameter Wakeby (WAK) distribution is expressed as:

$$x(F) = \xi + \frac{\alpha}{\beta} \left\{ 1 - (1 - F)^{\beta} \right\} - \frac{\gamma}{\delta} \left\{ 1 - (1 - F) - \delta \right\}$$

$$(30)$$

where, ξ , α , β , γ , and δ are the parameters of the Wakeby distribution.

4.1.5 Goodness of fit measures

In a realistically homogeneous region, all the sites follow the same frequency distribution. But as some heterogeneity is usually present in a region so no single distribution is expected to provide a true fit for all the sites of the region. In regional flood frequency analysis the aim is to identify a distribution which will yield reasonably accurate quantile estimates for each site of the homogeneous region. Assessment of validity of the candidate distribution may be made on the basis of how well the distribution fits the observed data. The goodness of fit measure assesses the relative performance of various fitted distributions and help in identifying the robust viz. most appropriate distribution for the region. A number of methods are available for testing goodness of fit of the proposed flood frequency analysis models. These include Chi-square test, Kolmogorov-Smirnov test, descriptive ability tests and the predictive ability tests. Cunnane (1989) has brought out a comprehensive description of the descriptive ability tests and the predictive ability tests. Apart from the aforementioned tests the recently introduced L-moment ratio diagram based on the approximations given by Hosking (1991) and the goodness of fit or behaviour analysis measure for a frequency distribution given by statistic Z_i^{dist} described below, are also used to identify the suitable frequency distribution.

4.1.5.1 L-moment ratio diagram

The L-moment statistics of a sample reflect every information about the data and provide a satisfactory approximation to the distribution of sample values. The L-moment ratio diagram can therefore be used to identify the underlying frequency distribution. The average L-moment statistics of the region is plotted on the L-moment ratio diagram and the distribution nearest to the plotted point is identified as the underlying frequency distribution. One big advantage of L-moment ratio diagram is that one can compare fit of several distributions using a single graphical instrument (Vogel and Fennessey, 1993).

4.1.5.2 Z_i^{dist} Statistic as a goodness-of-fit measure

In this method also the objective is to identify a distribution which fits the observed data acceptably closely. The goodness of fit is judged by how well the L-Skewness and L-Kurtosis of the fitted distribution match the regional average L-Skewness and L-Kurtosis of the observed data. The goodness-of-fit measure for a distribution is given by statistic Z_i^{dist} .

$$Z_{i}^{\text{dist}} = \frac{\left(\overline{\tau}_{i}^{\text{R}} - \tau_{i}^{\text{dist}}\right)}{\sigma_{i}^{\text{dist}}}$$
(31)

where $\overline{\tau}_i^R$ - weighted regional average of L-moment statistic i, τ_i^{dist} and σ_i^{dist} are the simulated regional average and standard deviation of L-moment statistics i for a given distribution.

The distribution giving the minimum $|Z^{dist}|$ value is considered as the best fit distribution. When all the three L-moment ratios are considered in the goodness-of-fit test, the distribution that gives the best overall fit when all the three statistics are consider together is selected as the underlying regional frequency distribution. According to Hosking (1993), distribution is considered to give good fit if $|Z^{dist}|$ is sufficiently close to zero, a reasonable criteria being $|Z^{dist}| \leq 1.64$.

Let the homogeneous region has N_s sites with site i having record length n_i and sample L-moment ratios t_i , t_{3i} & t_{4i} . Steps involved in computation of statistic Z_i^{dist} are:

i. Compute the weighted regional average L-moment ratios.

$$t^{R} = \frac{\sum_{i=1}^{N_{S}} n_{i} t_{i}}{\sum_{i=1}^{N_{S}} n_{i}}$$
(32)

The values of t_3^R and t_4^R are computed similarly by replacing t_i by t_{3i} and t_{4i} respectively.

- ii. Fit the candidate distribution to the regional average L-moment ratios t^R , t^R_3 and t^R_4 and mean = 1.
- iii. Use the fitted distribution to simulate a number of regions, say 500, having same record length as the observed data.
- iv. Repeat step 1 for each simulated region and the weighted regional average for the simulations are taken as t_1^R , t_2^R ... t_{500}^R and similarly for $t_3^R \& t_4^R$.
- v. Compute the mean (τ_i^{dist}) and standard deviation (σ_i^{dist}) for the values computed in step 4 above for each L-moment statistic i.

vi. Goodness-of-fit measure
$$Z_i^{\text{dist}}$$
 is computed as $Z_i^{\text{dist}} = \frac{\overline{\tau}_i^R - \tau_i^{\text{dist}}}{\sigma_i^{\text{dist}}}$ (33)

vii. Repeat the steps 2 to 6 for each of the distributions. Distribution giving the minimum $|Z_i^{dist}|$ value for the L-moment statistics is identified as the best fit distribution.

4.2 Preparation of Digital Elevation Model

The two toposheets of 1:50,000 scales obtained from Survey of India were scanned, georeferenced and projected to 43 North zone of WGS1984 UTM projected coordinate system. Then all the contour lines, spot heights and bench marks from the toposheets are digitised to polyline and point shape files with help of ArcMap. Further, the surveyed contours lines provided by THDC are imported to ArcGIS from Auto Cad file. The DEM is prepared with help of Topo to Raster tool of spatial analyst in ArcMap, which interpolates a hydrologically correct raster surface from point, line, and polygon data. The SRTM DEM is used in for remaining upper portion of the catchment. The prepared DEM of the plant area (prepared from surveyed contour) is Figure 4.1.



Figure 4.1: Digital elevation model of proposed plant area.

4.3 Catchment Delineation and Estimation of Catchment Characteristics

Initially a wide extent of generated DEM has been used to delineate the drainage network in and around the proposed plant area. The HEC-GeoHMS 5.0 package in ArcGIS 9.3 is tried for automatic delineation of catchments from DEM. The Aligarh drain is a natural drain and maintained by U.P. Irrigation Department and there are number of irrigation canals and road with culverts in the catchment area of drain. Moreover, the catchment area is comparatively small with very flat topography. Hence, automatic delineation of catchments from DEM was not very accurate. In such case the catchment area is delineated manually from the SOI topsheets considering the topographic features.

4.4 Derivation of Synthetic Unit Hydrograph

The various parameters of the synthetic unit hydrograph are derived from the Flood Estimation Report (CWC, 1984). Detail description of parameter and their relationships are given in Table 4.2. As mentioned in the CWC (1984) report the relationships are for 2-hour unit hydrograph (2-h UH). Hence, after deriving 2-h UH, the S-curve approach was used to develop 1-h UH.

Sl. No.	Parameters	Relationship
1	Peak discharge of unit hydrograph per unit area of catchment (m ³ /s/ km ²)	$q_p = \frac{2.030}{\left(L/\sqrt{S}\right)^{0.649}}$
2	Time in hours from the centre of unit rain fall duration to the peak of unit hydrograph.	$t_p = \frac{1.858}{q_p^{1.038}}$
3	Width of UH in hours at 50 percent of peak discharge	$W_{50} = \frac{2.217}{q_p^{0.990}}$
4	Width of UH in hours at 75 percent of peak discharge	$W_{75} = \frac{1.477}{q_p^{0.876}}$
5	Width of the rising limb of UH in hours at 50 percent peak discharge	$WR_{50} = \frac{0.812}{q_p^{0.907}}$
6	Width of the rising limb of UH in hours at 75 percent peak discharge	$WR_{75} = \frac{0.606}{q_p^{0.791}}$

Table 4.2 Relationships for estimating 2-h UH parameters for the study area

7	Base width of unit hydrograph in hours	$T_B = 7.744 \left(t_p \right)^{0.779}$
8	Peak discharge of unit hydrograph in m ³ /s	$Q_p = q_p \times A$

Where, L = Length of the main stream (km), S = Equivalent stream slope (m/km), A = Area of the catchment (km²).

4.5 Estimation of Flood Hydrographs

Flood hydrographs for various return periods were estimated for 1-day maximum rainfall. The steps for estimating flood hydrographs are discussed in following sections.

4.5.1 Design loss rate

Generally infiltration index and the initial losses values are derived from the available rainfall-runoff records for the severe storms in the basin. Assuming the basin would be saturated at the time of design storm the minimum infiltration rate and initial losses values would be considered. The minimum infiltration rate and minimum initial loss, thus obtained, are used to compute the effective rainfall of design storm. For this the initial losses must be subtracted first from the rainfall increments and thereafter a uniform loss rate equal to the minimum infiltration index is applied. Here, a loss rate of 0.3 cm/h is used as recommended in the CWC (1984) report.

4.5.2 Base flow for design flood

Base flow is the portion of stream flow that comes from the sum of deep subsurface flow and delayed shallow subsurface flow. CWC (1984) has analyzed total 48 events for estimating base flow. The recommended value of base flow $0.05 \text{ m}^3/\text{s/km}^2$ for Subzone-1(a) is used in this study.

4.5.3 Time adjustment of design rainfall

To determine the maximum depths for unrestricted periods and also to obtain short duration (less than 24-hours) increments of rainfall required for small and medium sized catchments, it is necessary to adjust the depth-duration curve of the design storm based on daily data. The Manual on estimation of design flood (CWC, 2001) analysed time distribution pattern of storms in the area for which adequate self recoding rain-gauge data are available. In the manual, depth duration analyses of maximum rainfall depths for standard duration of 6, 12, 18, 24, 36, 48 hours etc., were obtained for each of the storms and expressed as percentage of the total storm depth. Enveloping percentages are then obtained and applied to adjust the design rainfall based on observational day data. In

absence of hourly rainfall data it is recommended to apply a factor of 1.15 to convert 1-day maximum rainfall to 24-h maximum rainfall.

4.5.4 Design storm duration

The duration of storm rainfall which causes maximum discharge in a drainage basin is called design storm duration. The flood hydrographs due to 1-day maximum rainfall is correct for clock hour (24-h) and the hourly distribution was made according to recommended in the CWC (1984) report.

4.6 Estimation of Design Flood Hydrographs

The flood hydrographs are estimated by first calculating annual maximum rainfall at each rain-gauge station for various return periods obtained from L-moments based rainfall frequency analysis. The regional rainfall is also estimated. The 24 hour rainfall is divided in to incremental hourly rainfall according to time distribution provided in the CWC (1984) report. To obtain the critical sequence of rainfall the largest of increments is placed against the peak of UH, then the next largest against the next UH ordinate and so on until all rainfall increments get arranged. Then the sequence is reversed to get the critical sequence for all spells. In case of 24-h duration rainfall the first and second 12 h blocks are interchanged to get critical situation. The design loss rate is subtracted from the hourly rainfall to obtain effective rainfall hyetograph and the direct runoff hydrograph is estimated by convoluting this effective rainfall with UH. Finally, the base flow is added to obtain design flood hydrograph.

4.7 Flow Simulation and Flood Modelling

The flow in Aligarh drain and rainfall induced catchment flooding has been modelled MIKE 21 model. The MIKE 21 has been dynamically linked to the MIKE 11 model, into a single package called MIKE FLOOD developed at the Danish Hydraulic Institute (Rungo and Olesen, 2003) is widely used for flood inundation studies. (Sanders, 2007; Chatterjee et al., 2008; Patro et al., 2009 and Pramanik et al, 2010). The methodology and the working principal of MIKE FLOOD are being discussed in the following sections.

4.7.1 Flow modelling by Mike 11 hydrodynamic model

MIKE 11 is a versatile and modular engineering tool for modelling hydrodynamic conditions in rivers, lakes/reservoirs, irrigation canals and other inland water systems. It is a fully dynamic modelling tool for the detailed analysis, design, management and operation of both simple and Complex River and channel systems (DHI, 2004). The hydrodynamic (HD) model is the nucleus of the MIKE 11 modelling system and forms the

basis for simulation of flood inundation. The HD model is capable of simulating unsteady flow in a network of rivers. The result of HD simulation consists of a time series of water level and discharges at various points along the river system. MIKE 11 HD provides a choice among three different flow descriptions, namely kinematics, diffusive and dynamic wave approaches. MIKE 11 HD solves the Saint-Venant equations to obtain the hydrodynamic state of the river networks. The post-processor tool of MIKE 11 is the MIKEVIEW, which helps to view and analyze the results through graphical and animated interfaces.

4.7.1.1 Governing Equations

The governing equations in MIKE 11 are 1-D (one-dimensional) and shallow water type, which are the modifications of basic Saint-Venant equations. These are transformed to a set of implicit finite difference equations, and solved using double sweep algorithm (Abbot and Ionescu, 1967). The computational grid comprises of alternating Q and H_1 points automatically generated by the model, on the basis of user requirements (Figure 4.2). Q points are always placed midway between neighbouring H_1 points. H_1 points are located at cross sections or at equidistant intervals, in between if the distance between cross-sections is greater than the maximum space interval, dx specified by the users (dx=100 m in the present setup).



Figure 4.2 : MIKE 11 computational grids

4.7.1.2 MIKE 11 model setup

In the present study, the MIKE 11 model setup is prepared by defining following five input parameters:

- 1. Layout of river/ canal network
- 2. Cross section data definition
- 3. Defining hydrodynamic boundary conditions
- 4. Setting the HD parameters
- 5. Fixing the simulation parameters

4.7.1.3 Layout of river networks

The layout of MIKE 11 river networks are prepared by digitizing the scanned and georeferenced topographical map of the study area in the MIKE 11 network editor tool. Figure 4.3 presents the digitized drainage reach of the study area. The space interval between consecutive points are kept finer (dx=100m) to get accurate representation of the drainage network.



Figure 4.3 : Drainage network in MIKE-11

4.7.1.4 Cross section data definition

The topographical description of the area to be modelled is achieved through the specification of cross-sections of the drains, which lie approximately perpendicular to the direction of flow. Cross-sections are specified by a number of x-z co-ordinates where x is the transverse distance from a fixed point (often left bank top) and z is the corresponding bed elevation. Physically there should be a sufficient number of cross-sections to define adequately the variation in river shape. In the present study the actual measured cross-sections provided by THDC are used. The x-z co-ordinates are entered as raw data in the cross-section editor. The raw data are then automatically processed into a form used in the hydrodynamic calculations, i.e. the hydraulic parameters; cross-sectional area, hydraulic radius and width are calculated for a number of elevations between a minimum and a maximum which are either determined automatically or may be user specified.

4.7.1.5 Hydrodynamic boundary condition definition

Boundary conditions are required at all model boundaries, i.e. upstream and downstream ends of model branch which are not connected at any junction. The boundary conditions may be internal or external. The internal boundary condition includes the specifications at nodal points and structures, whereas the external boundary condition includes the specification of constant values of H or Q or time varying values of Q or H at start and end points. In the present setup there are three branches, each having two open hydrodynamic boundaries. The upstream boundary condition for Aligarh drain is given as design discharge. The downstream boundary condition is given as constant water level.

4.7.1.6 Setting the HD parameters

The HD parameters, in the present study, include the initial conditions of water level and discharge, friction coefficient (n) and output parameters options. Initial conditions are required to avoid the dry bed conditions. The n value is specified as 0.033. The global value for the initial condition for water level is kept at a low value of 0.01m to avoid dry bed conditions.

4.7.1.7 Fixing the simulation parameters

Before running the model simulation, control parameters such as simulation period, simulation time step, data to be stored and storage time have to be specified. The simulation periods are specified by start and end dates specified by year, month, day and hour and minute. MIKE 11 checks the actual time and reads all the data given in the time series during the simulation. There exists a versatile relationship between the time step and

the computational distance (dx) to define the Courant number given below, which is widely considered to choose the time step for the model simulation.

Courant number
$$(C_R) = \frac{\Delta t \left(V + \sqrt{gy} \right)}{\Delta x}$$
 (36)

Where, Δt = time step, V= mean flow velocity (m/s), y = water level (m) and $\Delta x = dx$ -max. If there is a large value of dx, the time step should be chosen so small that the C_R value should be low. Low value of C_R is needed to avoid instability during the model simulation. In the present setup the time step is kept very low as 2 second with the dx value of 100 m. The simulation has been performed for 48 h period starting from 7/1/2012 1:00:00 AM to 7/3/2012 1:00:00 AM. These dates are hypothetical.

4.7.1.8 Calibration and validation of MIKE 11

Calibration of a model is the process of adjusting model parameters to obtain a close agreement between the observed and the simulated outputs. Validation of the calibrated model is essential to check the calibration precision. Observed stage/discharge data of the river are not available for the calibration and validation process.

4.7.2 Two-Dimensional flow modelling by Mike 21 HD model

MIKE 21 HD is the basic computational hydrodynamic model of the entire MIKE 21 system. MIKE 21 HD simulates the water level variations and flows in response to a variety of forcing functions in creeks, rivers, lakes, estuaries, bays and coastal areas. The water levels and flows are resolved on a rectangular grid covering the area of interest. MIKE 21 HD is able to model the wide range of conditions likely to be encountered in inland waterways and their floodplains.

MIKE 21 system solves the full, time dependent, non-linear equations of continuity and conservation of momentum equation as given below.

$$\frac{\partial \zeta}{\partial t} + \frac{\partial p}{\partial x} + \frac{\partial q}{\partial y} = \frac{\partial d}{\partial t}$$

$$\frac{\partial p}{\partial t} + \frac{\partial}{\partial x} \left(\frac{p^2}{h}\right) + \frac{\partial}{\partial y} \left(\frac{pq}{h}\right) + gh \frac{\partial \zeta}{\partial x} + \frac{gp \sqrt{(p^2 + q^2)}}{C^2 \cdot h^2}$$

$$- \frac{1}{\rho_w} \left[\frac{\partial}{\partial x} (h_{xx}) + \frac{\partial}{\partial y} (h_{xy})\right] - \Omega_q - f(V) V_x + \frac{h\partial}{\rho_w \partial x} (p_a) = 0$$

$$(34)$$

Where, $\zeta =$ surface elevation (m), t = time (sec), p = flux density in x direction (m³/s/m), x, y = space coordinates (m), d = time varying water depth (m), h = water depth (m), g = acceleration due to gravity (m/s²), C = Chezy resistance coefficient (m^{1/2}/s) (in the model resistance may also be defined using Manning's coefficient and the equation is transformed accordingly), $\Omega_q =$ Coriolis parameter (s⁻¹), $\rho_w =$ density of water and f(V) = wind friction factor.

The solution is resolved using an implicit finite difference scheme of second order accuracy. MIKE 21 includes a special statistical feature for inundation mapping. Often information like the maximum depth, the time of the maximum depth, the maximum velocity and the time of the maximum velocity are sought as the most significant information of a flood study. This information is easily determined on the basis of output data from MIKE 21 using the statistical post-processing routine of the MIKE 21 package.

4.7.2.1 MIKE 21 HD model set up

For the simulation of MIKE FLOOD, MIKE 21 set up is required, because the former is a coupled unit of both MIKE 11 and MIKE 21 simulations. MIKE 21 model has many basic input parameters like; bathymetry, simulation period, boundary, source and sink, mass budget, flood and dry, and hydrodynamic parameters like; initial surface elevation, boundary, source and sink, eddy viscosity, resistance, wave radiation, wind condition etc. In the present study, parameters defining bathymetry, point source, precipitation initial surface elevation, flood and dry thresholds have been used. The resolution of the prepared bathymetry is $10m \times 10m$. The computational time step (Δt) is set to lower value of 2 seconds for different simulations. The prepared MIKE 21 setup, in the present study, is executed to check the error, however the simulation file (*.m21) is used as input to execute MIKE FLOOD, which is described below.

4.7.3 Flood inundation modelling by MIKE FLOOD

MIKE FLOOD couples MIKE 11 and MIKE 21 into a single system. Using a coupled approach, MIKE FLOOD enables to extract the best features of both MIKE 11 and MIKE 21 to simulate floods, while at the same time avoiding many of the limitations of resolution and accuracy encountered when using MIKE 11 or MIKE 21 separately. There are four types of links available in MIKE FLOOD to couple the MIKE 11 river system with the MIKE 21 cells. They include, Standard link, Lateral links, Structure link and Zero flow link. The standard link is the standard linkage in MIKE FLOOD, where one or more MIKE 21 cells are linked to the end of a MIKE 11 branch. This type of link is useful for connecting a detailed MIKE 21 grid into a broader MIKE 11 network, or to connect an
internal structure or feature inside a MIKE 21 grid. The lateral link allows a string of MIKE21 cells to be laterally linked to a given reach in MIKE 11, either a section of a branch or an entire branch. Flow through the lateral link is calculated using a weir equation or a Q-H table. This type of link is particularly useful for simulating overflow from a river channel onto a floodplain, where flow over the river levee is calculated using a weir equation. The structure link takes the flow terms from a structure in MIKE 11 and inserts them directly into the momentum equations of MIKE 21. The zero flow link is defined to prohibit the flow across the cell in a particular direction of X or Y. In this study MIKE 21 model setup is prepared with rainfall as input.

4.8 Safe Grade Elevation

The maximum flood level or the high water level (above Indian Mean Sea Level, IMSL) is arrived at from the model results for the most severe flooding condition at the plant site. National Disaster Management Authority, Government of India recommends the plinth levels of all the buildings 0.6 m above the drainage/ flood submersion lines (NDMA, 2008). In fact sufficient freeboard provides an extra measure of flood protection above the base flood elevation to account for waves, debris, hydraulic surge or insufficient data. The NDMA guideline recommends preparing the flood inundation maps using topographical maps at 1:10,000 scale with contours of 0.5/1.0 m and digital elevation model (NDMA, 2008). In present study, the main source of flooding is local site rainfall and overflow from the Aligarh drain.

4.9 Drainage Design

The drain around proposed plant area is designed to safely carry the runoff generated due to various return period rainfall. The cross-section of the drains are designed according to the Indian Standard, IS 10430:2000 (BIS, 2006). Trapezoidal section drains with side slope 1.5:1 (H:V) and longitudinal slope of 0.001 m/m (1.0 m/km) is designed using Mannings formula. The drain sections are designed for velocity less than 2.0 m/s and Manning's roughness coefficient (n) values of 0.015. The Free board recommended in the standard and used in this study are: 0.75 m for discharge greater than 10 m³/s and 0.6 m for discharge less than 10 m³/s. A typical cross-section of the drain is shown in Figure 4.4.



Figure 4.4: Typical Cross-section of the drain.

$$Q = VA \qquad V = \frac{k}{n} R^{2/3} S^{1/2} \qquad R = \frac{A}{p} \qquad A = \frac{y}{2} (b+T)$$

$$P = b + y \left(\sqrt{1 + z_1^2} + \sqrt{1 + z_2^2} \right) \qquad T = b + y (z_1 + z_2)$$

$$Z = \frac{x}{y}$$

5.1 Estimation of 1-day Annual Maximum Rainfall

The annual 1-day maximum rainfall series for all three stations are given in Figure 5.1 (Tabular value given in annexure II). The highest 1-day annual maximum rainfall observed at Aligarh Obsy, Bulandshahr Obsy and Khurja are 327.2 mm, 220.0 mm and 279.4 mm respectively.



Figure 5.1 : Annual 1-day maximum rainfall.

5.2 Estimation of 1-Day Rainfall of Various Return Periods using L-Moments Based Rainfall Frequency Analysis

Estimation of 1-day rainfall of various return periods using the L-moments based rainfall frequency analysis is described as follows.

5.2.1 Identification of robust distribution for 1-day maximum rainfall

Rainfall frequency analysis has been carried out using the L-moments approach. The robust frequency distribution for the study area has been identified based on Z_i^{dist} Statistic and L-moment ratio diagram. The Zi dist Statistic for various distributions for each three rain-gauge stations are given in Table 5.1. Figure 5.2 to Figure 5.4 show the L-moments ratio diagram for each of three rain-gauge stations and Figure 5.5 show the L-moments ratio diagram for regional of three rain-gauge stations. Based on the Z_i ^{dist} Statistic and Lmoment ratio diagram robust frequency distributions have been identified for the three rain-gauges and the regional rainfall frequency analysis procedure. The parameters for various distributions for 1-day maximum rainfall are given in Table 5.2. The first row of the parameter values (Table 5.2) shows the robust identified frequency distributions for each of the cases. The growth factors or site-specific scale factor (R_T/\overline{R}) are computed by dividing rainfall quantile (R_T) by the annual mean maximum rainfall of a rain gauge station (\overline{R}) as given in Table 5.3. The 1-day maximum rainfall for various return periods are estimated by multiplying the respective growth factor with mean annual maximum rainfall of the station as given in Table 5.4. The rainfall for 50 year return period is maximum at Bulandshahr (26. 26 cm) and the regional rainfall (28.99 cm) is maximum for 100 year return period are considered for further analysis as conservative approach.

S. No.	Distribution	Z _i ^{ust} –statistic				
Aligarh	Aligarh					
1.	Generalized Normal (GLO)	-0.38				
2.	Generalized Extreme Value (GEV)	-0.65				
3.	Generalized logistic (GNO)	-0.91				
4.	Pearson Type III (PE3)	-1.35				
5.	Generalized Pareto (GPA)	-1.39				
Buland	shahr					
1.	Generalized Pareto (GPA)	-0.14				
2.	Pearson Type III (PE3)	-0.16				
3.	Generalized logistic (GNO)	-0.36				
4.	Generalized Extreme Value (GEV)	-0.48				
5.	Generalized Normal (GLO)	-0.73				

Table 5.1 Zi ^{dist} -	- Statistic	of various	distributions	for 1-da	av annual	maximum	rainfall
	Statistic	or various	aistiioations	101 1 0	ay amaan	mannann	rannan

S. No.	Distribution	Z _i ^{dist} –statistic				
Khurja	Khurja					
1.	Generalized Extreme Value (GEV)	0.06				
2.	Generalized Normal (GNO)	-0.13				
3.	Pearson Type III (PE3)	-0.50				
4.	Generalized logistic (GLO)	-0.64				
5.	Generalized Pareto (GPA)	-1.30				
Region	al					
1.	Generalized Extreme Value (GEV)	-0.30				
2.	Generalized Normal (GLO)	0.31				
3.	Generalized logistic (GNO)	-0.67				
4.	Pearson Type III (PE3)	-1.30				
5.	Generalized Pareto (GPA)	-1.87				

Table 5.2 Parameters of various distributions for 1-day annual maximum rainfall

Distribution	Parameters of the Distribution				
Aligarh					
GLO	$\xi = 0.880$	$\alpha = 0.197$	k = -0.325		
GEV	$\xi = 0.773$	$\alpha = 0.263$	K = -0.228		
GNO	$\xi = 0.868$	$\alpha = 0.345$	k = -0.682		
PE3	$\mu = 1.000$	$\sigma = 0.470$	γ = 1.949		
GPA	$\xi = 0.523$	$\alpha = 0.486$	k = -0.019		
Bulandshahr					
GLO	$\xi = 0.894$	$\alpha = 0.242$	k = -0.246		
GEV	$\xi = 0.758$	$\alpha = 0.344$	K = -0.116		
GNO	$\xi = 0.883$	$\alpha = 0.426$	k = -0.512		
PE3	$\mu = 1.000$	$\sigma = 0.509$	$\gamma = 1.484$		
GPA	$\xi = 0.407$	$\alpha = 0.717$	k = 0.209		
Khurja	·		·	· · ·	
GLO	$\xi = 0.890$	$\alpha = 0.282$	k = -0.224		
GEV	$\xi = 0.728$	$\alpha = 0.408$	K = -0.083		
GNO	$\xi = 0.878$	$\alpha = 0.497$	k = -0.465		
PE3	$\mu = 1.000$	$\sigma = 0.576$	γ = 1.353		
GPA	$\xi = 0.304$	$\alpha = 0.883$	k = -0.267		

Distribution	Parameters of the Distribution				
Regional					
GLO	$\xi = 0.883$	$\alpha = 0.239$	k = -0.272		
GEV	$\xi = 0.749$	$\alpha = 0.332$	K = -0.153		
GNO	$\xi = 0.871$	$\alpha = 0.420$	k = -0.566		
PE3	$\mu = 1.000$	$\sigma = 0.521$	γ = 1.634		
WAK	$\xi = 0.308$	α = 1.494	$\beta = 5.010$	γ = 0.391	$\delta = -0.119$



Figure 5.2: L-moments ratio diagram for Aligarh for 1-day annual maximum rainfall



Figure 5.3: L-moments ratio diagram for Bulandshar for 1-day annual maximum rainfall



Figure 5.4: L-moments ratio diagram for Khurja for 1-day annual maximum rainfall



Figure 5.5: L-moments ratio diagram for Regional for 1-day annual maximum rainfall

Daingauga	Return periods (Year)							
Kanigauge	2	10	25	50	100	200	500	1000
Aligarh	0.880	1.513	1.978	2.424	2.976	3.664	4.844	6.000
Bulandshahr	0.870	1.717	2.086	2.320	2.526	2.702	2.900	3.026
Khurja	0.880	1.737	2.222	2.607	3.012	3.440	4.043	4.530
Regional	0.875	1.642	2.120	2.523	2.967	3.460	4.195	4.800

Table 5.3 Values of growth factors (R_T / \overline{R}) for 1-day annual maximum rainfall

Table 5.4 1-day annual maximum rainfall (mm) for various return periods

Daingauga	Return periods (Year)							
Kanigauge	2	10	25	50	100	200	500	1000
Aligarh	85.1	146.3	191.3	234.5	287.9	354.4	468.6	580.4
Bulandshahr	98.4	194.2	235.9	262.6	285.7	305.6	328.0	342.3
Khurja	73.3	144.6	185.0	217.0	250.7	286.4	336.5	377.1
Regional	85.5	160.4	207.1	246.5	289.9	338.0	409.8	471.2

5.3 Estimation of Synthetic Unit Hydrograph

The various catchments delineated are shown in Figure 5.6. The length of Aligarh drain upto Ghatal cut is 9.158 km and length of Aligarh drain from entry to plant boundary to Ghatal cut is 2.66 km. Hence, the Length of Aligarh drain upto plant boundary is 6.5 km. The longitudinal slope is taken as per UPID. The catchment characteristics of the basin is given Table 5.5 and parameters of UH derived using these characteristics are given in Table 5.6. The 1-h Synthetic Unit Hydrograph plotted using above parameters is shown in Figure 5.7 and the ordinates are given in Table 5.7.



Figure 5.6: Delineated Catchment area

SI. No.	Parameters & Relationship	Values
1	Length of main stream (L) (km)	6.5
2	Equivalent slope (S) (m/km)	0.34
3	Area (A) (km^2)	10.5

Table 5.5 Catchment characteristics

Table 5.6 Parameters of Synthetic Unit Hydrograph.

SI. No.	Parameters & Relationship	Values
1	$q_p = \frac{2.030}{\left(L/\sqrt{S}\right)^{0.649}}$	0.42
2	$t_p = \frac{1.858}{q_p^{1.038}}$	4.5
3	$W_{50} = \frac{2.217}{q_p^{0.990}}$	5.17
4	$W_{75} = \frac{1.477}{q_p^{0.876}}$	3.12
5	$WR_{50} = \frac{0.812}{q_p^{0.907}}$	1.76
6	$WR_{75} = \frac{0.606}{q_p^{0.791}}$	1.93
7	$T_B = 7.744 \left(t_p \right)^{0.779}$	24.99
8	$Q_p = q_p \times A$	4.46



Figure 5.7: 1-h unit hydrograph.

Time (h)	Runoff (m ³ /s)	Time (h)	Runoff (m ³ /s)
0	0.00	13	0.75
1	0.20	14	0.60
2	0.60	15	0.50
3	1.60	16	0.40
4	3.40	17	0.30
5	4.50	18	0.22
6	4.30	19	0.20
7	3.10	20	0.15
8	2.40	21	0.10
9	1.80	22	0.07
10	1.50	23	0.05
11	1.20	24	0.03
12	1.00	25	0.00

Table 5.7	Ordinates	of 1-h	unit l	hvdro	graph.
1 4010 0.7	Orannates	01 1 11	will's 1		5 m p 11.

5.3.1 Base flow for design flood

On this basis, the design base flow of $0.05 \text{ m}^3/\text{s}$ per sq. km. of the catchment area has been recommended and in this study also the recommended base flow has been adopted. In the present study base flow for the sub basins is found to be $0.525 \text{ m}^3/\text{s}$.

5.3.2 Temporal Distribution

The temporal rainfall distribution for 24 h duration is provided in the in the CWC report. This provides rainfall increments at unit duration. Then, the incremental depths are arranged in critical order for each bells of 12 h duration as mentioned in the Manual on Estimation of Design Flood (CWC, 2001). For this the largest of increments is placed against the peak of UH, then the next largest against the next UH ordinate and so on until all rainfall increments get arranged. Then the sequence is reversed to get the critical sequence for all spells. In case of 24-h duration rainfall the first and second 12 h blocks are interchanged to get critical situation.

5.4 Estimation of Flood Hydrographs

The details of estimation of flood hydrographs using two methods are discussed as follows.

5.4.1 Estimation of Flood hydrographs using 1-day annual maximum rainfall

After applying clock hour correction the 2, 10, 25, 50 and 100 year return period 24-h maximum areal rainfalls are found to be 9.83 cm, 18.45 cm, 23.82 cm, 28.35 cm and 33.35 cm respectively. The time distribution of rainfall was adopted according to the CWC (1984) report. The Cumulative rainfall distribution for 24-h storm duration is show in Figure 5.8. The hourly rainfall hyetograph for 24 h duration for 50 year and 100 year return period are shown in Figure 5.9. Base flow has been estimated using the 0.05 $m^3/s/km^2$ for the catchment area and added to estimated direct runoff hydrograph for estimating flood hydrographs. The Peak flood for 2, 10, 25, 50 and 100 year return periods are found to be 20.13 m^3/s , 44.06 m^3/s , 59.1 m^3/s , 71.59 m^3/s and 85.88 m^3/s respectively and the flood hydrographs are shown in Figure 5.10. The ordinates of flood hydrographs are given in annexure III.



Figure 5.8: Time duration curve for the 24-h rainfall



Figure 5.9: Rainfall hyetograph for 1-day maximum rainfall



Figure 5.10: Design flood hydrographs for various return periods resulting from 1-day annual maximum rainfall.

5.5 Flood simulation

The flood at proposed plant site may occur due to factors like overflow from the Aligarh drain, at site high rainfall and runoff from the surrounding areas.

5.5.1 Flow through Aligarh drain

The design discharge at inlet and outlet of Aligarh drain at plant area provided by UPID are 6.3 m^3 /s and 7.1 m^3 /s respectively. The Mike-11 setup of Aligarh drain is shown in Figure 5.11. It is observed that the drain is unable to carry the design discharge in present condition. Moreover, the surveyed cross-section shows that the depth of drain varies from 0.53 m to 2.28 m in width of 10 m. Further, the discharge in Aligarh drain estimated for 50 year return period rainfall is very high compared to the discharge provided by UPID. Hence, the sections needed modification to carry this high discharge.



Figure 5.11: Mike-11 setup of Aligarh drain.

5.5.2 Modification of the Aligarh drain

The existing and proposed aligned Aligarh drain is shown in Figure 5.12. The existing ground surface elevation and proposed bead level profiles of the realigned section of Aligarh drain is shown in Figure 5.15. The existing cross-section of Aligarh drain at inlet and outlet is shown in the Figure 5.13. The drain sections are surveyed for 10m width. Here, the proposed modified drain section given in Figure 5.14 are designed for 10 m width due to the space constraints and the corresponding flooding due to 100, 50, 25 and 10 year return period rainfall are studied. The Aligarh drain is designed for lined trapezoidal section with Manning's roughness of 0.015; 5 m base width and 1.5 m depth. The side slopes are 1.5:1 (H:V) and longitudinal slope is 0.35 m/km. Such section will be able to safely carry a discharge of 15.1 m^3 /s with a velocity of 1.3 m/s.



Figure 5.12: Existing and proposed re aligned Aligarh drain.



Figure 5.13: Existing cross-section of Aligarh drain at inlet and outlet



Figure 5.14: Proposed modified drain sections



Figure 5.15: Elevation profile along the realigned section of Aligarh drain

5.5.3 Combined flooding due to rainfall and flow through Aligarh drain

To study the effect of local rainfall of various return periods and corresponding flow in the Aligarh drain the Mike-11 setup is coupled with Mike-21 setup of plant area. The Bathymetry of plant area (Figure 5.16) is prepared at 5 m grid size for Mike Flood simulation. The combined effect of flooding due to overflowing of Aligarh drain and 100 year return period rainfall is shown in Figure 5.17. The longitudinal profile of Aligarh drain along with maximum water surface water elevation is shown in Figure 5.18. It may be observed that the overtopping of Aligarh drain is in all sections. However, in some locations the surface levels are higher and there is no flooding (Figure 5.17). Seven grids (cross marked in Figure 5.17) are selected on both sides of drain to view detail time series. The water depth and water levels at these grids are shown in Figure 5.19 and Figure 5.20 respectively. It can be noticed that the maximum water level at most upstream grid attains maximum of 193.3 m and in all other cases the maximum level is below 193.1 m. The water depth for 50, 25 and 10 year return periods are shown in Figure 5.21 to Figure 5.23 respectively. The water levels for various return periods during 48 hour simulation period at the selected seven grid points are shown in Figure 5.24 (a) to (g) and the maximum water levels are given in Table 5.9.



Figure 5.16 Bathymetry of the plant area



Figure 5.17: Flood water depth due to 100 year return period rainfall.



National Institute of Hydrology, Roorkee

SI.	Location	Elevation RL				
No.	(X,Y)	(m)				
1	(218,619)	192.64				
2	(244,538)	192.53				
3	(291,465)	192.50				
4	(222,428)	192.01				
5	(383,375)	191.46				
6	(328,189)	192.00				
7	(287,142)	192.01				

Table 5.8: Details of selected grids



Figure 5.19: Water depths at selected grids for 100 year return period flood



Figure 5.20: Water levels at selected grids for 100 year return period flood



Figure 5.21: Flood water depth due to 50 year return period rainfall



Figure 5.22: Flood water depth due to 25 year return period rainfall



Figure 5.23: Flood water depth due to 10 year return period rainfall









Figure 5.24 : Water levels for various return period flood. (a) to (g) for grid point 1 to 7

Grid	Maximum water level RL (m)			
Sl. No.	100 Year	50 Year	25 Year	10 Year
1	193.30	193.24	193.18	193.05
2	193.11	193.04	192.97	192.82
3	193.10	193.03	192.97	192.81
4	193.10	193.04	192.97	192.81
5	193.02	192.85	192.70	192.43
6	193.02	192.85	192.70	192.43
7	193.01	192.89	192.83	192.69

Table 5.9 : Maximum water level at selected grids for various return periods

5.6 Safe Grade Elevation

As discussed above flooding in the plant area may occur due to local rainfall and overflowing of Aligarh drain. The rainfall generated flow from upper catchment flows through Aligarh drain inside plant boundary. The cross-section of Aligarh drain is modified in 10 m width and realigned as shown in Figure 5.12. However, the modified section is also not able to carry the 100 year discharge and flooding has been observed. Hence, the possible flooding will be due to local rainfall and overflowing of Aligarh drain and needs be considered both in deciding the safe grade. It has been observed that maximum flood depth for this case is not uniform within the plant layout boundary and depending upon topography, it varies from 0.1 cm to 1.5 m for 100 year return period rainfall excluding some local depressions. Further, the maximum water level at most upstream grid (Grid 1) reached maximum up to 193.3 m and other grids are below 193.1 m (Table 5.9). The model setup has been prepared with limited data and therefore 0. 2 m may be kept extra buffer to cater data and model uncertainty in deciding safe grade elevation. Considering these aspects the safe grade should be higher than 193.5 m (193.3+0.2). In present situation about 20% of total plant area is above 193.5 m (Figure 5.25). The National Disaster Management Authority, Government of India recommends the plinth levels of all the buildings 0.6 m above the drainage/ flood submersion lines (NDMA, 2008). Moreover, the highway is also at a RL of 194.399 m (RP-14 in the Topographical survey of proposed Khurja STPP site). Considering these aspects, it is suggested to have the safe grade level in the plant area should be higher than RL 193.5 m and the the plinth levels should be higher than 194.1m or 194.4 m to avoid any drainage congestion due to highway alignment.

Hence, it is also recommended that the important plant and system installation should be placed at safe flood level of RL 193.5 m while the land development work within the plant site should be carried out to maintain the natural slope to facilitate the drainage in the area and divert any entry of excess water through plant boundary.



Figure 5.25: Percentage of area in existing levels.

5.7 Proposed Drainage Network

5.7.1 Drainage layout

The proposed local and periphery drains (1 to 13) are aligned along the plant boundary and roads as shown in Figure 5.26. The drains and their possible drainage area are shown in Figure 5.27. The white colour area will drain to directly to the Aligarh drain. The drains are aligned according to the natural slope and existing topography. However, the drain-1 is proposed to divert along plant boundary even though the existing drain joins to Aligarh drain inside the plant area. Similarly, the natural slope of drain-3 area is towards drain-2 and the flow to Aligarh drain inside plant area. However, these drains are also proposed to divert along the plant boundary as suggested by THDCIL. Flow directions in the drains are indicated by arrow. The drainage area of each section is given in Table 5.10. The discharge in drains for various return periods are estimated by multiplying its drainage area with estimated discharge per unit area of the required return period. The drains 1 to 5 runs in series along the east side of plant boundary. The drain 5 is also expected to carry discharge of existing drain joining the Aligarh drain as it will be removed during land development process. Further the drain 13 represents the existing escape/drain for releasing excess flow from the distributary. The length of drain 11 will be less, if the Aligarh drain is realigned. Further drain 10 and 11 cross the highway though culverts and join to Aligarh drain.



Figure 5.26 : Proposed drainage layout


Figure 5.27: Proposed drainage network with contributing runoff area

			Peak flow (m ³ /s)				
Section	Length (m)	Area (km²)	Drainage	e area flow	Cumula	Cumulative flow	
			25 year	50 year	25 year	50 year	
1	1374.56	2.16	12.16	14.73	12.16	14.73	
2	1311.61	1.88	10.58	12.82	22.74	27.55	
3	630.80	0.20	1.13	1.36	23.87	28.91	
4	1071.51	0.64	3.60	4.36	27.47	33.27	
5	695.40	1.25	7.04	8.52	34.50	41.79	
6	565.09	0.09	0.51	0.61	0.51	0.61	
7	354.53	0.08	0.45	0.55	0.45	0.55	
8	475.02	0.25	1.41	1.70	1.41	1.70	
9	180.04	0.52	2.93	3.55	2.93	3.55	
10	308.25	0.52	2.93	3.55	5.85	7.09	
11	640.76	0.26	1.46	1.77	3.32	4.02	
13	666.75	0.63	3.55	4.30	4.05	4.91	

Table 5.10 Length, drainage area and peak flow of various sections.

5.7.2 Design of drain section

The cross-section of the drains are designed according the Indian Standard, IS 10430:2000 (BIS, 2006). Trapezoidal section with side slope 1.5:1 (H:V) and longitudinal slope of 0.001 m/m (1.0 m/km) is designed. The longitudinal slope (s) is kept low as the topography of area is very flat. The drain sections are designed for velocity less than 2 m/s and Manning's roughness coefficient (n) values of 0.015 (lined section). The Free board recommended in the standard and used in this study is 0.6 m for discharge less than 10 m³/s and 0.75 for higher discharge value. The design details of various drain sections for 50 year and 25 year return period are given in Table 5.11. The drain 13 represents existing escape drain. The calculated dimension may be less as it doesn't account for possible amount of discharge from the minor irrigation channel. Further, section 5 supposed to carry additional discharge diverted to it. Hence, to account for this additional discharge, the drain section needs modification..

Drain Section	Q	b	d	v	Z	fb	D	t	Т
1	14.73	2.0	1.7	2.0	1.5:1	0.75	2.4	7.0	9.2
2	27.55	2.9	2.0	2.3	1.5:1	0.75	2.8	8.9	11.2
3	28.91	3.0	2.0	2.3	1.5:1	0.75	2.8	9.0	11.3
4	33.27	3.0	2.2	2.4	1.5:1	0.75	3.0	9.6	11.9
5	41.79	4.0	2.2	2.5	1.5:1	0.75	3.0	10.6	12.9
6	0.61	0.5	0.6	1.0	1	0.6	1.2	1.7	2.9
7	0.55	0.5	0.5	1.0	1	0.6	1.1	1.5	2.7
8	1.70	1.0	0.8	1.2	1	0.6	1.4	2.6	3.8
9	3.55	1.0	1.0	1.4	1.5:1	0.6	1.6	4.0	5.8
10	7.09	2.0	1.2	1.7	1.5:1	0.6	1.8	5.6	7.4
11	4.02	1.0	1.1	1.5	1.5:1	0.6	1.7	4.3	6.1
13	4.91	1.0	1.1	1.5	1.5:1	0.6	1.7	4.3	6.1
25 year return per	riod								
1	12.16	2.0	1.5	1.9	1.5:1	0.75	2.3	6.5	8.8
2	22.74	2.9	1.8	2.2	1.5:1	0.75	2.6	8.3	10.6
3	23.87	2.9	1.9	2.2	1.5:1	0.75	2.7	8.6	10.9
4	27.47	3.0	2.0	2.3	1.5:1	0.75	2.8	9.0	11.3
5	34.50	3.5	2.1	2.4	1.5:1	0.75	2.9	9.8	12.1
6	0.51	0.5	0.6	0.8	1	0.6	1.2	1.7	2.9
7	0.45	0.5	0.5	0.9	1	0.6	1.1	1.5	2.7
8	1.41	1.0	0.7	1.2	1	0.6	1.3	2.4	3.6
9	2.93	0.8	1.0	1.4	1.5:1	0.6	1.6	3.8	5.6
10	5.85	2.0	1.0	1.5	1.5:1	0.6	1.6	5.0	6.8
11	3.32	1.0	1.0	1.4	1.5:1	0.6	1.6	4.0	5.8
13	4.05	1.0	1.1	1.5	1.5:1	0.6	1.7	4.3	6.1

Table 5.11 Design details of drain section for 50 year and 25 year return period **50 year return period**

 $Q = Design \ discharge \ (m^3/s)$

b = Bed width (m)

d = Depth without free board (m)

v = Velocity (m/s)

 $z = Side \ slope \ (H:V)$

 $fb = Free \ board \ (m)$

D = Depth with free board (m)

t = Top width without free board (m)

T = Top width with free board (m)

5.8 Limitation of the Study

The limitation of the study due to non availability of data and assumption in the model are as follows:

- 1. The contour of 0.5 m interval was only available for the proposed plant area. For the remaining area SOI contour and SRTM data is used.
- 2. The available observed hourly rainfall data was sufficient to generate hourly rainfall distribution curve, hence the time distribution of rainfall was done according to CWC (1984) report.
- 3. Drain alignments are made with exiting topography. This may be modified according to final level obtained after land levelling.

Based on study following conclusions are drawn:

- 1 The Digital Elevation Model (DEM) of the study area is prepared from surveyed contour (0.5 m) for the plant area, spot heights; contour digitized from the SOI toposheets and SRTM data. The basin boundary and drainage networks are delineated manually from the DEM and SOI toposheets inside ArcGIS.
- 2 The catchment area of Aligarh drain up to proposed plant boundary, its length and slope are used to derive unit hydrograph using the guideline provided by CWC.
- 3 The 1-day annual maximum rainfall for various return periods are estimated for the site Aligarh, Bulandshahr, Khurja by rainfall frequency analysis using L-moments approach. Similarly the regional 1-day annual maximum rainfall for various return periods are also estimated.
- 4 The regional L-moments based approach resulted in maximum rainfall value based on the data of three stations for 100 year return period rainfall. Hence, regional 1day annual maximum rainfalls for 100 year return period is used for design flood estimation and drain design. The regional rainfall estimated using the rainfall data of three rain gauge stations are 20.71 cm, 24.65 cm and 28.99 cm respectively for 25, 50 and 100 year return periods respectively.
- 5 The Peak discharge (m^3/s) in Aligarh drain for 2, 10, 25, 50 and 100 year return periods are found to be 20.13 m³/s, 44.06 m³/s, 59.1 m³/s, 71.59 m³/s and 85.88 m³/s respectively from its catchment area of 10.5 km².
- 6 It is observed that the existing cross-section of Aligarh drain is unable to carry design discharge. Hence, modified lined trapezoidal cross-sections is proposed. Moreover, possible re-alignment of Aligarh drain is also proposed. However, the width is limited to 10 m and overflow has been allowed.
- 7 The potential source of flooding at the plant site is due to the local rainfall and overflow from the Aligarh drain also.

- 8 The land formation level should be based on the computed maximum flood elevation for severe most flooding scenario (100 year return period), model uncertainty and limitation of data availability. Considering these aspects, it is suggested to have the safe grade level in the plant area higher than RL 193.5 m and the plinth levels should be higher than 194.1 m or 194.4 m to avoid any drainage congestion due to highway alignment. The land development work within the plant site should be carried out to maintain the natural slope to facilitate the drainage in the area and divert any entry of excess water through plant boundary.
- 9 The peak flow for 25 and 50 year return period rainfall is estimated for various local and periphery drain sections and the trapezoidal drains are designed using Mannings formula and free board is provided as per BIS standard *IS 10430-2000*.
- 10 The local and periphery drains are designed for trapezoidal section with a side slope of 1.5:1 (H:V) and longitudinal slope of 0.001 m/m (1.0 m/km) to carry the discharge generated locally. Moreover, the drain sections are designed for velocity less than 2 m/s and Manning's roughness coefficient (n) values of 0.015.

References

Abbot, M. B. and Ionescu F. (1967) On the numerical computation of nearly horizontal flows. *Journal of Hydraulic Research* 5(2):97-117

BIS (2006). IS 10430-2000 Criteria for Design of Lined Canals and Guidance for Selection of Type of Lining. (Reaffirmed 2004).

Chatterjee C., Förster S. and Bronstert A. (2008) Comparison of hydrodynamic models of different complexities to model floods with emergency storage areas. *Hydrological Processes* 22 (24): 4695-4709

CWC (1984) Flood estimation report for upper Indo-Ganga plains (Subzone-1e). Central Water Commission. New Delhi, India

CWC (2001) Manual on estimation of design flood. Hydrology Studies Organization. *Central Water Commission*, New Delhi, India.

Department of Agriculture & Cooperation (2012). Agriculture Contingency Plan, Department of Agriculture & Cooperation, Ministry of Agriculture, Government of India. http://agricoop.nic.in/Agriculture%20Contingency%20Plan/UP/UP6-Bulandshahar-26.7.2012.pdf

DHI (2004) A modelling system for rivers and channels: Reference manual. *DHI Water* and *Environment*, Denmark.

Greenwood, J.A., Landwehr, J.M., Matalas, N.C., and Wallis, J.R. (1979) Probability weighted moments: Definition and relation to parameters of several distributions expressible in inverse form. *Water Resources Research* 15:1049-1054.

Hosking, J. R. M. (1990) L-moments: Analysis and estimation of distributions using linear combinations of order statistics. *J. of the Royal Statistical Society*, Series B, 52: 105-124.

Hosking, J. R. M., and Wallis, J. R. 1997. Regional Frequency Analysis-An Approach Based on L-moments. *Cambridge University Press*, New York.

IMD (2012) http://www.imd.gov.in/section/hydro/distrainfall/webrain/up/bulandshahr.txt

Kumar, R. and Chatterjee, C. (2005) Regional flood frequency analysis using L-moments for North Brahmaputra Region of India. *J. Hydrologic Engineering, ASCE*, 10(1), 1-7.

NDMG (2008) National disaster management guidelines: Management of floods, National Disaster Management Authority, government of India, New Delhi, India.

Patro, S., Chatterjee, C., Mohanty, S., Singh, R. and Raghuwanshi, N.S. (2009) Flood Inundation modeling using MIKE FLOOD and remote sensing data. *Journal of Indian Society of Remote Sensing* 37:107-118.

Pramanik, N., Panda, R. K. and Sen, D. J. (2010) One dimensional hydrodynamic modeling of river flow using DEM extracted river cross-sections. *Water Resources Management* 24(5):835-852.

Rungo, M. and Olesen, K. W. (2003) Combined 1- and 2-dimensional flood modeling, 4th *Iranian Hydraulic Conference*, 21-23 October, Shiraz, Iran.

Sanders, B. F. (2007) Evaluation of on line DEM for flood inundation modeling. *Advances in Water Resources* 30: 1831-1843.

Vogel R.M., and Fennessey N.M. (1993) L-moments should replace product moments diagrams. *Water Resources Research* 29(6): 1745-1752.

Zafirakou-Koulouris, A., Vogel, R.M., Craig, S.M., and Habermeier, J. (1998) L moment diagrams for censored observations. *Water Resources Research* 34(5): 1241-1249.

Annexure-I

Terms and Conditions:

1 Scope of Work:

i. Study of existing natural drainage pattern/system, available information in the form of reports, literature, satellite imageries, etc. having a bearing on the storm water drainage system for proposed project and its adjoining areas. The study shall include review of topographical features of the proposed site for the Power Project and its surrounding area.

ii. Review and analysis of rainfall information to arrive at design storm scenarios.

iii. Review and analysis of relevant Survey of India Topographical sheets, topographical survey and satellite imageries.

iv. Estimation of flood hydrographs considering historical as well as design rainfall to suggest complete scheme for storm water drainage of project and its adjoining areas including diversion of existing nalas/streams, if any. In case short interval observed rainfall runoff data would not be available then the standard regional approaches will be used for design flood estimation.

v. Estimation and routing of design flood hydrograph through the drainage system of concerned catchments considering appropriate boundary conditions including pre-project scenario as well as post-project scenario for suggesting Safe Grade Elevation for the plant.

vi. Suggesting final disposal point for the storm water & plant drainage.

vii. Site visit for acquaintance of prevailing conditions and collection of available data at site.

viii. Visit to THDC office for discussions regarding the studies.

Annexure-II

	Aligarh	Bulandshahr			Aligarh	Bulandshahr	
Year	Obsy	Obsy	Khurja	Year	Obsy	Obsy	Khurja
1951	69.3		73.7	1981	327.2	220.0	50.8
1952	52.1		112.0	1982	94.0	81.0	47.0
1953	70.6		81.5	1983	177.8		
1954	115.6		157.0	1984	84.6		
1955	140.0		109.5	1985	73.0		44.5
1956	94.5		111.5	1986	85.2		174.0
1957	155.7		279.4	1987	43.4		129.0
1958	146.3		134.6	1988	121.0		69.0
1959	62.8		127.0	1989	64.0		85.0
1960	90.6		157.7	1990	59.0		46.0
1961	95.6		88.1	1991	143.4		98.5
1962	80.8		71.6	1992	63.2		80.0
1963	144.4		164.3	1993			37.0
1964	220.6		150.9	1994	91.2		92.0
1965	108.2		90.2	1995	81.2		29.0
1966	98.2		39.1	1996	85.4		35.0
1967	124.0		71.1	1997	76.0		38.0
1968	83.0		73.1	1998			48.0
1969	52.0		69.8	1999	47.8		52.5
1970	68.4	72.0	69.8	2000	90.0		33.0
1971	124.8	137.4	129.5	2001	41.0		14.5
1972	117.2	142.8	93.8	2002	90.0		26.0
1973	75.4	92.0	63.0	2003	134.0		100.0
1974	69.7	173.5		2004	63.0		55.0
1975	102.6	178.8		2005	59.6		75.0
1976	84.2	75.9	70.9	2006	88.0		36.5
1977	92.1	54.0	100.3	2007			27.0
1978	76.8	102.0		2008			64.0
1979	62.4	56.8		2009			39.0
1980	62.4	84.2	97.1	1	·		

Annual 1 day maximum rainfall (mm) at various stations

Annexure-III

Time	100	50	25	10	2
(h)	Year	Year	Year	Year	Year
0	0.53	0.53	0.53	0.53	0.53
1	0.53	0.53	0.53	0.53	0.53
2	0.53	0.53	0.53	0.53	0.53
3	0.53	0.53	0.53	0.53	0.53
4	0.56	0.53	0.53	0.53	0.53
5	0.65	0.54	0.53	0.53	0.53
6	0.85	0.56	0.53	0.53	0.53
7	1.24	0.64	0.53	0.53	0.53
8	1.77	0.80	0.56	0.53	0.53
9	2.35	1.05	0.63	0.54	0.53
10	2.96	1.37	0.80	0.55	0.53
11	3.70	1.76	1.10	0.57	0.53
12	4.39	2.29	1.46	0.59	0.53
13	4.94	2.81	1.75	0.64	0.53
14	5.20	3.23	1.93	0.77	0.53
15	5.67	3.44	2.36	1.13	0.53
16	7.19	3.89	3.46	1.92	0.53
17	9.70	5.20	5.17	3.04	0.56
18	12.60	7.30	7.09	4.32	0.66
19	15.66	9.69	9.18	5.78	0.98
20	20.32	12.24	12.42	8.18	1.90
21	28.21	16.16	18.02	12.43	3.89
22	40.53	22.85	26.77	19.14	7.24
23	57.98	33.30	39.20	28.72	12.16
24	76.77	48.13	52.59	39.04	17.52

Ordinate of flood hydrographs due to annual 1 day maximum rainfall for vario	us
return periods	

Time	100	50	25	10	2
(h)	Year	Year	Year	Year	Year
25	85.88	64.01	59.10	44.06	20.13
26	80.73	71.59	55.46	41.25	18.67
27	66.59	66.80	45.48	33.61	14.84
28	52.87	54.07	35.96	26.45	11.49
29	41.56	42.09	28.26	20.77	9.04
30	33.16	32.75	22.62	16.69	7.38
31	26.74	26.32	18.30	13.55	6.07
32	21.56	21.29	14.80	10.99	4.99
33	17.13	17.25	11.79	8.78	4.03
34	13.71	13.69	9.47	7.08	3.32
35	11.12	10.98	7.72	5.80	2.78
36	8.89	8.91	6.21	4.70	2.32
37	6.97	7.16	4.91	3.74	1.90
38	5.49	5.63	3.90	3.00	1.59
39	4.46	4.45	3.21	2.50	1.39
40	3.49	3.63	2.55	2.01	1.18
41	2.61	2.87	1.95	1.57	0.98
42	1.97	2.17	1.50	1.24	0.84
43	1.47	1.64	1.17	1.00	0.73
44	1.05	1.25	0.88	0.78	0.63
45	0.71	0.92	0.65	0.61	0.56
46	0.59	0.65	0.56	0.55	0.53
47	0.55	0.55	0.54	0.54	0.53
48	0.53	0.53	0.53	0.53	0.53



Website: www.nih.ernet.in

ENCLOSURE-4

QUANTITATIVE RISK ASSESSMENT

1.1 Introduction

Risk analysis follows an extensive hazard analysis. Identification of causes and types of hazards is the primary task for planning for risk assessment. Hazard can happen because of the nature of chemicals handled and the nature of process involved. So for risk analysis first step is to identify the hazardous chemicals which are to be studied for risk analysis.

It involves the identification and assessment of risks at the project site and in the neighboring population who could get exposed to, as a result of hazards present. This requires a thorough knowledge of failure probability, credible accident scenario, vulnerability of population etc.

In the sections below, the identification of various hazards, probable risks in the proposed power plant, maximum credible accident analysis, consequence analysis are addressed which gives a broad identification of risks involved in the plant.

Approach to the Study

Risk involves the occurrence or potential occurrence of some accidents consisting of an event or sequence of events. The risk assessment study covers the following:

- Identification of potential hazard areas;
- Identification of representative failure cases;
- Visualization of the resulting scenarios in terms of fire (thermal radiation) and explosion;
- Assess the overall damage potential of the identified hazardous events and the impact zones from the accidental scenarios;
- Assess the overall suitability of the site from hazard minimization and disaster mitigation point of view
- Furnish specific recommendations on the minimization of the worst accident possibilities; and
- Preparation of broad Disaster Management Plan (DMP), On-site and Off-site Emergency Plan, which includes Occupational and Health Safety Plan.

1.2 Chemical Hazards

Identification of Hazardous Chemicals is done in accordance with The Manufacture, Storage and import of Hazardous Chemical Rules, 1989. Schedule-1, of the Rule provides a list of the Toxic and Hazardous chemicals and the flammable chemicals. It defines the flammable chemicals based on the flashpoint and boiling point.

"Major accident hazards (MAH) installations" is defined as the isolated storage and industrial activity at a site handling (including transport through carrier or pipeline) of hazardous chemicals equal to or, in excess of the threshold quantities specified in Column-3 of Schedule-2 and 3 respectively.

Schedule-3 has classified hazardous substances in an operating plant into 5 groups and has provided the threshold quantities for application of above rules.

Group1 & 2 – Toxic substances

Group 3 – Highly reactive substances

- Group 4 Explosive substance
- Group 5 Flammable substances

The following **Table-1.0** shows the list of major chemicals stored onsite which have been identified as hazardous chemicals in The Manufacture, Storage and import of Hazardous Chemical Rules, 1989 and which are to be considered as Major accident hazards (MAH) installations.

LDO, HFO and Chlorine

The identification of specific scenarios is based on the assessment of likely events and incidence of failures. In most of the cases stored quantities of liquid fuel and chemicals are considered in hazard identification.

S. No.	Chemical	Use	Nature of Chemical (Schedule 1 & 3)	Storage Quantity	Threshold quantity for MAH
1.	Fuel Oil	Supporting Fuel	Highly Flammable	4100 KL*	2500 tonnes
2.	Transformer Oil	Transformer	Highly Flammable	15 KL	2500 tonnes
3.	Chlorine	Cooling Tower	Toxic – Group 2	25 tonnes*	10 tonnes
4.	Sulfuric Acid	Water Treatment	Hazardous	24 tonnes	Not considered
5.	Caustic soda	Water Treatment	Hazardous	24 tonnes	Not considered
6.	Ammonia	Selective Catalytic Reduction(SCR)	Hazardous		60 tonnes

Table- 1.0: Hazardous Chemicals in Thermal Power Plant

* To be considered as MAH

The chemicals which are stored more than the threshold quantities are considered for major accident hazard.

- 1. Fuel oil (LDO/HFO), used as supportive fuel in the boiler, and is classified as Highly Flammable liquid as its flash point remains within 30°C–90°C. Its threshold quantity is 2500 tonnes.
- 2. Chlorine is a toxic gas and its MAH quantity is 25 tonnes. A substantial release will then form a vapour cloud. As the cloud travels under the influence of wind, it disperses and its concentration becomes further diluted and at some distance concentration becomes non hazardous.
- 3. Sulphuric Acid,Ammonia and Caustic soda are hazardous chemicals but are not included in Schedule-3 for MAH.

1.3 Fire Hazards

- Tank Fire: Oil is stored in floating roof tank. Leak in rim seal leading to accumulation of vapour is a source of fire. Lighting can be a source of ignition and can cause tank fire. Overflow from tank leading to spillage may cause vapour cloud formation. This can catch fire and it can flash back to the tank to cause tank fire.
- Pool / Dyke fire: If there is outflow from the tank due to any leakage from tank or any failure of connecting pipes or valves, oil will flow outside and form a pool. Where the tank is surrounded by a dyke, the pool of oil will be restricted within that dyke. After sometime, the vapour from the pool can catch fire and can cause pool or dyke fire.

1.4 Explosion Hazards

Explosion hazards can take place due to the following machineries:

- Hydrogen plant
- Turbo generators where hydrogen is used for cooling of TG
- Transformer (oil cooled)
- Boiler (Coal/Oil fired)
- Coal dust in Mills and Boilers

Explosion hazards can take place due to the following reasons also:

a) Bursting of Pipe Lines, Vessels

- Water / Steam pipes due to high pressure/ temperature
- H₂ Gas lines and Acid lines.
- Acid/Alkali tanks
- H₂ Gas Cylinders
- Compressed air header
- Compressed air receivers
- H₂ Gas Holder
- Electrical Hazards
- Fire Hazards

b) Release of Gases / Dust

- Chlorine in water treatment plant
- Hydrogen in turbo generator area of main plant
- Pulverized coal dust from mills and associated piping
- Fly ash from chimneys and ash ponds, ESP hoppers and bottom ash system
- Coal dust in transfer points, CHP, Crusher & mill area.
- Flue gas from the ducts

c) Failure scenario/Release of Liquid posing risk are listed below:

- Spillage in Acid and alkali tanks in water treatment plants
- Leak in Chlorine toners
- Spillage, Leak & Catastrophic Rupture in Fuel oil tanks in fuel oil handling section
- Transformer oil and seal oil leakage

2.0 Maximum Credible Accident(MCA) Analysis

Maximum Credible Accident Scenario involves identification of failure modes and scenarios. The MCA analysis involves ordering and ranking of various sections in terms of potential vulnerability. The data requirements for MCA analysis are:

- Flow diagram and P&I diagrams
- Detailed design parameters
- Physical and chemical properties of all the chemicals
- Plant layout
- Past accident data

Fire and Explosion Index (FEI) & Toxicity Index (TI)

Fire and Explosion Index (FEI) is useful in identification of areas in which the potential risk reaches a certain level. It estimates the global risk associated with a process unit and classifies the units according to their general level of risk. FEI covers aspects related to the intrinsic hazard of materials, the quantities handled and operating conditions. This factor gives index value for the area which could be affected by an accident, the damage to property within the area and the working days lost due to accidents.

Degree of hazards based on FEI and TI is given in the following **Tables 2** and **3** respectively.

FEI Range	Degree of Hazard
0 - 60	Light
61-96	Moderate
97 – 127	Intermediate
128 - 158	Heavy
159 and Above	Severe

Table 2Degree of Hazards Based on FEI

Source: Dow's Fire and Explosion Index Hazard Classification Guide, Seventh Edition, AIChE Technical Manual (1994)

Table 3

Degree of Hazards Based on TI

TI Range	Degree of Hazard
0 – 5	Light
5 – 10	Moderate
Above 10	High

Preventive and protective control measures are recommended based on degree of hazard. Therefore, FEI indicates the efforts to be taken to reduce risks for a particular unit. FEI and TI computed for various process equipments are presented in **Table 4**

Table 4

Fire and Explosion Index and Toxicity index

Sr.	Unit Name	FEI	Category
No.			
	Fire and Explosion Index		
1	LDO Oil Storage Tank	15.1	Light
2	Transformer Oil Storage Tank	12.5	Light
3	Hydrogen cylinder	70.6	Moderate
	Toxicity index		
1	Chlorine Tonner	19.35	High
2	Sulphuric Acid storage	13.25	high
3.	Caustic Soda	12.1	High
4.	Ammonia	10.2	High

Consequence Analysis is the application of the mathematical, analytical and computer models (PHAST software) for calculation of the effects and damages subsequent to a hydrocarbon/toxic release Event.

PHAST & PHAST RISK Software is used to predict the physical behavior of hazardous incidents. The model uses below mentioned techniques to assess the consequences of identified scenarios:

- Modeling of discharge rates when Leaks develop in process equipment/pipe work.
- Modeling of the size & shape of the flammable/toxic gas clouds from releases in the atmosphere.
- Modeling of the flame and radiation field of the releases that are ignited and burn as pool fire.

2.1 Consequence Modelling

Discharge Rate

The initial rate of release through a leak depends mainly on the pressure inside the equipment, size of the hole and phase of the release. The release rate decreases with time as the equipment depressurizes. This reduction depends mainly on the inventory and the action taken to isolate the leak and blow-down the equipment.

Dispersion

Releases of gas into the open air form clouds whose dispersion is governed by the wind, by turbulence around the site, the density of the gas and initial momentum of the release. In case of flammable materials the sizes of these gas clouds above their Lower Flammable Limit (LFL) are important in determining whether the release will ignite. In this study, the results of dispersion modeling for flammable materials are presented LFL quantity.

Pool Fire

A cylindrical shape of the pool fire is presumed. Pool-fire calculations are then carried out as part of an accidental scenario, e.g. in case a hydrocarbon liquid leak from a vessel leads to the formation of an ignitable liquid pool. First no ignition is assumed, and pool evaporation and dispersion calculations are being carried out. Subsequently late pool fires (ignition following spreading of liquid pool) are considered. If the release is bounded, the diameter is given by the size of the bund. If there is no bund, then the diameter is that which corresponds with a minimum pool thickness, set by the type of surface on which the pool is spreading.

While modeling cases of lighter hydrocarbons in the range of ATF wherein the rainout fraction have been minimal (not leading to pool formation) due to the horizontal direction of release, downward impingement has been considered for studying the effects of pool fire for consequence analysis only.

Pool fires occur when spilled hydrocarbons burn in the form of large diffusion flames. Calculating the incident flux to an observer involves four steps, namely

- Characterizing the flame geometry
- Estimation of the flame radiation properties
- Computation of the geometric view factors
- Estimation of flame attenuation coefficients and computation of geometric view factors between observer and flame.

The size of the flame will depend upon the spill surface and the thermo chemical properties of the spilled liquid. In particular, the diameter of the fire, the visible height of the flame, the tilt and drag of the flame etc. The radioactive output of the flame will depend upon the fire size, the extent of mixing with air and the flame temperature. Some fraction of the thermal radiation is absorbed by the carbon dioxide and water vapor in the intervening atmosphere. In addition, large hydrocarbon fires produce thick smoke which significantly obscure flame radiation.

The calculations for radiation damage distances start with estimation of the burning velocity: $Y = 92.6 \text{ e} - 0.0043 \text{T}_{b} \text{Mw} 10^{-7} / (\text{D X 6})$

Where, y= burning velocity in m/s

Mw= molecular weight in kg/kg mol

T_b= normal boiling point

The next step involves calculation of the equivalent diameter for the spreading pool- this depends upon the duration of the spill (continuous, instantaneous, finite duration etc.). This is calculated using expressions like:

 $D_{eq} = 2(V/3.142y)^{1/2}$

Where D_{eq} . Is the steady state diameter of the pool in m V= liquid spill rate in m³/s Y= Liquid burning rate in m/s

In the absence of frictional resistance during spreading, the equilibrium diameter is reached over a time given by:

 $T_{eq} = 0.949 D_{eq} / (\Delta y X D_{eq})^{1/3}$

The visible flame height is given by;

 H_{flame} = 42D_p ((BvD/D_a(gD_p)1/2)^{0.61} Where H_{flame} = flame height in m D= density in kg/m³ D_a= air density in kg/m³ g = gravitational acceleration or 9.81 m/s² The emissive power of a large turbulent fire is a

The emissive power of a large turbulent fire is a function of the black body emissive power and the flame emissivity. The black body emissive power can be computed by Planck's law of radiation. The general equation used for the calculation is:

 $E_P = -0.313T_b + 117$

Where E_p is the effective emissive power in kw/m²

T_b= normal boiling point of the liquid in °F

Materials with a boiling point above 30 °F typically burn with sooty flames-the emissive power from the sooty section is about 20 kW $/m^2$. The incident flux at any given location is given by the equation:

 $Q_{incident} = EP * t * V_F$

Where, $Q_{incident}$ = incident flux in kw/m²

t= transmitivity (a function of path length, relative humidity and flame temperature) often taken as 1 and the attenuation of thermal flux due to atmospheric absorption ignored. V_F = geometric view factor

The view factor defines the fraction of the flame that is seen by a given observer.

V_F= 1.143 (R_p/X) 1.757

Where, X= distance from the flame center in m R_p = pool radius in m

Based on the radiation received, the fatality levels are calculated from Probit equation, which for protected clothing is given by:

Pr.= $-37.23 + 2.56 \ln (t X Q^{4/3})$ Where Pr. = Probit No. t= time in seconds Q heat radiation in w/m²

Thermal Hazard Due to Pool Fire

Thermal radiation due to pool fire may cause various degree of burn on human body and process equipment. The following table details the damage caused by various thermal radiation intensity.

Incident Radiation (kW/m²)	Type of Damage
0.7	Equivalent to Solar Radiation
1.6	No discomfort for long exposure
4.0	Sufficient to cause pain within 20 sec. Blistering of skin (first degree burns are likely)
9.5	Pain threshold reached after 8 sec. Second degree burns after 20 sec.
12.5	Minimum energy required for piloted ignition of wood, melting plastic tubing etc.
25	Minimum energy required to ignite wood at indefinitely long exposure
37.5	Sufficient to cause damage to process equipment

Table5: Effects due to incident radiation intensity

Table 6: Physiological Effects of Threshold Thermal Doses

Dose Threshold, KJ/M ²	Effect
375	3 rd Degree Burn
250	2 nd Degree Burn
125	1 st Degree Burn
65	Threshold of pain, no reddening/blistering of skin.

1st Degree Burn : Involve only epidermis, blister may occur; example - sun burn.
 2nd Degree Burn : Involve whole of epidermis over the area of burn plus some portion of dermis.
 3rd Degree Burn : Involve whole of epidermis and dermis; subcutaneous tissues may also be damaged.

Explosion may also occur due to release of natural gas through leakage. This will cause damage mainly to property.

Toxic Release

The aim of the toxic risk study is to determine whether the operators in the plant, people occupied buildings and the public are likely to be affected by toxic substances. Toxic gas cloud e.g. chlorine, etc was undertaken to determine the extent of the toxic hazard created as the result of loss of containment of a toxic substance.

Standard System for the Identification of the Hazards of Materials for Emergency Response" is a standard maintained by the **U.S.-based National Fire Protection Association**. "fire

diamond" used by emergency personnel to quickly and easily identify the risks posed by hazardous materials. The four divisions are typically color-coded with **red indicating flammability**, **blue indicating level of health hazard**, **yellow for chemical reactivity**, and **white containing codes for special hazards**. Each of health, flammability and reactivity is rated on a scale from 0 (no hazard) to 4 (severe risk).

The numeric values in the first column are designated in the standard by **"Degree of Hazard**" using numerals (0, 1, 2, 3, 4)

Physiological Response	Concentration equal to or greater than		
	ppm	mg/m ³	
Slight symptom after several hours.	1.0	3.0	
Odour detectable	3.0 - 3.5	9.0 - 10.0	
Maximum allowable for exposure of 0.5 to 1 hr.	4	12	
Least amount causing immediate irritation to throat.	10 - 15	30 - 45	
Cause coughing	30	87	
Dangerous in about 30 minutes	40 - 60	116 - 174	
Lethal concentration for 50% of population after 30 minutes exposure	500	1450	
Fatal in 30 min or less	1000	2900	
Fatal in 10 minutes	1800	5200	

Table 7: Physiological response to chlorine concentration

Table 8: Pasquill-Giffard Atmospheric Stability class

** Class D & F are considered for modelling Worst case scenario

Sr.	Stability	Weather Conditions					
No.	Class						
1.	А	Very unstable – sunny, light wind					
2.	A/B	Unstable - as with A only less sunny or more windy					
3.	В	Unstable - as with A/B only less sunny or more windy					
4.	B/C	Moderately unstable – moderate sunny and moderate wind					
5.	С	Moderately unstable – very windy / sunny or overcast / light wind					
6.	C/D	Moderate unstable – moderate sun and high wind					
7.	D	Neutral – little sun and high wind or overcast / windy night					
8.	Е	Moderately stable – less overcast and less windy night thand					
9.	F	Stable – night with moderate clouds and light / moderate wind					
10.	G	Very stable – possibly fog					

2.2 Selected Worst case Failure Cases for Consequence Analysis

Sl.No.	Failure Scenarios	Likely Consequences
LDO N	NFPA classification of Chemicals Nh= 1	
Nf= 2		
Nr= 0		
1.	25 and 50 mm leak in LDO storage Tank	Thermal radiation Flash Fire, Jet Fire, Pool Fire
2.	Catastrophic failure of LDO storage tank	Thermal radiation, Flash Fire, Pool Fire
Transfo	rmer Oil NFPA classification of Chemicals Nh=	= 1
Nf= 1		
Nr= 0		
3.	25 and 50 mm leak in Transformer Oil storage Tank	Thermal radiation Flash Fire, Jet Fire, Pool Fire
1	Catastrophic failure of Transformer Oil storage	Thermal radiation, Flash Fire,
4.	tank	Pool Fire
Hydrog	en NFPA classification of Chemicals	Nh=0
Nf=4		
		Nr= 0
5.	10mm leak in Hydrogen Cylinder	Thermal Radiation
6.	Catastrophic Rupture of Hydrogen Cylinder	Thermal Radiation
7.	10 mm leak in Hydrogen compressor	Thermal Radiation
8.	Catastrophic rupture in Hydrogen compressor	Thermal Radiation
Ammon	ia NFPA classification of Chemicals	Nh=3
Nf= 1		
Nr= 0		
9.	10mm leak in Ammonia storage tank for 300PPM IDLH condition	Thermal and Toxic Scenario
10.	Cat in Ammonia storage tank for 300PPM IDLH condition	Thermal and Toxic Scenario
Chlorin	e NFPA classification of Chemicals	Nh=4
Nf=0		
Nr= 0		
11.	5 mm leak in Chlorine Tonner for 10 PPM IDLH condition	Toxic Release
12.	5 mm leak in Chlorine Transfer Piping of 2" for 10 PPM IDLH condition	Toxic Release
13.	Line Rupture in Chlorine Transfer Piping 2" for 10PPM IDLH condition	Toxic Release

Table 9: Selected Worst Case Failure scenarios

2.3 Consequence Analysis Results

Consequence analysis was carried out for identified selected failure cases given in **Table no 9**. Damage distances for the accidental release of hazardous materials have been computed at 2F, 3D and 5D weather conditions. In these conditions, 2, 3 and 5 are wind velocities in m/s and F and D

are atmospheric stability classes. These weather conditions have been selected to accommodate worst case scenarios to get maximum effective distances. DNV based PHAST Micro 6.51 software has been used to carry out consequence analysis.

Consequence analysis quantifies vulnerable zones. For the selected accidental failure scenarios, after vulnerable zone is defined, measures to minimize damages caused.Results of the consequence analysis for the scenarios covered in this study are summarized in **Table no 10 to 14** given below. Major contributing Scenarios from Thermal Power Plant are given in **Fig. No. 1 to 15**below:

Scenario Considered	LFL	Leak Size	Weather	LFL
	Concentration (nnm)	(mm)		Distance (m)
LDO	8000	25	2F	11.50
			3D	7.55
			5D	4.64
		50	2F	17.55
			3D	10.39
			5D	9.02
		Catastroph	2F	161.74
		ic Rupture	3D	111.94
			5D	90.4
Transformer Oil	ner Oil 7000 25		2F	2.11
			3D	2.93
			5D	2.26
		50	2F	12.05
			3D	7.46
			5D	5.58
		Catastroph ic Rupture	2F	5.35
			3D	5.40
			5D	5.50
Hydrogen Cylinder	400000	10	2F	23.52
			3D	20.77
			5D	20.75
		Catastroph	2F	15.42
		ic Rupture	3D	16.65
			5D	19.29
Hydrogen compressor		10	2F	23.52

Table 10: Flash Fire Consequence Analysis

Scenario Considered	LFL Concentration (ppm)	Leak Size (mm)	Weather	LFL Distance (m)
			3D	20.72
			5D	20.75
		Catastroph	2F	17.12
		ic Rupture	3D	18.43
			5D	21.41
Ammonia	80000	10	2F	12.79
			3D	13.05
			5D	12.89
		Catastroph	2F	19.70
		ic Rupture	3D	24.08
			5D	28.59

 Table 11: Jet Fire Consequence Analysis

Scenario Considered Leak	Leak Size (mm)	Weather	Damage Distance (m) for Various Heat Loads		
			37.5 kW/m 2	12.5 kW/m ²	4.0 kW/m ²
LDO	25	2F	-	2.66	3.93
		3D	-	2.31	3.64
		5D	-	2.07	3.39
	50	2F	5.92	5.94	7.77
		3D	4.11	5.35	7.10
		5D	3.61	4.93	6.58
Transformer Oil	25	2F	-	-	2.01
		3D	-	-	1.94
		5D	-	-	1.84
	50	2F	-	3.15	4.65
		3D	-	2.97	4.26
		5D	-	2.78	3.99
Hydrogen Cylinder	10	2F		-	9.08
		3D	-	-	11.41
		5D	-	-	13.85

Scenario Considered Leak	Leak Size (mm)	Weather	Damage Distance (m) for Various Heat Loads		e (m) for Loads
			37.5 kW/m 2	12.5 kW/m ²	4.0 kW/m ²
Hydrogen compressor	10	2F	9.65	16.97	22.38
		3D	12.50	17.86	22.67
		5D	16.19	19.41	23.13
Ammonia	10	2F	-	40.96	49.51
		3D	-	37.87	45.87
		5D	-	34.3	41.81

Table 12: Fire ball Consequence Analysis

Scenario Considered Leak	Leak Size (mm)	Weather	Damag Vari	e Distance ous Heat I	Distance (m) for s Heat Loads									
			37.5 kW/m 2	12.5 kW/m ²	4.0 kW/m ²									
Hydrogen Cylinder	Catastrop hic rupture	2F	29.18	61.28	111.69									
		hic	hic	hic	hic	hic	hic	hic	hic	hic	3D	29.18	61.28	111.69
		5D	29.18	61.28	111.69									
Hydrogen	Catastrop	2F	31.86	67.04	122.19									
Compressor	hic rupture	3D	31.86	67.04	122.19									
		5D	31.83	67.04	122.19									

Table 13: Pool Fire Consequence Analysis

Scenario Considered	Leak Size	eakPoolWeatDamage Distance (m) forsizeRadiusherVarious Heat Loads		Damage Distan Various Hea		e (m) for Loads	
	(mm)	(m)	n) (m)		37.5 kW/m 2	12.5 kW/m ²	4.0 kW/m ²
LDO	25	16.67	2F	-	20.77	51.36	
				3D	-	22.35	57.59
			5D	-	23.68	61.65	
	50	33.32	2F	-	36.62	83.83	
			3D	-	36.91	93.30	
			5D	-	37.94	100.01	

Scenario Considered	Leak Size	Pool Radius (m)	Weat her	Damage Distance (m) for Various Heat Loads		
	(mm)			37.5 kW/m 2	12.5 kW/m ²	4.0 kW/m ²
Catastro phic Rupture	Catastro	348.33	2F	-	350.46	588.50
	phic Bupturo		3D	-	348.82	629.24
	Kupture		5D	-	349.34	669.3
Transformer Oil	25	17.50	2F	-	21.39	51.62
			3D	-	23.09	57.81
			5D	-	24.24	61.72
	50	30.15	2F	-	33.48	76.01
			3D	-	34.44	85.01
			5D	-	35.61	91.01s
	Catastro		2F	-	32.10	75.05
	phic Rupture		3D	-	33.18	84.54
	ĸupture		5D	-	34.54	90.92

Scenario Considered	IDLH (ppm)	Leak Size (mm)	Weather	IDLH Distance (m)
Chlorine Tonner	10	5	2F	2479.28
			3D	711.22
			5D	579.61
Chlorine Transfer	10	5	2F	231.6
Piping			3D	70.32
			5D	49.67
		Catastroph ic Rupture	2F	250.61
			3D	197.96
			5D	146.59
Ammonia	300	10	2F	171.001
			3D	147.98
			5D	133.48
		Catastroph	2F	120.94
		ic Rupture	3D	83.60
			5D	93.70

Table 14: Toxic release Consequence Analysis



Fig No. 1LDO_25 mm Leak Consequence Distance Graph for different wind stability class (2F,3D,5D)



Fig No. 2LDO_50mm Leak Consequence distance Graph for different wind stability class (2F,3D,5D)



Fig No. 3LDO_Catastrophic Failure Consequence distance Graph for different wind stability class (2F,3D,5D)



Fig No. 4Transformer Oil_25 mm Leak Consequence distance Graph for different wind stability class (2F, 3D, 5D)



Fig No. 5Transformer Oil_50 mm Leak Consequence distance Graph for different wind stability class (2F, 3D, 5D)



Fig No. 6Transformer Oil_ Catastrophic Rupture Consequence distance Graph for different wind speed (2F, 3D, 5D)



Fig No. 7Hydrogen cylinder leak_10mm for Consequence Distance Graph for different wind stability class (2F,3D,5D)



Fig No. 8Hydrogen cylinder_catastrophic rupture Consequence Distance Graph for different wind stability class (2F,3D,5D)



Fig No. 9Hydrogen compressor_10mm leak Consequence Distance Graph for different wind stability class (2F,3D,5D)



Fig No. 10Hydrogen compressor_catastrophic rupture Consequence Distance Graph for different wind stability class (2F,3D,5D)



Fig No. 11Chlorine Tonner_5 mm Leak Consequence Distance Graph for IDLH Condition at different windtability speed(2F,3D,5D)



Fig No. 12Chlorine Transfer Piping_5 mm Leak Consequence Graph for for IDLH Condition at different wind stabilityClass (2F,3D,5D)



Fig No. 13Chlorine Transfer Piping_ Line Rupture Consequence Graph for for IDLH Condition at different wind stability Class (2F,3D,5D)



Fig No. 14Ammonia_leak_10mm Consequence Graph for for IDLH Condition at different wind stability Class (2F,3D,5D)



Fig No. 15Ammonia_catastrophic Rupture for Consequence Graph for IDLH Condition at different wind stability Class (2F,3D,5D)

3.0 Risk Evaluation

Risk is quantified in terms of probability of occurrence of hazardous event and magnitude of its consequences. The consequence modelling was carried out in order to assess the extent of damage by visualizing accidental release scenarios for various process equipments. The risk to the human due to accidental release scenarios is represented in two ways viz. individual risk and societal risk. Individual risk associated with the various equipments of Khurja STPP has been evaluated by analysing various scenarios which are described in subsequent sections.

Individual Risk

The Individual Risk (IR) level is more specifically defined as the Individual Risk Per Annum (IRPA), which is the calculated annual risk loading to a specific individual or group of individuals. Clearly this depends on the amount of time in a year that the individual spends in different risk areas. The individual risk calculation takes account of the fact that people move from one place to another.

When calculating individual risk from major accident scenarios, it is normal to take account of protection by buildings. Individual risk is typically depicted as contour plots on overall plot plan of a facility, the risk level falls rapidly as one moves away from the source of the leak / epicentre of potential explosions.


Fig No. 16Commonly Acceptable Individual Risks in Different Designated Land Zones

Societal Risk

Societal risk is used in quantified risk assessment (QRA) studies and is depicted on a cumulative graph called an F/N curve. The horizontal axis is the number of potential fatalities, N. The vertical axis is the frequency per year that N or more potential fatalities could occur, F. This risk indicator is used by authorities as a measure for the social disruption in case of large accidents.

It is normal to take account of protection by buildings, and people's response. For large toxic release models, alarm and evacuation can be included. Because it is a cumulative curve, the curve always drops away with increasing N. Normally the F/N curve has a lower frequency cut-off at one in a billion $(1 \times 10^{-9} / \text{yr})$. Regulators often split the graph into different regions, so that different actions have to be undertaken depending on where the F/N curve falls. Sometimes a maximum limit is placed on N (number of fatalities) possible for any event.

This type of curve is normal for plant type hazardous installations where a large group of people could be affected and their location is well established (housing estates, schools etc) relative to the event location (the plant). For pipelines however, because there is no single location for an event and the population affected varies along the pipeline route, this curve is not normally generated unless a large group of people can be affected over a reasonable distance.

United Kingdom (Risk Acceptability criteria)

In the UK the "Control of Major Accident Hazards" (COMAH) regulations are in line with the latest EU "Seveso-2" Directive. The regulations do not formally require a quantitative risk assessment, but the guidance notes make clear that in some circumstances quantification will help or could be asked for by the UK regulator - the Health and Safety Executive (HSE) - and this is often done in practice.

To advise planning authorities on developments around industrial installations, the UK HSE has been developing risk acceptance criteria over the years. A comprehensive treatment of the subject of tolerability of risk was given in a report titled "Reducing Risks Protecting People". The report repeated the concept and criteria as argued by the Royal Society in 1983. It accepted the concept of tolerable Individual Risk as being the dividing line between what is just tolerable and intolerable and set the upper tolerable limit for workforce fatalities at 10^{-3} /yr (1 in a thousand) for workers and 10^{-4} /yr (1 in 10 thousand) for members of the public. A level at which risks might be broadly acceptable but not altogether negligible was set at 10^{-6} /yr (1 in a million). The region in between would be controlled by the ALARP concept.

ALARP can be demonstrated in a variety of ways, depending on the severity of the worst case scenario. These are expressed in HSE guidance to Inspectors Consultation Draft September 2002.



Fig No. 17:United Kingdom Societal Risk Guidelines (risk to workforce and public)

4.0 Results and Discussion

Above consequence modelling results shows that Impact Distances are well within Limits. Appropriate safety measures to control any hazardous situation will be installed to prevent loss of Life and Properties.**Fire fighting facilities and measures to control toxic release scenario will be installed onsite.**

Risk Level estimated for Proposed THDC Ltd are given below in **Table No15** and **Fig No 18**. Results are well within limit set by HSE,U.K and are in the acceptable zone.**Hence the proposed Project No threat to Life and Loss of Property.**

Sl No.	Risk type	Results	HSE U.K Acceptance criteria
1.	Individual Risk	8.274x 10 ⁻⁶ /yr	Upper tolerable limit for workforce fatalities at 10^{-3} /yr (1 in a thousand) for workers and 10^{-4} /yr (1 in
2.	Societal Risk	1.234x 10 ⁻⁵ /yr	10 thousand) for members of the public.

Tabla	4 .	Taria	malaaaa	Camaaa		A
i anie	15	LOXIC	release	Consea	mence	Anaivsis
IUDIC	101	I OMIC	reicube	Gonged	uciice.	maryono





Risk Level Vs No of Fatalities Graph for THDC Ltd

5.0 General Mitigation Measures

- Fire is one of the major hazards, which can result from auxiliary fuel (LDO &Transformer Oil) storage tanks. The fire service facility shall be equipped with:
 - Smoke and fire detection alarm system
 - Water supply
 - Fire hydrant and nozzle installation
 - Foam system
 - Water fog and sprinkler system
 - Mobile Firefighting equipment
 - First aid appliances
- Smoke and fire detection, fire hydrant & nozzle installation etc. as indicated above shall be included as part of all major units at the proposed project.
- Periodic maintenance of all protective and safety equipment.
- Wind socks/wind cock should be installed at suitable height and with proper visibility to check the prevailing wind direction at the time of accident.

- Periodical training/awareness would be given to work force at the project as refresher courses to handle any emergency situation.
- Periodic mock drills should be conducted so as to check the alertness and efficiency of the Disaster Management Plan (DMP) and corresponding records should be maintained.
- Signboards including emergency phone numbers and no smoking signs should be installed at all appropriate locations.
- Plant would have adequate communication system.
- All major units/equipment shall be provided with smoke/fire detection and alarm system.
- All electrical equipments shall be provided with proper earthing. Earthed electrode shall be periodically tested and maintained.
- Emergency lighting shall be available at all critical locations including the operator's room to carry out safe shut down of the plant, ready identification of fire fighting facilities such as fire water pumps, fire alarm stations, etc.
- In addition to normal lighting each installation shall be equipped with emergency (AC) and critical (DC) lighting.
- All electrical equipments shall be free from carbon dust, oil deposits, grease, etc.
- Cable routing shall be planned away from heat sources, gas, water, oil, drain piping, air conditioning ducts, etc.
- Cable route markers shall be provided in the permanent way at the location of changes in the direction of cables and at cable joint locations.
- Chlorine detectors and Chlorine arresting kits would be provided at relevant locations.
- There would be necessary provision for emergency stop of critical equipments from control room in the event of major leak/flash fire at Plant.
- Clearly defined escape routes would be developed for the Station taking into account the impairment of escape by hazardous releases and sign boards be erected in places to guide personnel in case of an emergency.
- Well defined assembly point in safe locations would be identified for personnel in case of an emergency.
- Windsocks visible from all direction would be provided. This will assist people to escape in upwind or cross wind direction from flammable releases.
- There should be an SOP established for clarity of actions to be taken in case of fire/leak emergency.

6.0 Project Specific Mitigation Measures

Chlorine Tonners

For chlorine tonners following control/containment measures are recommended.

- Auto chlorine leak absorption system would be provided to absorb the leaked chorine from the tonners/system.
- To prevent the large release of chlorine to atmosphere, monitoring and feedback facilities for early detection leaks and emergency shutdown shall be provided.
- There should be facilities in the form of water curtain for absorption of chlorine released during an emergency as chlorine is highly soluble in water.
- Flow control values at key points would be installed to prevent excess chlorine flow from the tonner with multiple level safety per line.
- Provision for immediate evacuation of all personnel in case of accidental release of chlorine.
- Eye wash stations and emergency shower stations should be provided at appropriate locations especially in the vicinity of Chlorine storage and dosing facilities
- The stand by chlorine tonners shall be kept/stored at isolated covered warehouse at safe distance. It shall be provided with sufficient high (about 6 m) roof ventilation, chlorine detection and water spray system inside storage facility
- Conduct awareness programmes on regular basis in order to educate villagers around the project about the consequences of possible health hazards and their precautionary measures during accidental conditions

Auxiliary Fuel System

- Protective systems with high reliability and availability should be designed to ensure that physical conditions are maintained
- Dyke would be provided for LDO storage tanks
- Co-ordination with local authorities such as fire, police, ambulance, district administration & nearby industries to manage/control any eventuality
- To prevent the hazard of static electricity, the fill and recirculation lines to the storage tanks shall be discharged below the liquid level.
- The following arrangements are suggested for LDO/HFO storage tanks:
 - One independent high level alarm and trip off liquid inlet-line.
 - One low level alarm with trip off device.
 - Provision of auto deluge water sprinkler system for each bulk storage tank. The auto deluge water sprinkler would be set to start working at a temperature of 66°C.

- The ST turbine building, switchyard, transformer yard, administrative building canteen, first aid center, fire stations etc. shall be located safely, if viewed in the light of worst accident scenarios.
- In case of any tank on fire or fire in the vicinity, the cooling of adjoining tank should be resorted promptly in addition to tank on fire so that neighboring tanks does not give away.
- The night vision wind stocking be mounted on top of administrative building, main plant building and storage tanks so that people can move in upwind directions in the event of massive spillage or tank on fire.
- No machinery of vital importance like fire fighting pump house, Hydrant and Fuel oil pump house shall be placed out of radiation contours of 37.5 kW/m² heat intensity.
 - Maintenance plays a vital role in proper upkeep of plant. One important function is the monitoring of equipment health, pipelines and machines. Adoption of system like thickness survey (including supports) maintenance practices will improve plant performance and safety.

ENCLOSURE-5

Greenbelt Development Plan

1.1 **Objectives**

Objectives of the proposed green belt are as follows:

- Mitigation of air pollution due to fugitive emissions;
- Attenuation of noise generated from operation of different machines;
- Improvement of bio-diversity of the area; and
- Improvement of aesthetics of the site.

The main air pollutants likely to be generated from the proposed project are

- Particulate matter,
- Fugitive emission,
- Sulphur dioxide, and
- Nitrogen oxides.

1.2 Species for green belt

1.2.1 General Characteristics

The greenbelt would be designed in three tier system. The three tier system will be followed so that it could provide complete canopy coverage from ground flora up to top canopy and could provide considerable attenuation for noise and pollution impact. First inner rows will be facing the plant, where flowering shrubs and herbs shall be planted in 5 m width.Small trees shall be planted in the middle rows in 10m width, followed by taller trees in the last few rows. Adequate space shall be kept between the trees, small trees. Since the project site falls under agro-climatic zone namely Upper Gangetic Plains, the selection of plant species for greenbelt development was based on "Guidelines for Developing Green Belts, PROBES/75/1999-2000"for differenent purposes are as follows

For absorption of gases:

- Tolerance towards pollutants in question,
- Longer duration of foliage,
- Freely exposed foliage, through
 - Adequate height of crown,
 - Openness of foliage in canopy
 - ▶ Big leaves with long and broad laminar surfaces,
 - Large number of stomatal apertures
 - Well exposed stomata

For removal of suspended particulate matter:

- Height and spread of crown,
- Leaves supported on firm petioles,
- Abundance of surface on bark and foliage, through
 - ➢ Roughness of bark,
 - > Epidermal outgrowth on petioles,
 - Abundance of axiliary hairs,
 - ➢ Hairs or scales on laminar surfaces, and
 - Protected stomata.

In view of the fact that atmosphere in industrial areas constitute more than one pollutant, the guideline advices to choose plant species for green belt development, which are capable of absorption of chemicals as well as particulate matter pollutants.

For plantation along road sides:

Vehicles are ground level mobile sources of gaseous and particulate matter pollutants. Species selected for plantation along road sides shall therefore be capable of absorption of gaseous as well as particulte matter pollutants. For green belt development along road sides, the CPCB Guideline recommends plantation of shrubs of height 1 to 1.5 m and trees of 3 to 5 m height. The intermixing of trees and shrubs should be such that the foliage area density in vertical is almost uniform.

1.2.2 Agro-climatic zone

The proposed site is located within Bulandshar District in Uttar Pradesh. As per agro-climatic zones of India (CPCB Guidelines), the site falls within 'Upper Gangetic Plains', and sub-zone "North Western Plains, with Dry Sub Humid to Semi Arid climate.

1.2.3 Selection of Species

The selection of species for the proposed green belt is based on the recommendations under the CPCB guidelines for the applicable agro-climatic sub-zone. While selecting the species from the recommended list, quick growing species with longer duration of foliage and tolerant to air pollution have been preferred. With these considerations, the following species have been selected for plantation within the green belt and along the roads.

S. N.	Species	Ht.	Family	Local	Habit	Growth	Sensitive/
	•	(m)	U U	Name			Tolerant
							(To air
							pollution)
1	Adina cordifolia	05-20	Rubiaceae	Haldu	Tree	Slow	Tolerant
1.						growing	
n	Aegle marmelos	12-15	Rutaceae	Bel	Tree	Slow	Tolerant
Ζ.	(Linn)					growing	
2	Ailanthus	20-22	Simaroubaceae	Mahanimb	Tree	Quick	Tolerant
з.	excelsaRoxb.					growing	
4	Albiziachinensis	12-16	Mimosaceae	Chakua	Tree	Quick	Tolerant
4.	(Osbeck) Merrill.					growing	
5	Albizia lebbeck Benth	12-16	Mimosaceae	SafedSiris	Tree	Quick	Tolerant
Ј.						growing	
6	Alstonia scholaris	12-15	Apocynaceae	Saptparni	Tree	Quick	Tolerant
0.						growing	
7	Anogeissus latifolia	20-25	Combretaceae	Dhaura	Tree	Slow	Tolerant
7.	Wall.					growing	
Q	Anthocephalus	25-30	Rubiaceae	Kadamb	Tree	Quick	Tolerant
0.	<i>chinensis</i> (Lamk)					growing	
	Azadirachta indica A.	12-15	Meliaceae	Neem	Tree	Quick	Tolerant
0	Juss.					growth	
9.						after first	
						season	
10	Bischofia javanica	25-30	Phyllanthaceae	Paniala	Tree	Quick	Tolerant
10.	Blume					growing	
11	Bridelia squamosa	15-18	Euphorbiaceae	Khaja	Tree	Quick	Tolerant
11.	Lamk.					growing	
12	<i>Cassia fistula</i> Linn.	12-14	Caesalpiniaceae	Amaltas	Tree	Quick	Tolerant
12.						growing	
13	Cassia siamea	10-12	Caesalpiniaceae	Kassod	Tree	Fast	Tolerant
15.						growing	
14	Casuarina	05-10	Casuarinaceae	Janglisaru	Tree	Quick	Tolerant
17.	equisetifolia					growing	
15	Dalbergia	25-30	Fabaceae	Sitsal	Tree	Quick	Tolerant
15.	<i>latifolia</i> Roxb.					growing	
	Dalbergia	25-28	Fabaceae	Sissoo	Tree	Quick	Tolerant
16	<i>sissoo</i> Roxb.					growth	
10.						after first	
						season	
17	Drypetes roxburghii	05-15	Putranjivaceae	Putijia	Tree	Slow	Tolerant
					ļ	growing	
18	Ficus benghalensis	05-20	Moraceae	Bar	Tree	Quick	Tolerant
10.	Linn.				ļ	growing	
	Ficus elastica	05-12	Moraceae	Indian	Tree	Quick	Tolerant
19.				Rubber		growing	
				Tree			

Table - 1: List of trees proposed for Greenbelt development

20	Ficus glomerata	05-15	Moraceae	Gular	Tree	Quick	Tolerant
20.						growing	
21	Ficus hispida	05-10	Moraceae	Umber	Tree	Quick	Tolerant
21.						growing	
	Ficus virens	05-10	Moraceae	Pilkhan	Tree	Quick	Tolerant
22						growth	
22.						after first	
						season	
22	Jacaranda	05-12	Bignoniaceae	NeeliGulmo	Tree	Quick	Sensitive
23.	mimosifalia			har		growing	
24	Lagerstroemia	05-25	Lythraceae	Phurush	Tree	Quick	Tolerant
24.	parviflora					growing	
25	Madhuca longifolia	05-15	Sapotaceae	Mahua	Tree	Quick	Tolerant
25.						growing	
26	Mangifera indica	10-18	Anacardiaceae	Aam	Tree	Quick	sensitive
20.						growing	

Table - 2: List of proposed small trees species

S.	Species	Family	Local	Habit	Growth	Sensitive/
No.			Name			Tolerant (To air
						pollution)
1	Annona squamosa	Anonaceae Linn.	Sharifa	Small	Quick	Tolerant
1.	Linn.			tree	growing	
2	Bauhinia racemosa	Caesalpiniaceae	Banraj/Kat	Small	Quick	Tolerant
Ζ.	Lamk.		mauli	tree	growing	
2	Callistemon citrinus	Myrtaceae	Lemon	Small	Slow	Tolerant
5.	(Curtis)		Bottle brush	tree	growing	
4	Citrus aurantium	Rutaceae	Nimbu	Small	Quick	Tolerant
4.	Linn			tree	growing	
5	Psidium guajava	Myrtaceae	Amrood	Small	Quick	Tolerant
5.				tree	growing	

S.	Species	Family	Local Name	Habit	Growth	Sensitive/
No.						Tolerant
						(10 air
1	Bauhinia acuminate Linn.	Caesalpiniaceae	Kanchan	Shrub	Quick	Tolerant
					growing	
2	Bougainvillea spectabilis	Nyctaginaceae	Bougainvillea	Shrub	Quick	Tolerant
2		Determine	Devesture		growing	The large set
3	<i>Citrus limon</i> (Linn)	Rutaceae	Bara nimbu	Shrub	Quick	Tolerant
4	CrowiggubingggugligDC	Tiliagono	Dhalaa	Chruh	Quick	Tolorant
4	GrewiasubinaequalisbC.	Thaceae	Pliaisa	Sinub	QUICK	Tolerant
5	Hibiscus rosa-sinonsist inn	Malwaceae	Gudhal	Shruh	Quick	Tolerant
5	moiscus rosu-smensisLinn	Maivaceae	Guullai	Sinub	growing	TOTETAIL
6	Ixora chinensis	Rubiaceae	Chinese	Shruh	Ouick	Tolerant
Ŭ	ixor a chinensis	Rublaceae	Ginnese	Sinub	growing	Tolerane
			Ixora		8.08	
7	Lawsonia inermis	Lythraceae	Mehandi	Shrub	Quick	Tolerant
		5			growing	
8	Murraya paniculata	Rutaceae	Marchula	Shrub	Quick	Tolerant
					growing	
9	Nerium indicum	Apocynaceae	Kaner	Shrub	Quick	Tolerant
					growing	
10	Nyctanthes arbor-tristis	Oleaceae	Harsingar	Shrub	Quick	Tolerant
					growing	
11	Poinciana pulcherrima	Caesalpiniaceae	Guletura	Shrub	Quick	Tolerant
					growing	-
12	Sesbania sesban	Fabaceae	Jainti	Shrub	Quick	Tolerant
10	<i>m</i> 1				growing	m 1 .
13	I abernaemontana	Apocynaceae	Chandhi	Shrub	QUICK	Tolerant
14	aivaricata Theyetia normujana	Anogunagoas	Dilakanan	Chauk	growing	Tolorant
14	Thevella peruviana	Аросупасеае	глакапег	SIIruD	QUICK	rolerant
14		Apocynaceae	Fliakanei	SIII UD	growing	TUIETAIIt

Table - 3: List of proposed shrub species

1.3 Plantation programme

Dy. Manager (Environment), under control of Dy. General Manager (Environment), will be responsible for development and maintenance of green belt. The greenbelt development program shall be started with the start of construction activities, i.e., immediately after the project is accorded environmental and other statutory clearances, and will be completed within 4 years.

The activities at the initial stage (First two years) will consist of the following.

- 1. Appointment of expert/consultant for preparing a detailed plan in consultation with local Forest Department authorities
- 2. Identification of locations for plantation of saplings of different species

- 3. Survey of the area for plantation of trees and preparation of detailed map
- 4. Development of nursery and greenhouse for species to be planted
- 5. Digging of trenches, pits, protective fencing and soil conditioning with organic manure
- 6. Planting of saplings and sowing of seeds (during monsoon season)
- 7. Surveillance, maintenance and irrigation of the saplings to achieve a targeted survival rate of more than 80%.

The work plan for the second stage is as follows:

- 1. Avenue plantation along internal and approach roads
- 2. Maintenance and irrigation of species planted earlier
- 3. Survey of the area to identify the locations for re-plantation of saplings
- 4. Plantation of saplings at the identified locations
- 5. Development of lawns and gardens with ornamental trees in vacant areas around the administrative building
- 6. Maintenance and irrigation to achieve a targeted survival rate (90%) of the planted species.

The work plan for the third stage is as follows:

- 1. Maintenance and irrigation of species planted earlier
- 2. Identification of any remaining area within premises for afforestation and plantation of saplings at identified locations
- 3. Development of lawns and gardens in vacant areas within the premises
- 4. Maintenance and irrigation to achieve the targeted survival rate (95%) of the planted species.

The work plan for the subsequent years comprises

- 1. Irrigation and maintenance of saplings/trees on routine basis
- 2. Routine soil conditioning with organic manure
- 3. Cleaning of afforested areas to remove weed species (unwanted species)
- 4. Cleaning and maintenance of greenbelt and other plantation areas
- 5. Replacement of dead species with new ones.
- 1.4 Financial Provision

Financial provisions for the proposed green belt development and forestation plan are as follows:

Table - 4: Capital Expenditure on green belt development

S. N.	Particulars	Amount, Rs.
1	Fees of experts/consultants for detailed work planning	10,00,000
2	Trenching, conditioning, manuring of soil and protective fencing @ Rs 40,000/ per hectare	70,00,000
3	Plantation of trees, shrub, Herbs and grasses during 1 st year @ Rs 40,000 per hectare	70,00,000

4	Plantation of trees, shrub, Herbs and grasses during 2 nd year @ Rs 35,000 per hectare	61,25,000
5	Plantation of trees shrub, Herbs and grasses during 3 rd year @ Rs25,000 per hectare	43,75,000
	Total	2,55,00,000

Table - 5: Revenue Expenditure (Annual) on Green Belt Development

Sl. No.	Particulars	Amount, Rs.
1	Salaries of regular employees	80,00,000
2	Contract workers, 20 persons @ Rs300/- per day	21,90,000
3	Contingency and unforeseen expenses	1,43,10,000
	Total	2,45,00,000

Table - 6: List of trees and their medicinal uses proposed for Greenbelt development

S. No.	Species	Local Name	Medicinal Uses			
			Part of Plant	Uses		
1.	Adina cordifolia	Haldu	Bark	Dysentery, bacterial infections on the skin, cholera, cold and cough, fever and eczema		
			Leaf	Infertility, headache, Scars and skin yellowish of body		
			Latex	Toothache		
2.	Aegle marmelos	Bel	Ripe fruit	Dyspepsia, bacillary dysentery		
			Roots and Bark	Fever		
			Leaf	Inflammation, asthma, hypoglycemia, hepatitis etc.		
3.	Ailanthus excelsa	Mahanimb	Bark	Fever, labor pain		
			Leaf	Labor pain		
4.	Albizia chinensis	Chakua	Seeds	Anti-inflammation		
			Bark	Asthma, leucoderma, itching, skin disease, piles, excessive perspiration, inflammation, bronchitis, toothache, leprosy, deafness and strengthens the gums and teeth		
5.	Albizia lebbeck	SafedSiris	Leaf	Bites and stings from venomous animals, ear pain and coughing		
			Bark	Blood purification.		

			Seeds	Diarrhoea and Dysentery
6.	Alstonia scholaris	Saptparni	Bark	Dysentery and fever, skin disorders, malarial fever, chronic dysentery, diarrhoea, and in snake bite
7.	Anogeissus latifolia	Dhaura	Bark	Diarrhoea, cough, liver diseases, snakebite and skin diseases
			Gum	Tonic and generally consumed after delivery of child.
			Leaf	Purulent discharges from the ear
			Fruit	Cough and biliousness
8.	Anthocephalus chinensis	Kadamb	Leaf	Hydrocoele and in Pyorrhea, ulcers and wounds, stomatitis
			Bark	Eye diseases
			Fruit	Gastric irritability
9.	Azadirachta indica.	Neem	Leaf	Leprosy, intestinal helminthiasis, respiratory disorders, constipation, rheumatism, chronic syphilitic sores and ulcer
			Flower	Bile suppression, elimination of intestinal worms and phlegm
			Fruit	Piles, intestinal worms, urinary disorder, phlegm, eye problem, diabetes, wounds and leprosy
			Bark	Analgesic and antipyretic
10.	Bischofia javanica	Paniala	Leaf	Treatment of sores, tonsillitis and throat pain, diphtheria
			Stem Bark	Stimulate hair growth, diarrhoea and dysentery
			Ground Bark	Abortion
11.	Bridelia squamosa	Khaja	Bark	Cough, fever and asthma and as gargle for sores in mouth
			Leaf	Jaundice; emulsion for anaemia due to pregnancy.
			Roots	Inflammation, an astringent, anti- diarrhoea
			Fruit	Induce vomiting and as an antitoxic
12.	Cassia fistula	Amaltas	Seeds	Mild laxative
			Leaf	Insect bites, swelling, rheumatism and facial paralysis
			Roots	Tonic, an astringent, febrifuge and strong purgative, migraine and dysentery
13.	Cassia siamea	Kassod	Roots	Conjunctivitis
			Leaf and Flower	Indigestion and as expectorant
			Leaf	Heartburn and as antipyretic

			Seeds	Intestinal worms and used as antidote for snake and scorpion bites
14.	Casuarina equisetifolia	Junglisaru	Leaf	Diarrhoea, dysentery, headache, fever, cough, ulcers and toothache
			Seeds	Anthelmintic, antispasmodic and antidiabetic
15.	Dalbergia latifolia	Sitsal	Roots	Ulcers, leprosy, Oedema, brain tonic (memory enhancers)
			Bark	Leprosy, obesity and worm diseases etc.
16.	Dalbergia sissoo	Shisham	Leaf	Gonorrhoea
			Roots	Astringent
			Wood	Leprosy and to allay vomiting
17.	Drypetes roxburghii	Putijia	Leaf and Fruits	Rheumatism
18.	Ficus benghalensis	Bargad	Bark	Dysentery, diarrhoea, leucorrhoea, nervous disorders and reduces blood sugar in diabetes
			Leaf	Leaf extract is applied externally to abscesses and wounds to promote suppuration.
			Aerial Roots	Pimples, leucorrhoea and osteomalacia
			Twigs	Strengthen gums and teeth
			Latex	Rheumatism, haemorrhoids, gonorrhea, cracks of the sole and skin diseases
19.	Ficus elastica	Indian Rubber	Leaf	Skin infections and skin allergies
		Tree	Latex	To treat disease caused by roundworms and tapeworms
20.	Ficus glomerata	Gular	Bark	Diabetes, bronchitis, dry cough, dysentery, diarrhoea etc.
			Leaf	Diarrhoea, dyspepsia, haemorrhages and obesity
			Fruit	Leprosy, blood diseases, fatigue, leucoderma etc.
21.	Ficus hispida	Umber	Fruit	Coolant and tonic
			Roots and Leaves	Diarrhoea
22.	Ficus virens	Pilkhan	Leaf	Intrinsic haemorrhage, erysipelas and wound healing
			Bark	Dysentery and menorrhagia
23.	Jacaranda mimosifalia	NeeliGulmoha r	Bark	Syphilis
24.	Lagerstroemia	Phurush	Leaf	Diabetes mellitus

	parviflora		Roots	Mouth ulcers
			Bark	Febrifuge, and for relief of abdominal pains
25.	Madhuca longifolia	Mahua	Bark	Leprosy and wounds
			Flower	Cough,biliousness and heart- trouble.
			Fruit	Blood diseases
26.	Mangifera indica	Aam	Roots and Bark	Anti-syphilitic, anti-inflammatory, leucorrhoea, wounds, ulcers and vomiting.
			Leaf	Cough, hiccup, burning sensation, hemorrhages, diarrhoea and dysentery
			Flower	Anorexia, dyspepsia, diarrhoea and aneamiaetc
			Ripe Fruit	Anorexia, dyspepsia, cardiopathy, haemorrhages from uterus, lungs and intestine and aneamia.
			Unripe Fruit	Dysentery ophthalmia, and urethrorrhagia