

7.1 Risk Assessment

This section aims to summarize the results of the safety studies carried out to identify hazards in the scope of the project and impact of potential major hazards associated with the project. The major safety studies, carried out include Hazard Identification (HAZID), Desktop Process Safety Review (Shell acronym DSR), Quantitative Risk Assessment Study (QRA) and also the framework for the Emergency Response Plan (ERP), to deal with any emergency or disaster which may affect the facility and its surroundings. This framework will be developed into a detailed plan prior to commissioning of the project facilities.

Risk assessment is the process of estimating the likelihood of an occurrence of specific consequences (undesirable events) of a given severity. Risk analysis is proven as a valuable management tool in assessing the overall safety performance in industry. Although management systems such as engineering codes, checklists, and reviews by experienced engineers have provided substantial safety assurances, major incidents involving numerous causalities, injuries and significant damage can occur-as illustrated by recent world-scale catastrophes. The underlying basis of risk analysis is simple in concept. It offers methods to answer the following five questions:

- What can go wrong? (Hazard identification)
- What are the causes? (man –mode, natural)
- What are the consequences? (consequence Analysis)
- How often? And (TRIF,IRPA,LSR)
- What is the significance of the resulting risk? (Risk matrix/severity)

The following sections of risk assessment study provide answer to the above including quantification of the risks to rank them based on their severity. The resulting report can be used to understand the significance of control measures and to follow the measures continuously.

7.1.1 Past Accidents Analysis - LNG Marine Transport and Handling

In general LNG has been very safely handled for many years. However, the industry is not without its incidents and accidents, but it maintains an enviable “modern-day ” safety record. The process of natural gas liquefaction, storage and vaporization is not a new technology. In 1939, the first commercial LNG peak-shaving plant was built in West Virginia. There are over 120 peaks shaving and LNG storage

facilities worldwide, some operating since the mid- 1960s. In addition, there are 18 base-load liquefaction (LNG export) facilities in various countries including Abu Dhabi, Algeria, Australia, Brunei, Egypt, Indonesia, Libya, Malaysia, Oman, Nigeria, Qatar, Trinidad and U.S. (Alaska). LNG is transported by a fleet of LNG tankers of varying sizes from 18,500 m³ to 265,000 m³. This fleet of LNG ships delivers to receiving terminals in the Belgium, Dominican Republic, France, Greece, Italy, Japan, Korea, Spain, Taiwan, Turkey, U.K., India, U.S.A and other countries.

The LNG storage tanks at these facilities are constructed of an interior cryogenic wall, usually made of 9% nickel steel, aluminium or other cryogenic alloy. The outside wall is usually made of carbon steel or reinforced concrete. A thick layer of an insulating material such as Perlite separates the two walls.

With a few exceptions, LNG handling facilities have revealed an exceptionally superior safety record when compared to refineries and other petrochemical plants. With the exception of the 1944 “Cleveland Disaster”, all LNG-related injuries and/or fatalities, however devastating, have been limited to plant . There have been no LNG shipboard deaths. There has not been a member of the public injured by an incident involving LNG since the failure of the improperly constructed Cleveland facility. Small LNG vapour releases and minor fires have also been reported, but impact was limited to the plant and the hazard was promptly handled by plant personnel. Other accidents have occurred during the construction and repair of LNG facilities. Some of these accidents have been used to tarnish the exceptional safety record of LNG, but as no LNG was directly involved in the incident these accidents can only truly be called “construction” accidents. Damage has always been limited to the plant property.

7.1.2 Safety Record of LNG Ships

The first transportation of LNG by ship took place early in 1959 when the Methane Pioneer (an ex-Liberty ship that had been extensively modified) carried 5,000 M³ (cubic meters) of LNG from Lake Charles, Louisiana to Canvey Island, near London, England. Commercial transportation of LNG by ship began in 1964 when LNG was transported from Arzew, Algeria to Canvey Island in two purpose-built ships the Methane Princess and the Methane Progress. Since then the LNG tank ship fleet has delivered more than 30,000 shiploads of LNG, and travelled more than 100 million kilometres while loaded (and a similar distance on ballast voyages).

The overall safety record compiled by LNG ships during the past five decades has been remarkably good.



Risk Assessment

In all of these voyages and associated cargo transfer operations (loading/unloading), no fatality has ever been recorded for a member of any LNG ship's crew or member of the general public as a result of hazardous incidents in which the LNG was involved. In fact, there is no record of any fire occurring on the deck or in the cargo hold or cargo tanks of any operating LNG ship.

Among LNG import and export terminal personnel, only one death can be even remotely linked to the loading or unloading of LNG ships. (In 1977, a worker in the LNG Export Facility at Arzew was killed during a ship-loading operation when a large-diameter valve ruptured and the worker was sprayed with LNG. His death was the result of contact with the very cold LNG liquid; the spilled LNG did not ignite.

Table 7.1.1 summarizes the safety history of LNG ships in last 5 decades (Ref.: CH-IV International - Safety History of International LNG operations, web site: <http://www.ch-iv.com/AboutUs.html>). It summarizes as "Although a major effort was made to ensure the record presented is complete, it is possible that some incidents have been missed. However, it is very unlikely that a major incident has been omitted. Firstly, nearly every shipping incident that results in an insurance claim will be published in "Lloyd's List". Secondly, even if the ship owners are self-insured, news of major incidents travels quickly through the LNG industry because it is composed of a relatively small number of ship and terminal operators that often share experiences through industry associations such as SIGTTO (Society of International Gas Tanker. & Terminal Operators)".

LNG is cryogenic; it is in liquid form; and its vapours are flammable. It is not without its safety concerns – it, however, can be produced, liquefied, transported and re-vaporized as safely, and in most cases, more safely, than other liquid energy resources.

7.1.3 Hazard Identification (HAZID)

A hazard is an undesired event, which may cause harm to people or to the environment or damage to the property. A comprehensive Hazards Identification study for individual facilities at proposed project has been carried out by an interdisciplinary team of experts, who were drawn from different departments, viz. Design, Engineering, Projects, Environment, Operations, safety etc. and by conducting a Hazard Identification (HAZID) workshop. During the workshop the following main hazards were identified:

A) Tropical storms and cyclones

Kakinada Port area is prone to severe climate extremes. Severe Tropical storms and cyclones have occurred. Extreme weather conditions e.g. lightning, cyclones, high winds and heavy rainfall may result in damage to the moorings, hampering evacuation via stand by vessel, cause injuries such as slips, trips of personnel and/or equipment damage.

B) Tsunami

Fatalities and damage to the storage tanks on LNG Cargo ship, FSRU or pipeline infrastructure induced by Tsunami.

C) Accidental LNG Spill

Accidental LNG spill due to a cryogenic hose rupture, cold breakthrough followed by Low Temperature (LT) embitterment on FSRU & Island Jetty.

D) Effect of the Facility on the Surroundings – Proximity to Population

The FSRU will be located approximately 2.0 km away from the shore. There are local settlements close to the port, metering station and fishing activities happen in the proximity of FSRU location. In case of major incidents /releases it could potentially impact population.

E) Medical Evacuation from FSRU

There might be situations, where a crew member from the FSRU needs to be brought to shore for medical attention. Considering that the FSRU is approximate 2.5 km from shore, and a medical evacuation scenario can happen at any point of time i.e. during day or night or periods of poor light.

F) HSSE Issues related to Sub-Sea Pipeline

The HAZID was performed based on a structured brain storming session using an appropriate list of guidewords. The facilities were split into small sub systems (“Nodes”) to facilitate brainstorming. The hazards associated with each element were reviewed by the HAZID participants. Following were the major nodes for discussion:

- LNGC
- FSRU
- Jetty

Risk Assessment

- ORF
- Subsea Pipeline

The workshop participants brainstormed all potential hazards and identified the associated consequences. The planned controls were analyzed for their adequacy and recommendations as control measures were established as necessary. Action Party was appointed for effective close-out of each action item. The workshop discussions have been summarized and recorded on HAZID Study Worksheets. An outline of the basic HAZID process is provided in the following **Fig.7.1.1**.

7.1.3.1 Risk Matrix

The risk level was assessed taking into account the existing controls/ design intent that are in place or has been put in plan. For the purpose of this HAZID study, the agreed Risk Matrix (RM) is used to categorize the hazards as shown in **Table 7.1.2**.

The RM shown is a 5 by 5 matrix that categorize hazards and their threats into:

- Health & Safety
- Natural Environment
- Social/Cultural Heritage
- Community/ Government / Reputation/ Media
- Legal
- Financial

The horizontal axis of the matrix represents Consequence (the effect / result in the event that the failure mode occurs) and the vertical axis represents increasing Probability/Likelihood (the probability / frequency of occurrence). The boxes inside the matrix represent levels of risk, increasing from bottom left to top right corners.

The risk levels are categorized into four levels, which are:

- Low
- Medium
- High Risk
- Very High Risk

7.1.3.2 HAZID Results

A total of 58 action items were identified during the HAZID session, where 8 were identified for High Risk, 37 for Medium Risk, 1 for Low Risk and 12 action items not ranked as there are no sufficient details at this stage. The actions items are listed in **Table 7.1.3**.

Once a hazard has been identified, it is necessary to evaluate it in terms of the risk it presents to the employees and the neighbouring community. In principle, both probability and consequences should be considered, but there are occasions wherein it either the probability or the consequence can be shown to be sufficiently low or sufficiently high and decisions can be made on just one factor.

7.1.4 HAZOP - Desktop Process Safety Review (DSR)

DSR is a modified HAZOP (Hazard and Operability Review) study. The DSR is a line-by-line review of the P&ID by a multiple-discipline team under the lead of an experienced facilitator. In Shell, the facilitator for DSR requires the competencies of facilitation skill and also technical safety expertise. The methodology of the DSR is almost the same as HAZOP in that the deviations (Guidewords-Parameter combinations) from the design and operation intents are identified, the causes and consequences related to the deviations are established, and existing safeguards are examined and recommendations are made if the existing safeguards do not reduce the hazard to the risk acceptable to the company.

There two subtle differences between the DSR and HAZOP as follows:

- (i) DSR takes advantage of the experience and technical safety expertise of the facilitator, and allows the facilitator the flexibility to skip or minimize the discussion for the guideword-parameter combinations that the facilitator doesn't see significant safety implication. Operability issues those do not have the potential to lead to safety concerns are also skipped. This allows much stronger focus on safety related scenarios. The time saved is used for more in-depth discussion and analysis of the major hazardous scenarios identified in the review to ensure there are sufficient and robust safeguards present, and also used for coming up with robust recommendations.
- (ii) Unlike HAZOP that documents discussions for every Guideword-Parameter combination, DSR only documents exceptions or gaps unless full documentation is specifically requested. Documentation for only gaps works well for processes that Shell has already had significant operational experiences so that most of the hazards

have been understood and operating procedures and manuals have covered the hazards and precautions needed.

The objective of a DSR is to assess the hazard potential of mal-operation or malfunction of individual items of equipment and the consequent effects on the facility as a whole. This is done via the application of a systematic critical examination of the design intents of the equipment, in order to identify potentially hazardous deviations from the design intents.

The DSR technique is a systematic, line-by-line review of the latest Process Engineering Flow Schemes (PEFS) with respect to all technical safety and operability¹ aspects (including equipment fire protection), until every piece of equipment within the scope of the study has been reviewed. This is to ensure that the plant will handle all foreseeable operating conditions, including maintenance, start-up and shut-down (both normal and emergency), in a safe, healthy and reliable manner, with minimum environmental impact. To facilitate progress, reviewed systems will be marked in an easily identified color on the PEFS studied by the team leader.

The review includes:

- Identification of possible deviations from the actual design intent
- Identification of possible causes for deviations and determination of the consequences
- Identification of deviations from Shell design practices, guidelines and recommendations on technical HSE, fire safety and operability issues² (see also)
- Evaluation of the impact of the consequences on the technical and fire safety and operability) of the plant and its interconnected facilities² and on the environment.

Recommendations for design changes are made by the team.

The team leader is the catalyst for maintaining a structured discussion, challenging existing practices or design parameters where considered necessary, to ensure a thorough review of the facility.

¹Operability aspects in this context include those features of equipment, tanks, piping, valves, spades, instruments, etc., that allow the installation to be operated in a safe and healthy way by trained personnel, and that provide adaptability to the installation to different operating modes (including start-up, shut-down, upsets, venting and draining of equipment, etc.) with minimum impact on environment and on personnel and equipment safety. Not primarily related to reliability and on-stream time.

² Review of the interfaces with other installations, to ensure that the safety and environmental integrity of both new and interconnected plants is not violated by the interconnections. This includes Utility Systems, where impact on existing facilities must be assessed with respect to capacity, reliability, safety and environment.

Risk Assessment

As part of the FEED Phase, a Desktop Process Safety Review (DSR) was carried out to identify the Process Safety risks. The scope of the DSR was to review the integrated facilities starting at the FSRU after the LNG inlet block valve until the onshore 600# pipeline (of 3.6 km) to grid connection.

Key outcomes of the DSR are summarized below:

- Apply the High Pressure Natural Gas (HP NG) arm automated depressurisation options as proposed and provide means for operational depressurisation as well
- Assure FSRU Instrumented Protection System (IPS) meets the Safety Integrity Level (SIL) requirements
- Provide proper document on the function of the riser Emergency Shutdown (ESD) Valve and procedure
- Install a double block valve to allow a tie-in of future FSRU while in operation
- Develop the sequence of events when ship-shore link fails
- Replace the motor operated valve by an Emergency Shutdown (ESD) valve for the onshore isolation of the subsea line
- Convert the onshore isolation Motor Operated Valves (MOV) to ESD valve
- The ESD valve will close automatically after a timer delay upon detection of Fire & Gas (F&G) confirmed by voting system
- Consider to route Thermal Relief Valve (TRV) to the cargo tanks via the safety header to prevent liquid reliefs to the Knock Out Drum (KOD)
- For the High Pressure (HP) pump implement backflow protection as per Shell Design Engineering Practice (DEP) 80.45.10.11.
- Ensure that the cold temperature breakthrough safeguarding requirements as set by the send out system connected to the ship are consistent with the safeguarding functionality provided in the re-gasification unit;
- The vent header has a low point before the KOD, which requires a means to detect of liquids building up in the header and provide a timely alarm to the operator; and
- Asses the vent capacity using Flare Instrumented Protection Function (IPF) in order to determine the required SIL for the individual vaporiser trips.

7.1.5 Quantitative Risk Assessment (QRA)

The Quantitative Risk Assessment (QRA) study is primarily concerned with the identification and evaluation of quantified accidental events associated with the proposed operations, which have potential to cause major incident and is defined as:

- A fire and explosion due to the release of LNG resulting from accidental loss of containment from LNG carrier or unloading facility which could result in death or serious personal injury to people and damage of property/infrastructure within the facility; and
- Risks associated include uncontrolled release and subsequent fire due to accidental loss of containment of natural gas after regasification in the regasification unit, transport pipeline and/or metering skid.

The project design is for Floating Storage Regasification Units (FSRU) to take LNG from a carrier, regasify it and send it to shore for metering and distribution. The QRA covers the risks associated with the FSRU design, island jetty, the pipeline and the onshore facility.

The assessment involves Floating Storage and Regasification Units (FSRU) moored at the Island Jetty with LNG carriers periodically stationed alongside FSRU for loading operations.

The QRA aims to identify the major threats to life and to quantify them as risks expressed in terms of:

TRIF: Temporary Refuge Impairment Frequency (per annum) - the annual frequency with which the Temporary Refuge will be impaired within one hour from hydrocarbon release events

IRPA: Individual Risk Per Annum - the annual probability of fatality of an individual member of an employment category

LSR: The location specific risk (LSR) refers to the annual risk of fatality to a hypothetical individual at a location for 24 hours per day, 365 days per year, unprotected and unable to escape. LSR is usually represented on a map in terms of contours.

The objective of a QRA is to perform an evaluation of the proposed design of the installation to cope with the credible accidents which could occur during normal operations through a risk assessment regarding the expected frequencies and the consequences of the possible hazardous events. The specific objectives of the risk assessment studies are to:

Risk Assessment

- Identify the hazards associated with the FSRU and associated facilities and equipment;
- Model and appraise the risks associated with all flammable and toxic hazards resulting from potential loss of containment accident scenarios;
- Identify onsite and offsite risks posed by the facility and its associated operations to obtain and document satisfactory safety; and
- Perform a risk assessment to confirm that risk can be reduced consistent with the 'As Low As Reasonably Practicable' (ALARP) Principle.

The elements of the risk assessment study consist of the following steps:

- Data collection and review
- Hazard Identification including external hazards
- Consequence Analysis
- Frequency Analysis
- Risk Analysis and conclusion.

Data collection and information reviewed included the following:

- Details on Island Jetty & unloading facility
- FSRU design and operating conditions
- Subsea pipeline details
- Gas metering skid design and operation details; and
- Inventory and material properties.

Past incidents and relevant studies worldwide on similar LNG carriers, subsea pipelines and metering skids were also reviewed for the Risk Analysis.

The approach for risk analysis comprises of ascertaining the large consequence to help the decision making process on the safeguarding and design aspects for the proposed project. The frequency of releases from equipment has been determined by review of project related information and application of generic frequency data.

The release frequencies to be used are formed from the following sources:

Process Releases: This is based on the OIR12 data, which has been gathered from all reported incidents in the North Sea, in the period since 1992. The latest data that will be included is that for the year 2010/2011.

Pipeline Releases: Data is taken from the International Association of Oil & Gas Producers (OGP) Risk Assessment Directory Data (434-4). The recommended failure frequencies for

Risk Assessment

subsea ‘processed oil or gas’ pipelines of >24 inch diameter in open sea were used. The failure frequency was increased by a factor of two to account for shallow water.

Note: It is recognised that some LNG specific failure rate databases are available, but in QRA Consultant’s opinion, the available data is limited, with relatively small populations and hence these data sources are not used for the FSRU project. The failure frequencies by process equipment items are given in the **Table 7.1.4**.

7.1.5.1 LNG Transfer Hose Failures

The failure data for transfer hose is taken from Dutch LNG QRA guidance, a leak is taken as 10% of loading hose diameter;

Rupture of hose = 4×10^{-7} /hr of operation (assumed to be equivalent to 150mm release)

Leak from hose = 4×10^{-6} /hr of operation (assumed to be equivalent to 22mm release)

Note that releases from the loading hose system will still be modelled using the 4 possible release sizes since the loading hose system also includes fittings / instruments etc. in addition to the hose itself. Therefore, the release frequency associated with the hoses above will only be assigned to the 22mm and 150mm release sizes but the associated fittings frequency will be spread over the 4 release sizes.

Loading Arms

The most suitable data on offloading arm failure frequency is given in the Failure Frequency report by the UK HSE. This gives a frequency of accident frequency per cargo transferred as shown below for a full bore rupture and a ‘hole’.

Scenario	Failure frequency per transfer operation	
	FBR (Full Bore Rupture)	Hole
Total failure for 1 loading arm	7E-06	8E-06
Total failure for 2 loading arms	1.3E-05	1.6E-05

The failure frequency within the ‘hole’ category in the table above is split between the representative release sizes of 22mm, 70mm and 150mm based on the distribution for Steel Piping D>11”.

7.1.5.2 Release Outcome Frequencies

QRA Consultant's standard methodology has been used for calculating the ignition probabilities for accidental releases within the process facilities. This study has shown that, for a given scenario, the ignition probability varies with the mass flow rate, and that this relationship can be represented by a relatively simple correlation. 'Look-up' tables or correlations for a range of representative scenarios have been developed to provide an easy to use reference for ignition probabilities for use in QRA. These tables / correlations are supported by guidance on how to select a suitable representative scenario, interpret and apply the data, consider sensitivities etc.

For the FSRU facility, the following correlations have been used for process related events:

Sections	Correlation	Release Type	Description
LNG Carrier, FSRU, Jetty	21: Offshore Process Gas Large Module	Gas release from large offshore process module	Releases of flammable gases, vapour or liquids significantly above their normal (NAP) boiling point from within large offshore process modules or decks on integrated deck / conventional installations (module greater than 1000m ² floor area). (Process modules include separation, compression, pumps, condensate handling, power generation, etc).
Riser / Pipeline	23: Offshore Riser for 7mm, 22mm, 70mm	Gas Release from typical offshore riser in air gap	Releases from offshore installation risers in the air gap area where there is little chance of a release entering process areas on the installation (e.g. solid deck, wind walls). Applies to partial flashing oil or gas releases.
Riser / Pipeline	27: Offshore Engulf – blowout – riser for 150mm/Full Bore (FB)	Gas Release from typical offshore riser in air gap	Releases from drilling or well working blowouts or riser failure where the release could engulf the entire installation and reach into platform areas applies to partial flashing oil or gas releases.


Risk Assessment

Onshore Facilities	5: Small Plant Gas LPG	Gas or LPG release from small onshore plant	Releases of flammable gases, vapour or liquids significantly above their normal (NAP) boiling point from small onshore plants (plant area up to 1200 m ² , site area up to 35,000 m ²)
--------------------	------------------------	---	---

Correlation – Process related events (Offshore & Onshore Ignition Scenarios) –

Source: OGP 434, 6.1)

The relationship between outflow rate and ignition probability for each of these correlations is shown below:



Relation b/w outflow rate & ignition probability

The frequencies of all possible outcomes which may result from a hydrocarbon leak have been determined using the event tree as shown in below:

7.1.6 Consequence Analysis

The consequences resulting from accidental release of LNG and Natural Gas are assessed by employing standard consequence analysis tools and simulation software and modelled using empirical and integral models. As example, liquid releases would form a liquid pool while ignition of the pool could result in a pool fire, which would continue till the liquid is completely burnt. Liquid releases can also vapourise on exit and form jets, which is more likely for small LNG releases. The LNG release can also lead to vaporisation of large quantity due to sudden increase of temperature. This may lead to flash fire or even vapour cloud explosion (VCE). Natural gas release can result in jet fire or a VCE.

The consequences of each failure scenario have been modelled using Shell FRED software. This includes models for calculating discharge rates, dispersion of flammable gases, liquid spread and vaporization, radiation effects from fires (jet fires, pool fires, flash

fires BLEVE, VCE). The result of the consequence analysis is a hazard footprint for each accident scenario which is used to determine the level of harm to personnel and level of damage to equipment. The release consequences may be due to external or internal reasons leading to safety failure as described in the section on hazard identification.

7.1.6.1 Release sizes

For consequence assessment purposes a limited number of breach sizes have been assumed to represent typical breaches of containment, i.e. 150 mm, 70 mm, 22 mm and 7mm. These representative breach sizes have been chosen based on experience from previous QRA work. The hole size ranges represented by indicative breach diameters of 7mm, 22mm, 70mm and 150mm are given in the table below:

Hole Sizes

Indicative (mm)	Hole Size Range (mm)
Not modelled	≤ 3mm
7	3 – 10
22	10 – 50
70	50 – 100
150	100+

Small leaks with an equivalent hole size diameter smaller than 3mm are assumed to be controlled and therefore do not result in a risk of fatality or risk of significant escalation. As such, releases of 3mm or less will not be considered in the risk assessment. The hole size range has been correlated with the OIR12 database that will form the basis for the frequency evaluation for process releases.

7.1.6.2 Process parameter inputs

The project comprises of four main components which are LNG Carriers, FSRU with maximum capacity for about 217,000 m³, Island Jetty and Onshore facilities i.e. Natural Gas (NG) metering station, transferring pipeline and utilities.

The LNG carrier will be berthed alongside the FSRU and LNG will be pumped out from ship using submerged cryogenic pumps and sent to FSRU storage tanks through 8

Risk Assessment

cryogenic flexible hoses. Some of the vapour displaced during the FSRU filling operation will be sent back to the LNG carrier via 2 cryogenic flexible hoses.

The maximum offloading rate from the LNG carrier is 8,000m³/hr, which would mean 21.25 hours for evacuating 170,000 m³ LNG Cargo and 27.25 hours for evacuating 217,000 m³ LNG Cargo of maximum capacity of continuous offloading to fill the storage tanks from empty. The frequency of offloading is expected to be 41 – 66 times per year. It is assumed that the tanks are not completely empty before each offload and therefore a representative offloading time of 24 hours, 66 times per year (roughly once every 5 days) is used in the QRA.

The FSRU shall be designed, constructed and equipped to:

- Receive LNG from a standard LNG carrier and store liquefied natural gas (LNG) at a minimum temperature of –161°C at near atmospheric pressure
- Convert the LNG to NG using regasification units located on the forward deck of the installation and to transfer the resulting high pressure NG to the shore installation
- The installation shall manage the handling of the natural boil off gas from the LNG cargo loaded by the most efficient means e.g. Dual fuel power generation systems, combustion in a Gas Combustion Unit (GCU), Minimum Send out Compressor or recirculation to recondenser / suction drum;

The regasification system is likely to include one common skid mounted suction drum (recondenser) and three identical skid mounted regasification units arranged for parallel send out. Low pressure LNG from recondenser is pressurised by high-pressure, high capacity cryogenic pumps and sent to vaporisers. LNG is vaporised by an open loop sea water system.

At the vaporiser outlet, gas is sent to a fiscal metering system (Ultrasonic meters) at the FSRU battery limit with the gas pipeline running back along the port side of the vessel prior to the metering skid before crossing to the send out platform via standard loading arms. There will be a single steel riser departing from the send out area of the Island Jetty, joining a NG pipeline to shore.

Onshore the Natural Gas (NG) flow will be again measured by using a metering skid.

There will be two operating modes:

- Ship to ship transfer (STS) operation including unloading from LNGC;

Risk Assessment

- Transfer of NG via high pressure sendout arm to subsea pipeline.

The throughput limits are as follows:

- NG nominal Send out Capacity is 500 mmscfd
- NG Send out Minimum (turndown) Capacity is 25 mmscfd

LNG Storage will involve the use of four membrane tanks giving a total capacity of approximately 217,000m³ per FSRU.

The export gas riser and gas export line operates at a pressure of 81 bar.

The LNG composition assumed is (all values in mole %): 96.01% C1, 3.2% C2, 0.6% C3, 0.05% i-C4, 0.05% n-C4, 0.01% i-C5, and 0.08% N2.

Data on maximum credible loss scenarios provided by SPV for modeling of the different release cases are provided in **Table 7.7** together with release frequencies which have been derived from generic data on loss of containment events referring a number of sources.

7.1.6.3 Atmospheric Stability

The fire effects were calculated for three representative weather conditions:

- F2 (2m/s wind speed, stable weather conditions);
- D2 (2m/s wind speed, neutral weather conditions);
- D5 (5m/s wind speed, neutral weather conditions).

The split between the three weather conditions (F2, D2 and D5) modelled for the QRA analysis is given in the table below;

Split for weather conditions in QRA

	Calm	Wind Direction												Total
		341-10	11-40	41-70	71-100	101-130	131-160	161-190	191-220	221-250	251-280	281-310	311-340	
F2	23.276	0.856	0.249	2.235	1.625	0.351	1.091	1.462	1.888	5.366	0.845	0.303	1.699	41.247
D2	10.075	0.544	0.433	6.300	4.610	1.742	4.981	2.425	3.527	15.433	2.571	0.769	1.231	54.640
D5	0.000	0.031	0.021	1.136	0.318	0.091	0.256	0.066	0.122	1.602	0.305	0.128	0.035	4.113

This split is based on the rule-set described below:

Risk Assessment

- Stability class F is assumed to represent the stability classes E, F and G – total probability 41.2%
- Stability class D is assumed to represent the stability classes A to D – total probability 58.8%
- F2 – 41.2% - the total probability of stability class F as calculated above
- D2 – 54.7% - the probability of wind speeds \leq 6 knots for stability class D as calculated above
- D5 – 4.1% - the probability of wind speeds $>$ 6 knots for stability class D as calculated above

The base case weather data above was used in this QRA and was taken from the weather station located in Kakinada centre (i.e. onshore).

7.1.6.4 Consequence Modeling

The fire scenarios modelled are

- Jet fires – these are a result of high momentum releases of flammable gas or flashing liquid which reach an ignition source and present a risk to personnel due to thermal radiation effects;
- Pool fires – stabilised liquid releases are considered to form a pool fire if ignited and present a risk to personnel due to thermal radiation effects;
- Flash fires – flash fires involve the release and dispersion of flammable gas (or flashing LNG) to form a flammable gas cloud in a relatively open and un-congested area, followed by subsequent ignition.

7.1.6.5 Jet Fires

The following correlation was used for jet fire scenarios:

$$L = a \times Q^b$$

Where L, is the flame length (m)

Q, is the mass flow rate (kg/s)

a, b, are flame coefficients and are 12.5 and 0.4 respectively

7.1.6.6 Pool Fires

Pool fire effects are calculated using standard physical equations provided below to model the spread of flammable liquid on the deck and using FRED to determine the radiation effects.

Using the outflow rates the maximum pool size is determined (note that the maximum size is restricted to an upper limit which is defined as the deck area of the module in which the release occurs – in the case of releases on FSRU Trunk deck, this was limited to half of the deck width due to the deck camber).

$$d = 2 \left[\frac{Q}{\pi = 2} \right]^{1/2}$$

where d , is the diameter (m);

Q , is the LNG release rate (kgs^{-1});

m , is the LNG burning flux ($\text{kgm}^{-2}\text{s}^{-1}$) (taken from FRED).

Note that Equation 3.2 from the Shell FRED manual was used to calculate the LNG burn rate. The equation above was then calibrated against the results from FRED.

The methodology assumes that if the liquid release is from a large inventory, and therefore of long duration, the fire spreads (ideally to form a circular fire) until the mass burning rate is equivalent to the release rate from the vessel.

Once the diameter of a fire is determined, the height of the flames is found by using Thomas' correlation (which is also referenced within FRED):

$$H/d = 42[m/(\rho^a \sqrt{gd})]^{0.61}$$

where H , is the flame height (m);

d , is the pool fire diameter (m);

m , is the mass burning rate ($\text{kg/m}^2\text{s}$);

ρ^a , is the ambient air density (kg/m^3);

g , is the gravitational constant (m/s^2).

Again, the burn rate and calculations came directly from FRED. Although this correlation neglects wind speed, it conservatively calculates the maximum flame height.

Once the diameter and flame height of a fire were determined, the radiation levels were determined within FRED.

7.1.6.7 Fire Results

For each of the failure cases listed in the following table, results are presented for a range of hole sizes (7mm, 22mm, 70mm and 150mm) and for cases where the safety systems, i.e. Emergency Shutdown (ESD) and Blowdown, operate as intended and for the case when they fail to work. Hazard distances are presented for the flame contour and to radiation levels of 37.5kW/m², 20.0kW/m², 12.5kW/m² and 6.3kW/m². The fire sizes are provided for 7 time steps i.e. t = 0 minutes, t = 5 minute, t = 10 minutes, t = 15 minutes, t = 20 minutes, t = 30 minutes and t = 60 minutes.

Failure Cases Considered in the QRA

QRA ID	Failure Case ID	Phase	Description	Location
1	001-L-01	L	LNGC Offloading Header	Main Deck
2	002-L-01	L	Transfer Hoses – Liquid	Loading Hoses
3	002-L-02	L	LNG Cargo Liquid Header (transfer from LNGC to FSRU)	Main Deck
4	002-L-03	L	Cargo Tank Filling Lines	Main Deck
5	002-L-04	L	LNG Feed Header	Main Deck
6	002-L-05	L	Recondenser Feed Line from LNG Feed Header (Inlet 1 – Top Inlet)	Heating Medium
7	002-L-06	L	Recondenser Feed Line from LNG Feed Header (Inlet 2 – Bottom Inlet)	Heating Medium
8	002-L-07	L	Recondenser Liquid Release	Heating Medium
9	002-L-08	L	LNG Cargo Liquid Header (transfer from FSRU to small carriers)	Main Deck
10	002-G-01	G	Recondenser - Gas Side Inlet	Heating Medium
11	002-G-02	G	Regasification Skids Gas Outlet	Regas
12	002-G-03	G	HP NG Sendout	Main Deck
13	002-G-04	G	HP Gas Sendout Arms	Sendout Arms
14	002-G-05	G	NG Sendout Platform	Island Jetty

QRA ID	Failure Case ID	Phase	Description	Location
15	002-G-06	G	NG Riser/Subsea Pipeline	Island Jetty
16	002-G-07	G	Vapour Return from Other Carriers (cargo discharge operation)	Loading Hoses
17	002-G-08	G	Vapour Return from FSRU Cargo Tanks (cargo loading operation)	Loading Hoses
18	002-G-09	G	MSO Skid	Main Deck
19	002-G-10	G	NG Return Line	Loading Hoses
20	003-G-01	G	Onshore Gas Metering Facility	Onshore
21	002-G-11	G	Transfer Hoses – Vapour	Loading Hoses
22	002-L-09	L	HP Booster Pumps – Outlet	Heating Medium
23	M1	L	Machinery Space Fire	Engine Room

The jet fire results demonstrate the potential benefits of safety systems working as intended. The jet fire extent and fire durations are significantly lower when both isolation and blowdown systems are working compared with either one or both of these systems fail to work. This may also reduce the potential for escalation to other equipment and structures.

7.1.6.8 Cryogenic Pools

The pool size generated for fire scenarios was used as the hazardous extent of cryogenic pools in terms of the QRA fatality ruleset. This may be a slightly simplistic approach given the possibility of different release geometry and release inventories. However, while the actual hazardous range of the cryogenic release may be larger in some scenarios, this allows the QRA to account for the various possible releases in a robust manner.

7.1.6.8.1 Cryogenic Jet

DNV PHAST 6.7 software was used to generate the hazard distances for cryogenic jets. The hazardous extent of cryogenic jets was estimated using the vulnerability rule-set described below;

- Extent of cryogenic liquid jets or 2-phase jets with liquid fraction greater than 1%

Risk Assessment

- Extent of vapour jets until the jet temperature decays from exit temperature to above - 50°C.

7.1.6.8.2 Escalation Rule sets

The following rulesets are applied within the consequence analysis to determine the credible escalation paths.

They are based on empirical evidence from historical accidents, as well as full scale tests performed by the Steel Construction Institute, as reported through the Fire and Blast Information Group (FABIG). These typically represent the failure times for process equipment and structures on the FSRU, jetty and onshore facilities i.e. not the FSRU hull.

7.1.6.8.3 Pool Fire

- An unprotected primary structure or vessel with design pressure greater than 30bar (regasification and sendout equipment) will fail within 20 minutes when subject to direct impingement from a pool fire. It is assumed that this also applies to the island jetty structure.
- An unprotected pressurised hydrocarbon inventory with a design pressure less than 30bar (all other process equipment) will fail within 10 minutes when subject to direct impingement from a pool fire.

7.1.6.8.4 Jet Fire

- An unprotected primary structure or vessel with design pressure greater than 30bar (regasification and sendout equipment) will fail within 10 minutes when subject to direct impingement from a jet fire. It is assumed that this also applies to the island jetty structure.
- An unprotected pressurised hydrocarbon inventory with a design pressure less than 30bar (all other process equipment) will fail within 5 minutes when subject to direct impingement from a jet fire.

7.1.6.9 Passive Fire Protection (PFP)

Where PFP is fitted, escalation will not occur unless the duration of the fire exceeds the capacity of the PFP. The failure times shown in the table below are assumed for load bearing walls, structures or vessels. Those highlighted in **bold** are defined as the design criteria for that PFP rating. Those that are in faint are assumed, based on the results of large scale testing of PFP.

Assumed Failure Times (minutes) for Protected Items

PFP Type	Jet Fire	Pool Fire
A0 (steel plate)	10	10
A60	15	30
H60	30	60
H120	60	120
J60	60	120
J120	120	>120

In reality, the FSRU, jetty and onshore facilities are not extensively provided with PFP. In terms of the FSRU accommodation, the front bulkhead is A60 rated and therefore expected to fail within 15 mins of jet fire impingement or 30 minutes of pool fire impingement. However, there is a water deluge drenching system provided for the front face of the accommodation. This is not considered to be particularly effective against jet fires due to their momentum driven nature. However, water deluge can be effective against pool fires and for the purposes of this study, it is assumed to double the failure time to 60 minutes for pool fires if initiated.

The front face of Cargo tank 1 has 2 bulkheads, one of which is provided with chartek coating. There is also a cofferdam between the regasification area and the cargo tank as well as the barrier surrounding the regasification to protect equipment against wave action during periods where the FSRU must sail away. Therefore, it is considered reasonable to assume that escalation to the cargo tank will not take place within an hour.

The potential failure time of the FSRU hull is difficult to determine without specific, detailed structural analysis. This is due to the presence of different barriers:

- Outer steel plate;
- Water ballast tanks. Note that flame impingement may also occur above the of these tanks.
- Insulation layer for cargo tanks;
- Inner steel plate.

Some experimental data has been provided for cargo tanks. These indicate a potential failure time of 29 minutes from a LNG pool fire on the sea surface. This 29 minutes indicates the potential time to failure of the insulation layer of the cargo containment system from a heat flux of 300kW/m². The analysis also indicates that there would be minimal heat up of the cargo until the insulation was fully degraded i.e. the damage would be limited to the outer barriers of the cargo containment system and there would be no loss of cargo until after this time. It is worth noting that damage to the outer steel plate of the hull could occur within around 5 minutes according to the analysis.

Jet fire impingement may have a higher heat flux than the value indicated above and also has an erosive nature since jet fires are momentum driven. Based on this, and for the purposes of the QRA, it is assumed that a jet fire impinging on the FSRU hull (e.g. from the high pressure gas riser on the island jetty) will cause some form of failure of the hull within 30 minutes i.e. similar to H60 rating. This failure scenario is assumed to result in an orderly evacuation of the FSRU by Totally Enclosed Motor Propelled Survival Craft (TEMPSC) but not catastrophic failure of the cargo containment system. Note that some damage to the outer barrier of the hull would still occur before this time. If necessary, detailed structural analysis can be conducted by the project to determine a more realistic failure time.

7.1.6.10 Explosions

The following escalation rulesets are used for explosion overpressures:

Process Equipment

Leading to Flange Breach (Judged to be 50mm release): 0.5bar

Leading to 150mm Damage: > 0.75bar

Leading to Catastrophic Damage: 1bar

TR (including windows) and TEMPSC

Zero damage: < 100mbar

100% damage: >100mbar

Note that the blast resistance of the Temporary Refuge (TR) on the FSRU is unknown but this level (100mbar) of resistance is expected to be readily achievable. This is also assumed to be the case for the windows overlooking the process plant. While household windows have been known to suffer some damage at 20mbar and glass injury at around 50mbar, it is expected that the windows on the accommodation module will be significantly stronger since they should be designed for possible wave action during seagoing operations.

7.1.6.11 Cryogenic

References as part of the QRA study have identified exposure times for structural steel to LNG prior to embrittlement and potential failure. This suggests that structural steel can fail in less than 1 minute when exposed to cryogenic liquid jets. Therefore, the following rulesets are used to determine the vulnerability of assets to cryogenic spills.

- Unignited releases pose a cryogenic threat to adjacent structures / equipment if they are exposed to vapour releases at -40°C or lower for more than 20 minutes.
- Unignited releases pose a cryogenic threat to adjacent structures / equipment if they are exposed to liquid droplets or a liquid stream -40°C or lower for 1 minute or more.

This is also assumed to apply to the front face of the accommodation module. Note that there is a deluge drenching system for the front face of the accommodation module that can be activated via operator intervention upon detection. This is assumed to be possible in approximately 1 minute. Therefore, it is assumed that the drenching system will be effective against cryogenic vapour releases since they take 20 minutes to impairment. However, the drenching system is assumed to be ineffective against cryogenic liquid releases since damage could occur within 1 minute.

7.1.7 Risk Calculations

In the QRA, the predicted level of risk has been calculated for four different categories of fatalities that could occur following a hydrocarbon release. Each is discussed in more detail below.

7.1.7.1 Immediate Fatalities

The personnel exposed to fire and explosion are generally considered to be those located in the incident area at the time of release / ignition. However this is not always the case. Immediate fatalities may occur in adjacent areas if the release is particularly large. The actual number of fatalities is based on a rule set regarding the size and type of event. The calculations take account of the expected average number of persons in the incident area at any time.

For jet fires and pool fires, the immediate fatality levels were calculated using the rule sets derived from the Eisenberg probit modified by Lees. The rule set used to estimate the vulnerability to thermal radiation is as follows.

Vulnerability to Thermal Radiation

Thermal Radiation Range		Probability of Fatality
Minimum	Maximum	
37.5 kW/m ²		1.00
20.0 kW/m ²	37.5 kW/m ²	0.90
12.5 kW/m ²	20.0 kW/m ²	0.30
6.3 kW/m ²	12.5 kW/m ²	0.03

For each release, the representative fire sizes were compared to module areas to determine the effects on the initiating module and adjacent areas. Immediate fatality levels were calculated using a simple rule set that suggests for personnel in average clothing, there would be 50% fatalities amongst a group that were exposed to 37.5 kW/m² for 22 seconds.

Within this analysis, it is applied more conservatively here in that it is assumed that all personnel within the 37.5 kW/m² heat contour are immediate fatalities.

For flash fires, the probability of fatality is:

- Within the LFL contour: P(Fatality) = 100%
- Outside of the LFL contour: P(Fatality) = 0%

This is applicable also to explosions since the overpressures are expected to be low and therefore personnel are more at risk from the flash fire aspects of the event.

The following rulesets are used for cryogenic releases:

- Any person exposed to a liquid cryogenic release will become an immediate fatality with 100% probability.
- It is possible, that breathing vapours at extremely low temperatures, would lead to cold burns to the lungs which may lead to fatalities. There is no clear industry guidance on this, but the cold temperatures needed to cause fatality would be close to the cryogenic liquid spills themselves.

7.1.7.2 Muster Fatalities

Muster fatalities are defined as those fatalities resulting from personnel being unable to muster because the escape ways back to the TR are impaired and conditions on the FSRU

are life-threatening. The probability of muster being impaired is assessed on an event-by-event basis. The calculation of muster fatalities requires the following steps:

- Calculate the conditions and probability of impairment of the escape routes;
- Calculate a fatality fraction assuming the route is impaired.

The fatality fraction for personnel who are unable to return to the TR due to the escape routes being impaired has then been calculated. This takes into account the possibility of trapped personnel evacuating the installation by tertiary methods, e.g. liferafts, or through directly entering the sea. Fatalities that arise from personnel who are prevented from mustering, but who evacuate the platform via tertiary means are still classed as muster fatalities. An average muster fatality fraction of 0.25 is used, similar to that used for TR fatalities.

The muster fatalities have been calculated for each end event for each breach size using the following formula:

$$\text{Muster fatality} = \text{Frequency of end event} \times [\text{number of personnel on plant - immediate fatalities}] \times \text{Probability of escape route impairment} \times \text{muster fatality factor}$$

7.1.7.3 Post Muster Fatality Event Tree

If the TR maintains its integrity no further fatalities are assumed to occur. However, if the TR is impaired through a first mechanism, say direct thermal impairment, then the possibility of evacuation is considered.

Before calculating the risks associated with TR and Escapet Evacuation Rescue (EER) impairment it is necessary to identify the potential mechanisms by which the TR can be impaired.

7.1.7.4 TR Fatalities

These fatalities occur as a result of the TR and the TEMPSC being coincidentally impaired such that personnel become fatalities within the TR. These include fatalities that result due to the escalation of initial releases to other inventories.

Only when the incident has been assessed and a serious threat to the TR is identified, will an attempt be made to evacuate the facility. If the TEMPSC are unavailable when the evacuation is instigated, historical data suggested that a high level of fatalities

would ensue. This is based on a number of factors, the most important being that whilst the interior of the TR is still habitable, personnel will be very reluctant to exit the TR into an atmosphere of smoke and fire. Under such circumstances, the majority of personnel would become fatalities inside the TR by failing to make any escape. The personnel that do manage to make some form of escape will then encounter further hazards such as the height of the installation and the time taken to recover personnel from the water. A fatality fraction of 90% of personnel is often used for this outcome.

Note that although there are liferafts in addition to the TEMPSC, it is considered likely that they will also be impaired by the event that has impaired the TR and TEMPSC.

It is likely that this value is overly conservative due to the location of the FSRU. It is moored in a port and therefore the passing vessel traffic is likely to be high. The water is shallow, calm and warm. These factors suggest a good prospect of recovery from the water. As such, it may be the case that personnel are more likely to evacuate directly to sea. A value of 25% has been adopted for this study.

The calculation for each end event is detailed below:

TR fatality = end event frequency x [total POB - immediate fatalities - number of personnel prevented from mustering in the TR] x TR impairment probability x conditional TEMPSC impairment probability x TR fatality factor

Note that in this context 'end event frequency' can be taken to be TRIF and thus the TRIF is directly related to the calculation of TR fatalities.

7.1.7.5 Ordered Evacuation using TEMPSC

Where personnel are able to use the TEMPSC it is still recognised that there is a degree of risk associated with TEMPSC use. Historical data has been used to calculate a weather averaged fatality factor for davit launched TEMPSC. This fatality fraction reflects the probability of fatality during the evacuation and recovery process over a range of sea states.

The calculation for each end event is detailed below:

Evacuation fatality = End event frequency x [total Personnel on Board (POB) - immediate fatalities - number of personnel prevented from mustering in the Temporary Refuge] x Temporary Refuge impairment probability x Evacuation fatality factor

For the purposes of the QRA davit launched lifeboats are assumed to be used hence a fatality fraction of 10.2% have been used throughout.

Note that this assumes the lifeboats can be launched without any obstructions due to being in a jetty location and with a LNGC being present.

It should also be noted that for any evacuation, there is also the possibility of using liferafts on the FSRU or moving to other external areas if these are not themselves impaired. These additional measures are taken into consideration when determining the fatality fractions above.

7.1.8 Non-Hydrocarbon Related Events

7.1.8.1 Ship Collision

A separate ship collision study has been conducted for the project and concluded that the potential risk is low and therefore, the consequences of ship collisions have not been analysed for the QRA. The outcomes of the Ship Collision study conclude that probability of collisions and allisions to a FSRU or a LNGC navigating in the approach channel or lying secured at the LNG Facility respectively are low to extremely low. The potential for loss of containment and release of LNG due to a breach of their inner hull can be considered negligible.

Threat	Scenario	Probability	Consequence
Collisions	LNGC/FSRU during channel navigation with KDWP bound vessels	Extremely Low	Medium ¹
Collisions	LNGC/FSRU during channel navigation with Anchorage Port bound vessels	Very Low	Medium
Allisions	FSRU/LNGC at berth by vessels exiting KDWP	Very Low	Low ²
Allisions	FSRU with jetty structures	Low	Very Low ³
Allisions	FSRU with berthing LNGC	Low	Very Low

¹Medium consequence: Has the potential to cause damage to external hull leading to its piercing or fracture. Breach of LNG containment, however is not considered credible.

²Low consequence: Would most likely result in compression damage to hull of LNGC/FSRU, with fracture being extremely rare.

³Very Low consequence: would result in scrapes and dents of hull plating.

Note: The above definitions are based on the research available, arrived at by evaluating the probable velocities at the time of any of the incident.

7.1.8.2 Structural Collapse

A structural collapse frequency (for non-hydrocarbon initiating events) of 1.30×10^{-5} per annum, is applied for the FSRU. This could occur rapidly and within the QRA it assumed to occur in heavy weather, such that it leads to 90% of the POB becoming fatalities. With regards to the FSRU this is considered most likely to occur when the FSRU is attempting to evade an incoming cyclone, hence may be some distance offshore, leading to this high level of fatalities.

It is recognised that the FSRU has been designed and built for world wide trading (Winter North Atlantic being taken as worst case environmental conditions) and that a well founded ship should not suffer a structural collapse in heavy weather, particularly given that cyclone avoidance is undertaken to minimise any potential damage. However, for the purposes of this QRA study at this stage of design, it is considered an appropriate structural collapse frequency to use. If necessary, this frequency can be revisited during the next design phase e.g. by consulting databases such as "Lloyds List Intelligence" and latest gas carrier casualties data.

7.1.8.3 Seismic Events

It is assumed that the threat due to seismic events on a floating installation is negligible.

7.1.9 Occupational Risk

The occupational risks relate to the hazards associated with performing work offshore, e.g. hazards such as falls, crushing, mechanical impacts, electrocution, etc. The Fatal Accident Rates (FARs) used in the QRA are based on a detailed review of historical databases covering details of all fatalities within the North Sea. This is the only area for which a detailed breakdown of the causes of fatalities is regularly published, together with sufficient information to show the offshore population for any data period, together with the breakdown of the number of personnel within each worker group.

The FAR values can be converted to Individual Risk Per Annum (IRPA) by taking into account the actual fraction of calendar time members of each employment category are exposed to the hazards at the workplace based on their offshore occupancy and their on-shift time. Below shows the FAR and IRPA for the categories of worker that have been considered in this risk assessment. This is based on 21 years period, i.e. 1991-2012.

Summary of IRPA and FAR for all Offshore Worker Categories

Worker Category	Max Offshore Occupancy	IRPA	FAR (per 10 ⁸ hours)
Cargo	0.5	1.10x10 ⁻⁵	0.5
Engineering	0.75	2.63x10 ⁻⁴	8.0
Deck	0.75	2.63x10 ⁻⁴	8.0
Catering/Management	0.75	-	-

The FAR is the number of fatalities per 10⁸ working hours.

It should be noted that these occupational risks are calculated using UK North Sea general data for offshore workers as it is considered the best source. It is broken down by worker category (production tech, marine crew, deck crew, catering, etc) and therefore has a relatively good resolution and a large supporting population. Of course, the occupational risks for workers on the FSRU are likely to be somewhat different considering that the FSRU is basically considered as a trading ship (LNGC) complying with IMO minimum manning certification with very few extras. However, for the purposes of this QRA, the values given above are believed to be the best available and sufficient to represent the workforce.

There are a number of onshore worker types across the facilities. The historical data related to onshore occupational risk is not available with a breakdown for different worker categories in the same way as provided above for offshore workers. Therefore, the most applicable OGP data has been used for all onshore worker categories. The global onshore worker FAR (excluding transport risk) has been used and a factor applied to make this data more applicable to the Asia region. The global FAR is 2.24 fatalities per 10⁸ working hours and the regional factor is 0.36, giving a FAR of 0.81 fatalities per 10⁸ working hours. The hours worked each year by the different onshore worker categories has been applied to give the IRPAs shown below.

Summary of IRPA for all Onshore Worker Categories

Worker Category	IRPA
Operators (including visits to jetty)	1.75x10 ⁻⁵
Office / Workshop	1.75x10 ⁻⁵
Lab	1.75x10 ⁻⁵

Risk Assessment

Instrument Technicians	1.75×10^{-5}
Electrical Technicians	1.75×10^{-5}
Painters	3.89×10^{-6}
Visitors	4.70×10^{-6}

For the purposes of the QRA, the onshore Operators who make daily visits to the Island Jetty are assumed to have the same occupational FAR whether they are onshore or offshore i.e. an IRPA 1.75×10^{-5} per year.

7.1.9.1 Transport Risk

All personnel will transfer from shore to the FSRU by boat. No transport risks are included in the QRA for FSRU personnel as it is assumed the risks to personnel from the boat journey from shore are minimal. This is particularly true since most crew members will only make the 15 minute journey every 3 to 6 months. It is assumed that personnel would be wearing life vests and the short distance travelled, calm warm shallow water, proximity to shore and other vessels in the vicinity (port) give a good prospect of recovery should an accident occur.

However, it is also recognised that 2 personnel will make a daily visit from shore to the island jetty. Clearly, even accounting for the points raised above, this frequency of boat journey introduces some risk.

Data has been taken from the Water Transport Accident Statistics report prepared by the International Association of Oil & Gas Producers (OGP). The fatal accident rate (FAR), which is the risk of fatality per 10^8 exposed hours, for marine personnel (boat crew) is shown below. Note that this is a general industry number and assumes adequate embarkation and disembarkation is provided so as not to increase the personnel risk.

Fatal Accident Rate for Marine Personnel

Measure	Value
Fatal accident rate (10^8 hours)	$30 + 26/\text{transit time (in hours)}$

The individual risk can be calculated as follows:

$$\text{Individual Risk (per Journey)} = \text{FAR} \times 10^{-8} \times \text{Transit Time per Journey (hours)}$$

i.e. $[30 + 26/\text{transit time (hrs)}] \times \text{transit time in hours}$

It is clear, from project guidance, that the 2 personnel visiting the island jetty for 8 hours each day will be part of the onshore operator team. Although other technicians, riggers, painters, HSSE personnel and diving crew etc. will visit the island jetty at varying intervals and durations, these are less frequent than the daily visits and therefore are not included here for the same reason as they not included for the FSRU crew.

From examining the manning distribution, it would appear that the onshore operator team visiting the island jetty will rotate between the various shifts such that each shift operator will spend 1 week every 4 weeks visiting the island jetty and they will visit for 6 days out of 7. Note that annual leave and public holidays are also incorporated into this.

This means that each individual operator will visit the island jetty for 6 days per 4 week i.e. 78 return trips per year.

This involves a 10 minute boat journey, to and from the island jetty, twice daily for 78 days. This equates to approximately 26 hours boat transport each year per person and an IRPA of 4.84×10^{-5} per year.

7.1.9.2 Dropped Objects

Any lifted load is a hazard as it has the potential to fall and cause a hydrocarbon release either from the process or from risers/pipelines, or to cause a direct fatality by striking installation personnel. The potential for dropped objects leading to breaches in the process equipment or risers/pipelines is generally included in the generic breach frequencies used to model each event. A separate Dropped Object Study has been performed to identify the threat frequency to topsides and subsea equipment.

7.1.9.3 Man Overboard

Although there is a small possibility of personnel being lost overboard during severe weather, it is assumed that adequate controls on the hazard will limit the risk levels to that already accounted for in the occupational risk levels.

7.1.9.4 Asphyxiation Incidents

A release of fixed extinguishant into a confined area (e.g. if used as active fire protection systems) could lead to fatalities from asphyxiation. These are included in the occupational type incidents for this facility. The narcotic or asphyxiation effect of hydrocarbon releases is not considered due to the open nature of the processing areas.

7.1.9.5 Electrical Fires (Excluding Accommodation)

Electrical fires could occur in any part of the installation due to faults in local

panels, junction boxes, etc. However, in the vast majority of cases the quantity of combustible material is very limited and the fire should be rapidly extinguished.

Electrical fires in switchgear areas and control rooms could be more serious due to the greater density of panels, cabling, etc. It is unlikely, however, that they could result directly in fatality and typically they will be well segregated from process equipment. All equipment will be suitably rated for the area in which it is located to minimise the ignition potential. Cables and equipment specifications for the project are such that they do not support combustion once deenergised.

7.1.9.6 Accommodation Fires

Fires within the accommodation fall into one of the following categories:

- Galley fires
- Fires within living quarters (including laundry)
- Electrical fires.

There is a potential for multiple fatalities due to fires in accommodation modules. The main threat is smoke, though in some instances personnel could become trapped in their cabins due to the location of a fire.

Personnel are expected to have multiple diverse escape routes available from the accommodation block, hence no fatalities are expected within the accommodation module. From inspection it is concluded that a fire in the accommodation is very unlikely to escalate out with the accommodation. Hence, provided personnel can escape out of the accommodation, they should not be further threatened. This scenario has therefore not been considered as threatening the integrity of the TR.

7.1.10 Results Presentation

7.1.10.1 Risk Plots


After running the RiskTool model, the risk contours were produced for a single FSRU moored at the Island Jetty. These risk contours represent the Location-Specific Individual Risks (LSIRs) from the immediate effects of releases assuming that personnel are located in each location for 100% of the time.

Note that to calculate risk of immediate fatality for workers, the manning distribution, occupancy and operational procedures (e.g. restricting personnel from loading hose area during loading operations) also need to be accounted for. This part of the calculation is completed in the QRA Riskmodel.


Risk Assessment

Also, as the plots show immediate risk, the impact of blowdown and isolation systems on the size of the contours is limited. The exception to this is the flash fire modelling for large LNG releases for which successful operation of the isolation system can significantly reduce the hazard effect distances. Therefore for these scenarios two sets of hazard ranges, with and without isolation systems working, have been included in the risk model, together with relevant probabilities. The impact of taking credit for successful operation of the isolation system for large flash fire events is to reduce the risk contours from the facility – these would otherwise be significantly increased.

The following figure shows the risk contours around the offshore and onshore facilities. The 1×10^{-5} /yr and 1×10^{-6} /yr contours cover the whole FSRU facility.



Risk Contour – Offshore



Risk Contour –Onshore facilities

7.1.10.2 Temporary Refuge Impairment Frequency (TRIF)

This risk measure is the frequency with which the Temporary Refuge is impaired due to a hydrocarbon event. This is presented as it is a direct measure of the potential for serious escalation of hydrocarbon events and their resulting effects on personnel. TRIF is presented over all time periods, i.e. it includes events that can threaten the TR after 1 hour.

Table below presents a summary of the Total TR Impairment Frequency. The way in which personnel will be affected is accounted for in the probability that the lifeboats (TEMPSC) will also be impaired, and is addressed under individual risk. Neither the island jetty of the onshore facilities has a TR.

TR Impairment Frequency per Annum for FSRU

Source	Within 1 Hour	
	TRIF (per annum)	%
Cryogenic - Direct	1.55E-04	60.63%
Fire - Direct	3.45E-07	0.13%
Gas Ingress into TR (HVAC Fails)	1.34E-05	5.22%
Machinery Space Fire	8.62E-05	33.69%
Riser - Hull failure	9.38E-08	0.04%
Smoke ingress into TR (HVAC Fails)	7.52E-07	0.29%
Total	2.56E-04	100%

impingement of subcooled LNG releases on the front face of the accommodation. These releases originate from a small percentage of the LNG headers and tank filling lines closest to the accommodation. It is self evident that that the frequency of impairment is relatively high for this mechanism since the releases do not have to find an ignition source for them to cause rapid damage. These same release scenarios also contribute to the other TR impairment mechanisms which are related to ignited events.

In reality, while this has been classified as TR impairment for the purposes of the QRA, the potential level of damage to front face of the accommodation will be relatively localised and therefore, this should not result in large numbers of fatalities. Still, the decision may be made to evacuate the FSRU and this is assumed within the QRA. Therefore, no immediate fatalities are assumed to be associated with this mechanism i.e. only forced evacuation fatalities are included. Similarly, it is assessed that the TEMPSC will not be impaired by these cryogenic releases.

The results also show that a large portion of the threat arises from machinery space fires e.g. engine room fires. By virtue of their severity and proximity to the accommodation, it would be expected for these mechanisms to dominate. Historical data suggests the frequency of such a severe incident to be once every 11,600 operating years, hence it is a fairly infrequent event, but the consequences are likely to be severe and cause impairment of the Temporary Refuge.

Overall, the level of TRIF is relatively low. This is particularly true for the remaining four TR impairment mechanisms (direct process fire impingement, riser fire impingement on the hull and smoke or gas ingress if the HVAC fails to shut down) which give a combined total TRIF (excluding cryogenic risk) of 1.45×10^{-5} per annum.

The potential for hull damage from riser fire impingement (i.e. only releases from riser itself) is very low at 8.36×10^{-8} per annum. This is because only ignited 70mm releases (ignited event frequency of 9.3×10^{-7} per annum) directed towards the hull (assumed directional probability of 50% due to size of fire and size of FSRU) are assumed to result in impairment. The FSRU is also at risk from releases from the sendout pipework on the island jetty immediately upstream of the riser ESDV. Again, only 70mm releases are capable of resulting in impairment and since the riser ESDV must fail to close (3% probability of failure on demand), this contribution to TRIF is low at 1.02×10^{-8} per annum.

There are a number of escalation rulesets considered within this analysis and it is clear that the critical escalations are those that can result in TR impairment. This would

Risk Assessment

include cryogenic releases and ignited pool fires impinging on the accommodation as well as NG riser fires damaging the FSRU hull. While other significant escalations can occur to process pipework and other structures e.g. at the regasification equipment, these are not considered capable of causing TR impairment or resulting in additional personnel risk.

Therefore, it is worth considering the rulesets applicable to critical escalations (i.e. TR impairment). Clearly there is a significant amount of uncertainty with regards to the potential for damage to the FSRU hull from riser releases. However, since the frequency of TR impairment associated with these releases is very low, it is unlikely that changes to this specific escalation ruleset will materially affect the QRA results.

Similarly, fire impingement on the front face of the accommodation is not a significant contributor to TRIF. However, it is clear that cryogenic releases impinging on the accommodation is a major contributor to TRIF. Within the QRA, it has been relatively conservatively assumed that damage to the accommodation will occur within a very short space of time (less than 1 minute), based on best available knowledge. At the same time, no specific credit is taken for the ability of operators to manually intervene and activate the deluge drenching system prior to damage occurring. Therefore, it could be considered that the QRA is relatively sensitive to this particular escalation ruleset. However, it has also been assessed that this type of damage would not automatically result in fatalities within the TR since the extent of damage is unlikely to be too severe. In fact, fatalities calculated for this scenario are dependent on the assumption that this will result in an evacuation of the FSRU with the associated risk of fatalities during the evacuation process.

Clearly the design of the FSRU, with a large separation distance between the accommodation and the process facilities towards the bow of the FSRU is a major contributor to this low TRIF from ignited releases. Additionally, the open, ventilated deck means that potential explosion overpressures should be low and this, combined with localised bunding and drip trays, to manage spills, results in a relatively low TRIF. Note that the maximum predicted explosion overpressure that could be experienced on the front face of the accommodation module would be <100mbar (based on the TNO method). This would only be possible for a small number of releases very close to the accommodation e.g. releases from LNG headers. It is assumed that the accommodation module (including windows) are capable of withstanding this level of blast. It is likely that the windows overlooking the process areas would be most vulnerable to explosions. However, some credit is given to the likelihood that these windows will be more robust than normal windows, particularly since they will be designed for seagoing operations. Therefore, no TR Impairment (or associated fatalities within

the TR) is included for explosions.

Explosion overpressures related to the regasification area may reach 1bar and is assumed to result in significant damage to structures and equipment in that area. This is caused to some extent by the confinement due to the barrier provided around the regasification area to protect against wave damage during seagoing operations. Explosion overpressures could be significantly reduced if this wall was removed, however, consideration of this would have to be balanced against the potential for wave damage. In any event, TR impairment from these explosions is considered to be unlikely due to the location of the regasification equipment, which is around 190m from the accommodation and is protected by the raised trunk deck. With a maximum overpressure of 1bar, there might usually be some merit in developing an exceedance curve which could be used to predict the probability with which different overpressures (below the maximum level of 1bar) could occur. However, the regasification system involves very few release scenarios and the releases generally involves high pressure gas, Therefore, it is more likely that a flammable gas cloud of sufficient size to produce the maximum overpressure will occur. Therefore, there is little benefit to be gained by producing an exceedance curve.

It is worth considering the potential impact of the emergency shutdown (ESD) and blowdown systems on risk levels. Clearly these system have little, if any, impact on immediate risk since they do not change the immediate release consequences. Therefore, it is more appropriate to discuss these systems with regards to escalation and TR impairment. The blowdown system on the FSRU is only provided for the high pressure gas inventories related to the regasification and sendout equipment. Clearly, the blowdown system will help to reduce the pressure within the system and thereby decrease fire sizes and durations. However, these inventories are located approximately 190m away from the accommodation (shielded by the trunk deck) so, the impact of the blowdown system in preventing TR impairment from fires is limited.

The blowdown system can also potentially help to limit the size of flammable gas clouds. However, when considering the regasification equipment releases (which can result in explosion overpressures of around 1bar) it is unlikely that the blowdown system will give much benefit since the gas cloud will build up too quickly from this high pressure source. Furthermore, since these explosions are not considered credible in terms of causing TR impairment, the real benefit of the blowdown system will be in reducing the potential for significant fire escalation to other inventories which can result in downtime.

The ESD system will act to limit the inventory available for release. As discussed,

Risk Assessment

only a handful of releases close to the accommodation have been considered capable of causing TR impairment and these are primarily liquid LNG releases. It has been assumed that significant releases, especially near the accommodation and particularly for manned operations such as LNG loading, will be either manually or automatically detected and the pumps will be shutdown. The assumed time to shutdown varies between manned and unmanned operations but will typically take place within a few minutes. It is not considered credible that significant releases near the accommodation will go undetected for any longer than this. Therefore, appropriate credit is taken for the shutdown system for these releases. Still, it should be noted that unignited releases near the accommodation can result in TR impairment even when detected and shutdown due to the rapid impairment time.

Releases further away from the accommodation, particularly for unmanned operations e.g. gas releases from regasification equipment may go undetected for longer (although significant releases should still normally be detected). However, as noted above for the blowdown system, these releases are not assessed to be capable of causing TR impairment.

The list of failure scenarios, ranked in terms of contribution to TRIF is shown in below Table. If the FSRU is moored to the island jetty on the berth which has greater separation distance from the riser, the contribution of NG riser releases can be removed from the TRIF.

Ranked TRIF for FSRU

Ranked	Event ID	Description	Total TRIF	%
1	002-L-04	LNG Feed Header	1.01E-04	40%
2	002-L-09	Machinery Space Fire	8.62E-05	34%
3	002-L-03	Cargo Tank Filling Lines	2.50E-05	10%
4	002-L-08	LNG Cargo Liquid Header (transfer from FSRU to other small carriers)	2.48E-05	10%
5	002-L-02	LNG Cargo Liquid Header (transfer from LNGC to FSRU)	1.86E-05	7%
6	002-G-06	NG Riser/Subsea Pipeline	8.36E-08	0.03%
7	002-G-05	NG Sendout Platform	1.02E-08	0.004%
8	001-L-01	LNGC Offloading Header	0.00E+00	0%
9	002-L-01	Transfer Hoses - Liquid	0.00E+00	0%
10	002-L-05	Recondenser Feed Line from LNG Feed Header (Inlet 1 – Top Inlet)	0.00E+00	0%
11	002-L-06	Recondenser Feed Line from LNG Feed Header (Inlet 2 – Bottom Inlet)	0.00E+00	0%
12	002-L-07	Recondenser Liquid Release	0.00E+00	0%
13	002-G-01	Recondenser - Gas Side Inlet	0.00E+00	0%
14	002-G-02	Regas Skids Gas Outlet	0.00E+00	0%
15	002-G-03	HP NG Sendout	0.00E+00	0%
16	002-G-04	HP Gas Sendout Arms	0.00E+00	0%
17	002-G-07	Vapour Return from Other Carriers (cargo discharge operation)	0.00E+00	0%
18	002-G-08	Vapour Return from FSRU Cargo Tanks (cargo loading operation)	0.00E+00	0%
19	002-G-09	MSO Skid	0.00E+00	0%
21	002-G-10	NG Return Line	0.00E+00	0%
22	003-G-01	Transfer Hoses - Vapour	0.00E+00	0%
23	002-G-11	HP Booster Pumps - Outlet	0.00E+00	0%

Risk Assessment


7.1.10.3 Individual Risk Per Annum (IRPA)

The Individual Risk per Annum (IRPA) brings together the risks from all hydrocarbon and non-hydrocarbon events for the individuals on the installations.

The IRPA for all worker groups on the the FSRU is shown below with the results being shown graphically in below figure.

IRPAs for All Offshore Worker Categories on FSRU

Source	Cargo		Engineering		Deck		Catering/Management	
	IRPA		IRPA		IRPA		IRPA	
Immediate - Ignited	3.20E-05	27.7%	6.89E-05	18.8%	4.30E-05	12.0%	7.98E-06	18.1%
Immediate - Non-Ignited	5.14E-05	44.5%	5.90E-06	1.6%	2.08E-05	5.8%	6.08E-06	13.8%
Muster Fatalities	1.07E-06	0.9%	1.23E-07	0.0%	4.32E-07	0.1%	1.26E-07	0.3%
TR Fatalities	1.77E-06	1.5%	2.65E-06	0.7%	2.64E-06	0.7%	2.65E-06	6.0%
Evacuation Fatalities	1.24E-05	10.7%	1.84E-05	5.0%	1.85E-05	5.2%	1.86E-05	42.0%
Occupational	1.10E-05	9.5%	2.63E-04	71.5%	2.63E-04	73.6%	0.00E+00	0.0%
Structural	5.85E-06	5.1%	8.78E-06	2.4%	8.78E-06	2.5%	8.78E-06	19.9%
Total	1.15E-04	100%	3.68E-04	100%	3.57E-04	100%	4.42E-05	100%



Breakdown of IRPA Results for FSRU Crew

It is seen that the IRPA for the Engineering crew is the highest amongst the worker groups considered at 3.68×10^{-4} fatalities per annum. This is due to their high historical occupational risk, as well as an exposure to immediate fatalities arising from engine room fires. The contribution to their IRPA from hydrocarbon releases is 9.60×10^{-5} fatalities per annum with non-hydrocarbon risks contributing 2.72×10^{-4} fatalities per annum.

The Deck crew have a similar IRPA (at 3.57×10^{-4} fatalities per annum), again largely due to the historical occupational risk. Their IRPA is a little lower since they have a lower contribution from the immediate effects of hydrocarbon releases. This is mainly due to the fact that they do not spend any significant amount of time in the engine room although they are exposed to other hydrocarbon fires.

The cargo crew historically have a fairly low occupational risk and thus have a lower

Risk Assessment

overall IRPA than the Deck and Engineering crews. However, they have the highest contribution from hydrocarbon risks at 9.85×10^{-5} fatalities per annum with a total IRPA of 1.15×10^{-4} fatalities per annum.

The occupational risks are lower for the catering and management crew, as these personnel spend almost all of their time offshore in the accommodation, where they are at much lower risk of injury due to slips, trips, falls, etc. than personnel who spend the majority of their time on plant. They are also not generally exposed to the immediate effects of hydrocarbon releases, hence they have the lowest overall IRPAs. Their total IRPA is 4.42×10^{-5} fatalities per annum

The average IRPA across all worker categories is calculated as 2.42×10^{-4} fatalities per annum.

It is also worth noting that the assumed offshore occupancy of personnel (other than cargo crew) is 75%. As noted, there are a number of individuals in each worker group that have a lower offshore occupancy, and therefore, a lower IRPA than the worker group in general. However, as discussed earlier, the worst case occupancy for each worker group is used here as a conservative assumption.

As noted earlier, the IRPAs for workers on the FSRU berth away from the riser is slightly lower since they are not at risk from evacuation due to NG riser releases. This typically means a very small reduction in IRPA i.e. between 4×10^{-9} fatalities per annum 6×10^{-9} and fatalities per annum lower compared to workers on the FSRU if moored on the berth closer to the riser. Other than this difference, the IRPA profile is the same for workers on both FSRUs.

The IRPAs for onshore workers, including those risks associated with trips to the island jetty, are provided below.

IRPAs for Onshore Worker Categories

Hazard	Operators		Office / Workshop		Lab Workers		Instrument Techs		Electrical Techs		Painters		Visitors	
	IRPA		IRPA		IRPA		IRPA		IRPA		IRPA		IRPA	
Onshore Hydrocarbon	1.16E-05	11.8%	1.26E-06	6.7%	1.13E-05	39.2%	7.63E-06	30.4%	1.28E-06	6.8%	2.80E-07	6.7%	3.39E-07	6.7%
Occupational	1.75E-05	17.8%	1.75E-05	93.3%	1.75E-05	60.8%	1.75E-05	69.6%	1.75E-05	93.2%	3.89E-06	93.3%	4.70E-06	93.3%
Jetty Risks	2.10E-05	21.3%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%
Transport to Jetty	4.84E-05	49.1%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%	0.00E+00	0.0%
Total	9.85E-05	100%	1.88E-05	100%	2.88E-05	100%	2.51E-05	100%	1.88E-05	100%	4.17E-06	100%	5.04E-06	100%

As can be seen, the operators who man the onshore control room and make regular visits to the island jetty are clearly the onshore workers with the highest IRPA. It is also clear that these risks are dominated with the hazards related to the trips to the island jetty. In particular, the transport hazard (daily boat transfers) make up approximately 49% of their

total risk while risks due to hydrocarbon releases in and around the jetty are also a significant contributor (21%). Note that when only one FSRU is at the island jetty, the IRPA for the operators decreases to 8.91×10^{-5} fatalities per annum since there are fewer hydrocarbon release scenarios that can affect the jetty.

Even without the risk associated with the island jetty, these operators have the highest IRPA, although very similar to the lab workers. This is due to their exposure to the immediate effects of hydrocarbon releases onshore since the control room and labs are located closer to the metering skid than many of the other onshore buildings. Additionally, the onshore operators make periodic visits to the metering skid where the immediate risk from hydrocarbon releases is highest.

The onshore occupational risk is significantly lower than that historically experienced offshore but is still a major contributor to the individual risk for onshore workers.

7.1.11 QRA Conclusion

- The overall frequency of hydrocarbon release for all SPV facilities is 0.24 (i.e. 2.43×10^{-1}) releases per annum.
- The overall ignited event frequency is 9.25×10^{-3} per annum.
- Temporary Refuge Impairment Frequency (within 1 Hour) is 2.56×10^{-4} per annum, or once every 3,900 years.
- The majority of events that have been identified as being able to impair the TR within an hour are a small proportion of releases from the LNG headers and pipework immediately adjacent to the accommodation front face. They can result in TR impairment due to the cryogenic threat from unignited releases or direct fire impingement as well as ingress of smoke or gas if the HVAC fails to shut down. The dominant contributor is from cryogenic releases (61%) as they do not require an ignition source and are assumed capable of causing rapid damage to the accommodation. This mechanism for TR impairment is not always assumed to result in large numbers of fatalities but does result in asset damage as well as the potential for fatalities during the evacuation process. Machinery space fires (e.g. fires in the engine room) are also a significant contributor to TRIF (34%). Finally, there is a very low contribution to TRIF from NG riser and associated releases that can impinge on the hull of the FSRU. This is assumed to only occur when a LNGC is alongside since this increases the time that it takes the FSRU to move away to a safe location.

Risk Assessment

- Only one failure scenario has been identified with the potential to result in muster impairment that might result in a small number of people having to use liferafts at the forward end. This is a large liquid release from the recondenser located at the forward end of the trunk deck.
- There is also a threat to personnel associated with events that lead to high levels of immediate fatalities in the process areas. This is partly due to the ability of fires on the open process decks to affect personnel over quite large areas. Unignited, cryogenic releases, also contribute to the immediate risks to personnel. While their hazard range is smaller than equivalent ignited releases, their frequency is higher since they do not require an ignition source.
- The risk to life from non-hydrocarbon events on the facility is dominated by occupational risks.
- The IRPA for the Engineering crew, which is the category of worker at greatest risk on the FSRUs, is 3.68×10^{-4} fatalities per annum, whereas the IRPA for catering/management crew who are the lowest risk group is 4.42×10^{-5} fatalities per annum. The average IRPA across all worker categories is 2.42×10^{-4} fatalities per annum.
- The control room Operators are the onshore worker at highest risk with an IRPA of 9.85×10^{-5} fatalities per annum. This includes risk related to periodic trips to the offshore island jetty. In fact, the risks (hydrocarbon and boat transfers) associated with the trips make up 70% of the onshore Operator's IRPA.
- The risk contours produced show that the 1×10^{-3} /yr contour is associated with the area around the loading hoses and the 1×10^{-4} /yr contour covers most of the FSRU but does not extend significantly beyond the facility.
- The 1×10^{-6} /yr contour for the offshore FSRU facilities does not reach the shore.
- The lower risk levels extend a maximum of 850m. This is significantly less than the distance to shore – i.e. for even the worst case events there is no potential for exposure to risk at the shore.




Fig. 7.1.1: HAZID Process

Table 7.1.1 : Chronological summary of incidents involving LNG ships

S. No.	Year of Incident	Name and Size of the Vessel	Brief description of the Incident
1	1964/1965	Jules Verne 25,500 M ³	<p>While loading LNG in Arzew, Algeria, lightning struck the forward vent riser of the ship and ignited vapour, which was being routinely vented through the ship venting system. Loading had been stopped when a thunderstorm broke out near the terminal but the vapour generated by the loading process was being released to the atmosphere. The shore return piping had not yet been in operation. The flame was quickly extinguished by purging with nitrogen through a connection to the riser.</p> <p>A similar event happened early in 1965 while the vessel was at sea shortly after leaving Arzew. The fire was again extinguished using the nitrogen purge connection. In this case, vapour was being vented into the atmosphere during ship transit, as was the normal practice at that time.</p>
2	May, 1965	Methane Princess, 27,400 M ³	The LNG loading arms were disconnected before the liquid lines had been completely drained, causing LNG to pass through a leaking closed valve and into a stainless steel drip pan placed underneath the arms. Seawater was applied to the area. Eventually, a star-shaped fracture appeared in the deck plating in spite of the application of the seawater.
3	May, 1965	Jules Verne, 25,500 M ³	On the fourth loading of Jules Verne at Arzew in May 1965 an LNG spill, caused by overflowing of Cargo Tank No.1, resulted in the fracture of the cover plating of the tank and of the adjacent deck plating. The cause of the overfill has never been adequately explained, but it was associated with the failure of liquid level instrumentation and unfamiliarity with equipment on the part of the cargo handling watch officer.
4	April 11, 1966	Methane Progress 27,400 M ³	Cargo leakage reported.

[Source : <http://www.ch-iv.com/AboutUs.html>]

Contd....

Risk Assessment

Contd....Table 7.1.1

S. No.	Year of Incident	Name and Size of the Vessel	Brief description of the Incident
5	September, 1968	Aristotle, 5,000 M ³	Ran aground off the coast of Mexico. Bottom damaged. Believed to be in LPG service when this occurred. No LNG released.
6	November 17, 1969	Polar Alaska, 71,500 M ³	Sloshing of the LNG heel in No. 1 tank caused part of the supports for the cargo pump electric cable tray to break loose, resulting in several perforations of the primary barrier. LNG leaked into the inter-barrier space. No LNG released.
7	September 2, 1970	Arctic Tokyo 71,500 M ³	Sloshing of the LNG heel in No. 1 tank during bad weather caused local deformation of the primary barrier and supporting insulation boxes. LNG leaked into the inter-barrier space at one location. No LNG released.
8	Late 1971	Descartes 50,000M ³	A minor fault in the connection between the primary barrier and the tank dome allowed gas into the inter-barrier space. No LNG released.
9	June, 1974	Methane Princess 27,400 M ³	the Methane Princess was rammed by the freighter Tower Princess while moored at Canvey Island LNG Terminal. Created a 3- foot gash in the outer hull. No LNG released.
10	July, 1974	Barge Massachusetts 5,000 M ³	LNG was being loaded on the barge on July 16, 1974. After a power failure and the automatic closure of the main liquid line valves, a small amount of LNG leaked from a 1-inch nitrogen-purge globe valve on the vessel's liquid header. The subsequent investigation by the US. Coast Guard found that a pressure surge caused by the valve closure induced the leakage of LNG through the bonnet and gland of the 1-inch valve. The valve had not leaked during the previous seven or more hours of loading. Several fractures occurred in the deck plates. They extended over an area that measured about one by two meters. The amount of LNG involved in the leakage was reported to be about 40 gallons. As a result of this incident, The U.S. Coast Guard banned the Barge Massachusetts from LNG service

[Source : <http://www.ch-iv.com/AboutUs.html>]

Contd....

Risk Assessment

Contd....Table 7.1.1

S. No.	Year of Incident	Name and Size of the Vessel	Brief description of the Incident
			within the U.S. It is believed that the Barge Massachusetts is now working in liquid ethylene service.
11	August, 1974	Euclides 4,000 M ³	Minor damage due to contact with another vessel. No LNG released.
12	November, 1974	Euclides 4,000 M ³	Ran aground at La Havre, France. Damaged bottom and propeller. No LNG released.
13	1974	Methane Progress 27,400 M ³	Ran aground at Arzew, Algeria. Damaged. No LNG released.
14	September, 1977	LNG Aquarius 125,000 M ³	During the filling of Cargo Tank No. 1 at Bontang on September 16, 1977, LNG overflowed through the vent mast serving that tank. The incident may have been caused by difficulties in the liquid level gauge system. The high-level alarm had been placed in the override mode to eliminate nuisance alarms. Surprisingly, the mild steel plate of which the cargo tank cover was made did not fracture as a result of this spill.
15	August 14, 1978	Khannur 124,890 M ³	Collision with cargo ship Hong Hwa in the Strait of Singapore. Minor damage. No LNG released
16	April, 1979	Mostefa Ben Boulaid 125,000 M ³	While discharging cargo at Cove Point, Maryland on April 8, 1979, a check valve in the piping system of the vessel failed releasing a small quantity of LNG. This resulted in minor fractures of the deck plating. This spill was caused by the escape of LNG from a swing-check valve in the liquid line. In this valve, the hinge pin is retained by a head bolt, which penetrates the wall of the valve body. In the course of operating the ship and cargo pumping system, it appears that the vibration caused the bolt to back out, releasing a shower of LNG onto the deck. The vessel was taken out of service after the incident and the structural work renewed. All of the check valves in the ship's liquid system were

[Source : <http://www.ch-iv.com/AboutUs.html>]

Contd....

Risk Assessment

Contd....Table 7.1.1

S. No.	Year of Incident	Name and Size of the Vessel	Brief description of the Incident
			modified to prevent a recurrence of the failure. A light stainless steel keeper was fashioned and installed at each bolt head. Shortly after the ship returned to service, LNG was noticed leaking from around one bolt head, the keeper for which had been stripped, again probably because of vibration. More substantial keepers were installed and the valves have been free from trouble since that time.
17	April, 1979	Pollenger 87,600 M ³	While the Pollenger was discharging LNG at the Distrigas terminal at Everett, Massachusetts on April 25, 1979, LNG leaking from a valve gland apparently fractured the tank cover plating at Cargo Tank No. 1. The quantity of LNG that spilled was probably only a few litres, but the fractures in the cover plating covered an area of about two square meters.
18	June 29, 1979	El Paso Paul Kayser 125,000 M ³	Ran aground at 14 knots while manoeuvring to avoid another vessel in the Strait of Gibraltar. Bottom damaged extensively. Vessel re-floated and cargo transferred to sister ship, the El Paso Sonatrach. No LNG released.
19	December 12, 1980	LNG Taurus 125,000 M ³	Ran aground in heavy weather at Mature Anchorage off Tobata, Japan. Bottom damaged extensively. Vessel re-floated, proceeded under its own power to the Kita Kyushu LNG Terminal, and cargo discharged. No LNG released.
20	Early 1980s	El Paso Consolidated, 125,000 M ³	Minor release of LNG from a flange. Deck plating fractured due to low temperature embrittlement.

[Source : <http://www.ch-iv.com/AboutUs.html>]

Contd....

Risk Assessment

Contd....Table 7.1.1

S. No.	Year of Incident	Name and Size of the Vessel	Brief description of the Incident
21	Early 1980s	Larbi Ben M'Hidi 129,500 M ³	Vapor released during transfer arm disconnection. No LNG released.
22	December, 1983	Norman Lady 87,600 M ³	During cool down of the cargo transfer arms , prior to unloading at Sodegaura, Japan, the ship suddenly moved astern under its own power. All cargo transfer arms sheared and LNG spilled. No ignition.
23	1985	Isabella 35,500 M ³	LNG released as a result of overfilling a tank. Deck fractured due to low temperature embrittlement.
24	1985	Annabella 35,500 M ³	Reported as "pressurized cargo tank." Presumably, some LNG released from the tank or piping. No other details are available.
25	1985	Ramadan Abane 126,000M ³	Collision while loaded. Port bow affected. No LNG released.
26	February, 1989	Tellier 40,000 M ³	Wind blew ship from its berth at Skikda, Algeria. Cargo transfer arm s sheared. Piping on ship heavily damaged. Cargo transfer had been stopped. According to some verbal accounts of this incident, LNG was released from the cargo transfer arm s .
27	Early 1990	BachirChihani 125,000 M ³	A fracture occurred at a part of the ship structure, which is prone to the high stresses that m a y accompany the complex deflections that the hull encounters on the high seas. Fracture of the inner hull plating led to the ingress of seawater into the space behind the cargo hold insulation while the vessel was in ballast. No LNG released.
28	May 21, 1997	Northwest Swift 125,000M ³	Collided with a fishing vessel about 400 km from Japan. Some damage to hull, but no ingress of water. No LNG released.

[Source : <http://www.ch-iv.com/AboutUs.html>]

Contd....

Risk Assessment

Contd....Table 7.1.1

S. No.	Year of Incident	Name and Size of the Vessel	Brief description of the Incident
29	October 31, 1997	Capricorn 126,300 M ³ LNG	Struck a mooring dolphin at a pier near the Steenbok LNG Terminal in Japan. Some damage to hull, but no ingress of water. No LNG released.
30	September 6, 1999	Methane Polar 71,500 M ³	Engine failure during approach to Atlantic LNG jetty (Trinidad and Tobago). Struck and damaged Petrotrin pier. No injuries, No LNG released.
31	December 2002	Norman Lady 87,000 M ³	A U.S. nuclear submarine, the U.S.S. Oklahom a City , raised its periscope into the ship necessitating her withdrawal briefly from service for repairs due to penetration of outer hull allowing leakage of seawater. No LNG released
32	December 15, 2009	Matthew 126,500 M ³	The 920-foot Norwegian LNG tanker Matthew was grounded, half a mile southeast of Cayo Caribe near Guayanilla, Puerto Rico. The crew shifted some of the cargo and the vessel was refloated after about three hours with the help of two tugboats. The Matthew proceeded to the EcoElectrica Punta Guayanilla LNG terminal to discharge and receive surveys. Authorities say investigators found no signs of a spill or other environmental damage from the grounding. No LNG released
33	2010	Bluesky 145,000 M ³	The TMT-controlled carrier was damaged at GDF Suez's Montoir de Bretagne terminal in France when a valve was by-passed and liquid passed into the gas take-off line during discharge operations. The damage sustained extended to part of the ship's manifold and its feed lines without damage to the shore-side systems. No LNG release was reported
34	March 1, 2010	LNG Edo 126,500 M ³	During loading operations at the Bonny LNG terminal in Nigeria, LNG Edo took a significant list. Cargo loading operations were suspended. The cause of the list was found to be abnormal ballast water distribution in the ship's tanks. The distribution in the ballast tanks was returned to normal and loading was completed in a normal manner on March 4th. There were no injuries to personnel nor was there any pollution or damage to either the vessel or the jetty. The vessel subsequently discharged cargo at Sines, Portugal, on March 13th and 14th without incident. No LNG released

[Source : <http://www.ch-iv.com/AboutUs.html>]

Risk Assessment

S. No.	Year of Incident	Name and Size of the Vessel	Brief description of the Incident
35	December 28, 2013	Al Gharrafa 215,500 M ³	While transiting the Singapore Strait en route to Japan, the Qatari-chartered Al Gharaffa collided with the Greek Controlled, 10,114-teu Hanjin Italy. The LNG Carrier suffered severe bow damage, however there were no injuries, no damage to the containment system, and no LNG was released. The ability of the vessel to sail was not compromised, and the ship was safely anchored shortly after the incident. Between January 10 and 13, 2014, the LNG from the Al Gharrafa was successfully transferred to the Al Ghashamiya. No LNG Released

[Source : <http://www.ch-iv.com/AboutUs.html>]

Table 7.1.2 : Risk Matrix and Definition for HAZID

				Consequence				
				Insignificant	Minor	Moderate	Major	Catastrophic
				1	2	3	4	5
Health & Safety (H&S)				No medical treatment required	Objective but reversible disability requiring hospitalization	Moderate irreversible disability or impairment(<30%) to one or more persons	Single fatality and/or severe irreversible disability (>30%) to one or more persons	Multiple fatalities, or significant irreversible effects to >50 persons
Natural Environment (ENV)				Minor effects on biological of physical environment but not effecting ecosystem functions	Moderate, short-term effects	Serious medium term environmental effects	Very serious, long-term environmental impairment of ecosystem functions	
Social / Cultural Heritage				Minor medium-Term social impacts on local population. Mostly repairable	On-going social issues. Permanent damage to items of cultural significance	On-going serious social issues. Significant damage to structures/items of cultural significance		
Community/ Govt/ Reputation/ Media				Minor adverse local public or medical attention or complaints	Attention from media and/or heightened concern by local community. Criticism by NGOs	Significant adverse national media/public/NGO attention	Serious public or media outcry (International coverage)	
Legal				Minor legal issues, non-compliances and breaches or regulation		Serious breach of regulation with investigation or report to authority with prosecution and/or moderate fine possible	Major breach of regulation Major Litigation	Significant prosecution and fines. Very serious litigation including class action
Profit reduction				<US\$10K	US\$10K-US\$100K	US\$100K-US\$1M	US\$1M-US\$10M	US\$10M+
Likelihood	A	Almost certain	Once a year or more frequently	Medium	High	High	Very High	Very High
	B	Likely	Once every ten years	Medium	Medium	High	High	Very High
	C	Possible	Once every thirty years	Low	Medium	Medium	High	High
	D	Unlikely	Once every 100 years	Low	Low	Medium	Medium	High
	E	Rare	Once every 10,000 years	Low	Low	Medium	Medium	Medium

Table 7.1.3: HAZID analysis actions details

S.No	Hazard Ref. No.	Recommendation	Risk Ranking
1	1.1.1 B	Elevation of ORF to consider the data from Met ocean Study.	Medium
2	1.1.1 H	Select properly the type of trees to be planted in the green	Medium
3	1.1.2 A	Define appropriate standards for underground electrical	High
4	1.1.4 A	Light protection to be provided by FEED contractor	Medium
5	1.1.4 A	SOP for personnel to take shelter in main control room during lightning storms to be developed	Medium
6	1.1.5 A	Design of ORF shall account for seismic data during FEED	High
7	1.1.5 A	Seismic sensor shall be provided at strategic location in the ORF	High
8	1.1.6 A	Mitigation measures shall be implemented based on recommendations of environmental impact assessment and environmental management plan.	Medium
9	1.1.7 A	Geotechnical Survey to be conducted in FEED and FEED contractor to confirm if piling is required.	Medium
10	1.2.1 A	Water Bath Heater/Diesel Generator specifications to include requirement to comply with local environment regulations	Medium
11	1.2.3 A	Certified vendor to be engaged to collect, treat and dispose water from Water Bath Heater.	Medium
12	1.3.3 A	Check that the ORF location is not within the exclusion Zone	Not Ranked
13	1.4.3 A	Review the possibility of locating the filling station outside the ORF	Medium
14	1.4.11 A	Review the possibility of the pig receiver in consideration of jet fire releases and consider providing fire walls against the release direction	Medium
15	1.4.12 A	Fire protection shall consider the result from QRA study in FEED	Medium
16	1.4.13 A	Provide FM200 for control rooms. Provide fire extinguishers	Medium
17	1.4.14 C	Overpressure design criteria for control room to be defined in FEED.	Medium
18	1.5.1 A	Pipeline design shall consider vacuum drying of subsea pipeline.	Medium
19	1.5.2 A	Confirm the piping design pressure is able to take	Medium

Contd....

Risk Assessment

Contd....Table 7.1.3

S.No	Hazard Ref. No.	Recommendation	Risk Ranking
		thermal expansion of gas at 40 deg C ambient temperature.	
20	1.5.3 A	Sizing of diesel tank to be confirmed during FEED	Low
21	1.5.11 A	Consider to provide insulation on water Bath Heater (for energy conservation).	Medium
22	1.6.1 A	Evaluate if aboveground or underground firewater ring main shall be used within ORF in FEED.	Not Ranked
23	1.7.1 A	Material Handling Study to be conducted in FEED.	Not Ranked
24	1.7.2 A	Requirement for override provisions to be identified in FEED.	Medium
25	1.7.3 A	Requirement for bypass provisions to be identified in FEED.	Medium
26	1.8.5 A	Design of Natural Gas header /metering shall consider future Expansions	Not Ranked
27	1.10.1 A	Assess the adequacy for main, backup and emergency power supply during normal operations.	Not Ranked
28	2.1.6 A	FEED design to consider the scenario and design according to code requirement.	Medium
29	2.1.7 A	FEED design to consider scouring and design according to code requirement.	Medium
30	2.3.4 A	Consider providing riser protection in FEED	Medium
31	2.5.1 A	Bypass valves (2") are required around 24" ESDV.	Not Ranked
32	2.5.6 A	FSRU pump shutoff pressure shall be lower than pipeline design pressure or HIPPS system to be provided.	Medium
33	2.6.2 A	Provide tie-in point in ORF for N2 connection for subsea pipeline purging.	Medium
34	2.8.1 A	FEED contractor to design pipeline to ensure pipeline is pig gable and ensure quality of pipeline (as PMC).	Medium
35	3.1.1 K	Distance for moving safety Zone around LNGC to be defined in pre-FEED.	High
36	4.1.1 K	Distance for moving safety Zone around FSRU to be defined in pre-FEED	High
37	4.5.20 B	Time required to depressurize has to be considered in the design of the HP arm (drift study)	High

Contd....

Risk Assessment
Contd....Table 7.1.3

S.No	Hazard Ref. No.	Recommendation	Risk Ranking
38	5.1.3 A	Distance for moving safety zone around LNGC to be defined in pre-FEED.	Medium
39	5.1.7 A	Design of topsides of jetty shall local extreme weather conditions	Not Ranked
40	5.1.7 A	Cryogenic arm design shall be suitable for marine conditions at sea during emergency departure.	Not Ranked
41	5.1.9 B	To confirm if emergency venting (cold venting) is allowed by local/international regulations for permanent installations	Medium
42	5.1.9 C	To confirm FSRU is considered as temporary or permanent installation by Indian regulations.	Medium
43	5.2.4 A	Protective shelter to be provided for diesel/hydraulic containment systems	Medium
44	5.2.4 B	Provide pump in impoundment basin to drain rainwater	Medium
45	5.4.13 A	Firefighting system to be designated as per code requirements and results from site-specific fire safety study.	Medium
46	5.4.13 A	All mooring lines shall be equipped with nylon/ polyesters grommet and ensure that all mooring lines are insulated.	Medium
47	5.5.2 A	Possible liquid carryover to cold vent leading to potential brittleness of cold vent and design to consider this scenario.	Medium
48	5.5.2 B	Indicate nitrogen snuffing system at cold vent on UFDs.	Medium
49	5.5.5 A	Layout to be optimized to reduce the inventory in piping system.	Medium
50	5.5.8 A	Vendor shall confirm if the release of HP regasified LNG trapped between the PERCs of both loading arms can be safely disposed of locally, or a vent connection to a safe location is needed.	Medium
51	5.5.10 B	Activation of disconnection shall be studied based on drifting scenarios, ball valve characteristics and arm envelope.	Medium
52	5.5.14 A	Surge analysis to be conducted in FEED.	Medium
53	5.8.1 A	Provide ladders at forward dolphin side of jetty	High
54	5.8.4 A	Material handling study to be conducted in FEED and mobile crane to be sized according to heaviest equipment.	High

Contd....

Contd....Table 7.1.3

S.No	Hazard Ref. No.	Recommendation	Risk Ranking
55	6.1.2 A	Access to main road shall be provided upstream of inner creek.	Not Ranked
56	6.1.2 A	Outer creek to be delivered towards sea, upstream of inner creek.	Not Ranked
57	6.1.3 A	Location of ORF to be checked against relevant OISD based on exclusion zone of ORF results; if no specific requirements, NFPA 59A shall be considered.	Not Ranked
58	6.1.3 A	If ORF impacts the public road, location of ORF shall be optimized without compromising the shipping area in the sea.	Not Ranked

Table 7.1.4: Failure frequencies by process equipment

Equipment	Hole Size / Location	Frequency (/yr)					
		Total	Tiny (1-3mm)	Small (7mm)	Medium (22mm)	Large (70mm)	Very Large (150mm)
Centrifugal Compressors		1.02E-02	6.86E-03	2.35E-03	9.47E-04	3.27E-05	
Reciprocating Compressors		7.98E-02	5.68E-02	1.49E-02	7.89E-03	2.25E-04	
Reciprocating Pump		8.17E-03	4.98E-03	1.74E-03	9.24E-04	5.03E-04	2.89E-05
Centrifugal Pump (double seal)		6.25E-03	4.67E-03	1.35E-03	2.26E-04		
Centrifugal Pump (Single seal)		8.90E-03	5.61E-03	2.62E-03	6.71E-04		
Shell & Tube Heat Exchangers	Shell	4.38E-03	2.98E-03	9.64E-04	2.63E-04	1.75E-04	
Shell & Tube Heat Exchangers	Tubing	3.36E-03	2.52E-03	4.20E-04	3.00E-04	2.89E-05	9.11E-05
Plate		9.90E-03	4.84E-03	3.63E-03	1.39E-03	3.67E-05	
Fin Fan Coolers		3.43E-03	3.43E-03				
Expanders		9.90E-03	4.95E-03	4.95E-03			
Pressure Vessels		2.46E-03	1.54E-03	2.82E-04	4.33E-04	1.44E-04	6.79E-05
Pig Receivers & Launchers		2.14E-02	1.21E-02	4.56E-03	3.05E-03	9.27E-04	7.60E-04
Wellheads / Xmas Tree (Press. < 5000 psi)		2.08E-03	1.35E-03	4.05E-04	2.61E-04	6.63E-06	5.94E-05
Wellheads / Xmas Tree (Press. > 5000 psi)		1.37E-03	8.50E-04	4.47E-04	7.26E-05		

Contd..

Contd....Table 7.1.4

Equipment	Frequency (/yr)						
	Hole Size / Location	Total	Tiny (1-3mm)	Small (7mm)	Medium (22mm)	Large (70mm)	Very Large (150mm)
Filters		2.62E-03	1.58E-03	7.08E-04	2.50E-04	7.85E-05	4.81E-06
Instruments		5.54E-04	3.57E-04	1.38E-04	5.63E-05	2.54E-06	
Flanges	D ≤ 3 inch	2.57E-05	1.72E-05	4.70E-06	3.61E-06	2.17E-07	
Flanges	3 < D < 11	4.00E-05	2.83E-05	6.18E-06	3.77E-06	4.08E-07	1.30E-06
Flanges	D > 11 inch	6.40E-05	4.22E-05	1.45E-05	2.67E-06	2.17E-06	2.43E-06
ESD Valves	D ≤ 3 inch	1.84E-04	1.15E-04	3.97E-05	2.80E-05	1.96E-06	
ESD Valves	3 inch < D	4.48E-04	3.44E-04	4.99E-05	4.07E-05	4.49E-06	8.50E-06
Other Actuated Valves	D ≤ 3 inch	8.51E-04	5.29E-04	1.84E-04	1.29E-04	9.07E-06	
Other Actuated Valves	3 inch < D	7.12E-04	5.47E-04	7.94E-05	6.48E-05	7.14E-06	1.35E-05
Manual Valves	D ≤ 3 inch	5.79E-05	3.60E-05	1.25E-05	8.78E-06	6.17E-07	
Manual Valves	3 < D < 11	8.81E-05	6.64E-05	1.04E-05	8.04E-06	1.11E-06	2.11E-06
Manual Valves	D > 11 inch	3.65E-04	3.01E-04	3.13E-05	3.28E-05		
Steel Piping (/ metre)	D ≤ 3 inch	1.79E-04	1.16E-04	3.98E-05	2.06E-05	2.11E-06	
Steel Piping (/ metre)	3 < D < 11	5.31E-05	3.15E-05	9.82E-06	5.44E-06	1.16E-06	5.16E-06
Steel Piping (/ metre)	D > 11 inch	4.70E-05	2.87E-05	8.16E-06	4.90E-06	3.85E-07	4.84E-06
Flexible Piping (All sizes / metre)		2.69E-04	1.59E-04	4.97E-05	2.75E-05	5.88E-06	2.61E-05

7.2 Emergency Management Plan

This section outlines the procedure for the management of emergencies and evacuation plans during the operations phase. The main objective of the Emergency Response Plan (ERP) is to ensure that activities are carried out to the following priorities:

- Safeguard lives
- Protect the Environment
- Protect Company and all assets including third party assets
- Maintain the Company Image/Reputation
- Resume normal activities.

Personnel involved in dealing with emergency situations shall follow these priorities when making decisions and developing strategies.

7.2.1 Scope

The ERP covers the emergency response philosophy that needs to be applied to the facilities as an integrated operational entity. This integrated operational entity would cover the FSRU, Island Jetty and the onshore facility. The FSRU/LNGC will have their own a separate Emergency Response Procedure and any emergency on the FSRU/LNGC or affecting the FSRU/LNGC will be covered by the same. A HSSE bridging document shall be developed between the SPV and the FSRU to detail interfaces on a number of aspects including emergency response, which shall be used in conjunction with this document, as well as the Emergency Response Procedures of the FSRU and the vessel manager's emergency preparedness and response plans.

7.2.2 Emergency Response

Prevention of emergencies through good design, operation, maintenance and inspection are essential to reduce the probability of occurrence and consequential effect of such possibilities. However, it is not possible to totally eliminate such eventualities and random failures of equipment and human errors. Omissions and unsafe acts cannot be ruled out to create safety incidents and adversarial forces can create security emergencies. Emergency response planning thus outlines the immediate actions and operations required for dealing with incidents in which normal operations are interrupted and special measures are required to be taken to mitigate the effects of such incidents and restoration of normalcy at the earliest.

Risk Assessment

Emergency management planning is therefore, an essential and critical component of impact minimising measures. It is through such planning that one recognises that accidents and security incidents are possible and arrive at their impacts. These pre-incident plans so developed helps in taking informed decisions and these help in mitigating the effect of the emergency in case of such an event. Main objective of an Emergency Response Philosophy (ERP) is:

- Identify the source of emergency;
- Minimise the effects of the emergency on people and property.

The ERP therefore, is related to the identification of sources from which hazards can arise and the maximum credible loss scenario that can take place in the concerned area. The action that can successfully mitigate the effects of losses / emergencies need to be well planned, so that they would require less effort and resources to control and terminate emergencies, should the same occur. Formulation of an ERP is the first step in this process, and needs to be followed by development of a detailed ER procedure. This procedure shall be reviewed at periodic intervals and needs to be tested by holding of periodical mock emergency simulation and drill. Any shortcomings revealed during such exercise are thereafter required to be corrected by further training or making changes to the Emergency Response Plan. The procedure shall be reviewed and updated in the following circumstances, as a minimum:

- Major alteration or extension of Port, SPV facilities or pipeline.
- Major change in habitation or land use of the neighbourhood takes place.
- Change in Security threat perception;
- Change in the operating philosophy with the FSRU

Following sequence to be followed in all scenarios:

- Raise Alarm
- Escape
- Isolate
- Control
- Evacuate
- Rescue
- Recover and Normalize

7.2.2.1 FSRU

The FSRU is a manned sea going LNG carrier, equipped with a re-gas module located on it. It would receive LNG from other LNG carriers via flexible hoses, store it, re-gasify it and send it to the onshore facility via fixed unloading arms.

The FSRU is a standalone unit and would have its own emergency response systems. The only process link it has to the onshore facility is through the fixed NG discharge arms. In case of an emergency, if required, FSRU can unmoor and move away from the Island Jetty.

Security related Emergency Response of the FSRU would not be as independent as in the case of a moving ship as the dynamics of such incidents may be different, the FSRU being located at a port and co located with other activities and facilities. Also, it would be within the response plan of the port/SPV. The FSRU will be treated as a vessel and as such will have to maintain an International Ship and Port Security (ISPS) certificate based and a Ship Security Plan (SSP).

7.2.2.2 Island Jetty

The Island Jetty would be an unmanned installation, accessed by boats using the boat landing, and later stairs/monkey ladder to climb up. It is located approximately at a distance 2.5 km away from shore. It would have a high pressure NG unloading arm w.r.t hazardous chemicals (as per factory rules, LNG and Re-gasified natural gas are classified as Hazardous chemicals due to flammable properties). The current Operations & Maintenance (O&M) philosophy is to access the Island Jetty (8 hrs/day) by two Shore operators for the routine inspections and maintenances.

7.2.2.3 Sub-Sea Pipeline

From the Island Jetty the NG would be evacuated to shore via a sub-sea pipeline. This pipeline is proposed to be 3.8 km long and transfers the NG to the on-shore metering skid. It has provisions of isolation valve for safe isolation (Riser ESDV) and inlet ESDV at the onshore facility and would be designed for intelligent pigging to maintain integrity.

7.2.2.4 Onshore Receiving Facility (ORF)

The onshore receiving facility (ORF) would have a metering station/custody transfer with the customers. It is a manned location and the Central Control Room is located here. All the utilities required to support these units are located here. The facility also has a vent which will be used to vent gas during the maintenance of the pipeline as well as for emergency depressurization.

7.2.3 Temporary Refuge / Muster Points

7.2.3.1 FSRU and LNGC

The accommodation block on the FSRU is envisaged to act as the temporary refuge for all the people on the FSRU. Depending on Emergency situation, FSRU personnel will muster at different locations - fire control point. Primary Muster point is near the Fire Control Station (Main Deck), port side of the accommodation, main deck level. There are multiple pathways (each side plus up the stairs and along trunk deck) are available for making escape towards the accommodation/muster point. Primary means of evacuation from the FSRU would be by lifeboats. Secondary means of evacuation would be via offshore side gangway, or via the Island Jetty. Life rafts would be the last option for evacuation.

The LNGC will follow its own protocol for Evacuation and muster; this will be in accordance to the Marine standards and as approved by their respective classification society and flag state.

7.2.3.2 Island Jetty

For the Island Jetty, no Temporary refuge has been developed and the personnel would use the boat landing on the send out platform or the extreme end of the mooring dolphin towards the shore side, and board the standby vessel. In an event that access to boat landing is not possible, and should the FSRU gangway access be clear, then they would go to FSRU muster location.

7.2.3.3 Onshore Receiving Facility (ORF)

In the onshore receiving facility, the muster points have been identified and the staff will chose the one nearest to them first and then follow the PA instruction, as given by the Incident Commander.

7.2.4 Emergency Guide for different Scenarios

7.2.4.1 Process Events

Upon detection of an event, the following should be considered in assessing the situation.

- Source and nature of the event, e.g. location of the event, size and type of a impact;
- Consequence of the event, i.e. determine whether ignition occurs or not;
 - If no ignition, conduct field assessment to ensure that ignition sources are isolated, for e.g.: ESD is initiated and that leak is being contained or dispersed to safe level;

Risk Assessment

- If the event results in a fire or explosion, conduct damage assessment to determine the conditions of escape routes and platform structure. In addition, the potential for the event to escalate based on inventory isolated;
- Impact of the event to the Muster Station/Temporary Refuge (TR). Ensure no fire, smoke or gas is affecting the electrical systems.

If situation is under control and there is no potential for escalation, Incident Commander after confirming with Emergency Response Team (ERT) to declare situation under control and stand down. Recovery measures should then proceed. If situation is uncontrollable and further escalation occurs, Incident Commander can take relevant actions for escalation. During the emergency Incident Commander shall conduct field assessment and take appropriate action.

All affected personnel shall upon hearing alarm, proceed to Muster Station for headcount and await further instructions from Incident Commander.

7.2.4.2 Non Process Events

Upon discovery of a non process event (like medical emergencies), the following guide should be adopted,

- Provide immediate assistance to the injured, if safe to do so;
- Conduct field assessment to ensure integrity of escape routes and platform structure;
- Assess impact to the Process, i.e. leaks;
 - If the event lead to process impact;
 - If there is no impact to the process, Incident Commander to determine if Medivac is necessary.

If integrity of escape routes and structure is not affected and situation is under control, Incident Commander should declare situation under control and stand down. Recovery measures should then proceed. If situation is uncontrollable and further escalation occurs, Incident Commander can take relevant actions for escalation. During the emergency Incident Commander shall conduct field assessment and take appropriate action.

All affected personnel shall upon hearing alarm, proceed to Muster Station for headcount and await further instructions from Incident Commander.

7.2.4.3 Security Emergency

- Any security related incident shall be managed in accordance with the Security Manual. For the FSRU, the Ship Security Plan (& interface with Port Facility Security Plan, if any) shall be complied with. If the Island Jetty, is manned during a security incident on the FSRU, all personnel shall report to the FSRU, and act in accordance with the instructions of the FSRU Captain.
- There will be a need to accommodate the Port Facility Security Emergency Response plan. Therefore, this particular arrangement would further be dealt with more in detail in the related bridging document to be prepared subsequently
- Kakinada Deep Water Port is ISPS Code compliant and Port Security Plan will cover security arrangements within the port as a whole. Any breach of security within the port area shall be brought to the Port Facility Security Officer.
- In case of onshore, a security plan shall be developed, and all personnel shall act in accordance with the instructions of the Incident Command post.

7.2.4.4 Emergency Scenarios Identified

The major hazard scenarios for the project have been identified in the various exercises like HAZID and DSR. The scenarios identified for the proposed facilities are given in **Table 7.2.1**.

7.2.5 Alarms Systems

7.2.5.1 Onshore Facility and Island Jetty

- Fire Alarms: the fire alarms shall be located at all the places with a potential fire scenario. Also, automatic trip systems upon their detection might be installed. They shall be studied in the fire and gas mapping.
- Gas Alarms: Gas alarms shall be installed across all the locations with a potential to have a gas leak. The installation of automatic shutdown upon detection by these alarms shall be studied in details, depending upon the reliability of the gas detector and the scenario.
- All Clear siren: All clear siren shall be present to indicate all clear situation after an emergency.
- PA system: will be used to indicate the situation by means of verbal command.

7.2.5.2 Shipboard Emergency

- FSRU and the LNGC will be fitted with the necessary alarms in compliance with the regulations under which it is built and operated. These will include but not limited to fire alarms, gas alarms, high level alarms, high and low pressure alarms, high and low temperature alarms, hydrocarbon presence alarms.
- Manual and automatically activated alarms shall be used to activate emergency actions on board.
- Detection and alarm systems on board are provided in accordance with the rules of the Fire Safety Systems code of the IMO as part of SOLAS statutory requirements for such as Regasification ships as approved by classification society and flag state.
- PA system: will be used to indicate the situation by means of verbal command.

7.2.5.3 ESD Alarms

- The ESD alarms from the FSRU or the facility automatically close the ESDV.
- For the Island Jetty, the Fire Alarm will have a 2ooN voting system for automatic ESD activation.
- After the initiation of shutdown systems, before resetting, the cause for the same needs to be ensured and the relevant checks need to be done.

7.2.5.4 Adverse weather / Rough Sea Condition Warnings³

- The FSRU mooring arrangement is being designed to withstand non-cyclonic environmental conditions. Cyclonic developments in the Bay of Bengal will be evaluated in adequate time and FSRU removed from Island Jetty to sea to ride out cyclones that threaten FSRU operations at the Island Jetty.
- All decisions to evacuate FSRU/LNGC shall be taken by Master of FSRU/LNGC in consultation with SPV Terminal Manager, relevant Ship Management Company and Kakinada Sea Ports Limited (KSPL).
- Evacuation will be Tug assisted.
- Detailed adverse weather response plan shall be developed and signed off by all concerned prior to arrival of FSRU at Island Jetty.

³ Note: This not an alarm, but more a protocol providing for certain actions to be made by the ship in the event of the probability for defined critical parameters being predicted by the various monitoring systems as will be established for the project with those systems for reference being sources via both public and privately contracted entities.

7.2.6 Key Emergency Response Teams

7.2.6.1 Incident Commander (IC)

The incident commander will be leading the response team until the emergency is totally brought under control. Incident Commander takes control of an incident and manages directly or appoints personnel to positions. She/he assumes control of the organization and maintains command with site personnel.

- Assess the situation
- Appoint, brief and task personnel
- Initiate Incident action plan (IAP)
- Manage emergency operations at the incident site
- Plan, execute, review and re-assess fire fighting operations continuously
- Maintain safe environment

For Island Jetty and the onshore facility, the Production Supervisor (during day time) is the IC. He/She will follow the notification protocol as mentioned in section. In the night time the Senior CRO will be the IC, till the Production Supervisor reaches the site.

For FSRU, the Master of the FSRU is the Incident Commander.

Depending on the magnitude of emergencies the appointment of Incident Commander may change to a different person in discussion with all entities involved in dealing with the incident. This decision will be based on expertise, experience, awareness of local regulations etc to ensure all entities i.e. SPV, , KSPL, local authorities integrate together.

7.2.6.2 Control Room Operator (CRO)

Two control room operator are always present (shift duty) in onshore facility control room. The operators would be responsible for monitoring the normal NG transfer from FSRU to the over the fence customer. His/her responsibilities include:

- The CRO's would be Emergency Duty Coordinators, or people who receive the first alert in case of an emergency
- Senior CRO acts as Incident Commander during night time till the production supervisor arrives at site
- Prompt Isolation of effected area of plant
- Aid in maintaining internal communication.

7.2.6.3 Facility Security Officer

- Any security incident will be guided by the Facility Security Officer, as detailed in the security plan.

7.2.6.4 Incident Command Post (ICP)

The Incident Command Post) comprises the Incident Commander and immediate staff, and may include other designated incident management officials and responders from State, local authorities, as well as private-sector, nongovernmental, and volunteer organizations.

The ICP is located at or in the immediate vicinity of the incident site and is the focus for the conduct of direct, on-scene control of tactical operations. Incident planning is also conducted at the ICP; an incident communications centre also would normally be established at this location. The ICP may perform local Emergency Operations Centre-like functions in the context of smaller jurisdictions or less complex incident scenarios.

ICP is expected to carry out following tasks:

- **Planning/Intelligence:** Gathers all information regarding the incident, it's impact on other parts of the process and it's possible evolution
- **Incident Operation:** Manages the practical aspects of incident control, implements the action plan, provides a practical input to it, establishes a structure of actors, identifies additional practical resources, relays current information regarding the incident back to the Incident Manager
- **Safety Advice:** Evaluates the adequacy of response to incident, advises the Incident Commander about response strategy and tactics.
- **Security Advice:** Evaluates the adequacy of response to incident, advises the Incident Commander about response strategy and tactics.
- **Logistics support:** Provides and maintains personnel, materials, facilities and services as and when requested by Incident Commander.
- **Inform and Coordinate with Country Crisis Management Team (CCMT).**

Company shall have designated and trained site personnel who will interact with press, public, govt. and media briefing during emergency. No employee or contractor would interact directly with above agencies without permission of ICP.

7.2.6.5 Onshore Receiving Facility and Island Jetty

- ICP lies with the Terminal Manger in case of an incident on the onshore receiving facility and the Island Jetty. The Key onshore team members that would coordinate (under ICP) in case of an emergency are:
 - Onshore Superintendent
 - Marine Superintendent
 - Facility Security officer
 - HSSE supervisor
 - Production Supervisor

7.2.6.6 FSRU

- In case, there is an emergency affecting the FSRU, the ICP is jointly held by the SPV Terminal Manger and the FSRU emergency response representative.

The Key FSRU team members and FSRU Operator support that would coordinate (under ICP) in case of an emergency are:

- Master FSRU or Second-in Command
- FSRU Operator Support Team (Consisting of Fleet Manager, Deputy Fleet Manager, Operations Superintendent, Engineering Superintendent additional support from FSRU Company)

7.2.6.7 Port Emergency Response Officer

In case, there is an emergency that requires the FSRU or the LNGC to leave the port, the port emergency response officer is communicated of the need for Tug boats. The Port ER officer will be responsible to communicate the need and ensure the Tugs arrive at the location of the LNGC and/or FSRU location in a timely manner to help the vessels in to the access channel.

The Port ER officer is also responsible to communicate any emergencies in the port to the facility Incident Commander to ensure proper actions are taken for the safety and operation of the facilities.

7.2.6.8 Mutual Aid / External Help Arrangements

As part of mutual aid scheme, SPV will align with neighbouring industries at Kakinada to share Emergency resources and equipment in case of serious crisis. However, the decision of seeking external assistance will be taken by duty manager on advice of ICP and CCMT. SPV would enter into mutual aid with nearby industries via District authorities and KSPL.

Table 7.2.1: Emergency Scenarios Identified for Proposed Project

S.No	Hazard category	Event	Facility*		To be captured in*	
			Island Jetty + FSRU	Onshore	Island Jetty + FSRU	Onshore
1	Climate Extremes	Tsunami;	✓	✓	Tsunami Response plan	Tsunami Response Plan
2		Cyclone;	✓	✓	Adverse weather plan	Adverse weather plan
3		Adverse Weather;	✓	✓		
4	Security Hazards	Fisherman	✓	✓	SPV Security Plan & FSRU Emergency Response Plan (ERP)	SPV Security Plan
5		Terrorist attack	✓	✓		
6	Man -Made Hazards	Lube & Diesel spill (onshore)		✓		Onshore ERP
7		SIMOPS		✓		SIMOPS procedure
8		Vessel Collision in shipping Channel-fog, poor visibility	✓		SPV ERP	
9		SIMOPS	✓		SIMOPS procedure	
10		Allison between LNGC & FSRU/Allison between FSRU & Island Jetty during berthing;	✓		FSRU Emergency Response Plan (ERP)	
11		FSRU/LNGC grounding due to moving in/out of the dredged areas;	✓		FSRU ERP will cover grounding. SPV ERP to cover grounding scenario, with interfaces with KSPL.	
12		Spill during bunkering	✓		FSRU ERP	
13		LNG spill (Cryogenic Hose parting)	✓		SPV ERP & FSRU ERP	

Contd...

Risk Assessment

Contd... Table 7.2.1

S.No	Hazard category	Event	Facility*		To be captured in*	
			Island Jetty + FSRU	Onshore	Island Jetty + FSRU	Onshore
14		Un ignited gas release;	✓		FSRU ERP	
15		Boat Capsize during transport of personnel	✓		FSRU ERP & SPV/Port ERP	
16		Effect of facility on surroundings	Ammonia Release from port	✓		FSRU ERP/SPV ER Response
17	Health & Safety	Road Transport Incidents		✓		ERP for Road Transport Emergencies
18		Un ignited gas release;		✓		Onshore ERP Plan
19		Medical emergencies		✓		Medical Emergency Response Procedure
20		Medivac from offshore	✓		FSRU ERP SPV medical emergency plan.	
21		Man-overboard	✓		FSRU ERP & SPV/Port ERP	
22	Fire	Fire in onshore facilities		✓		Fire Emergency Response Procedure
23		Electrical fire		✓		Onshore ERP
24		HP gas jet fires		✓		Fire Emergency Response Procedure
25		Fire on diesel storage tank ⁴		✓		
26		Fire in CCR ⁴		✓		
27		Fire in admin buildings ⁴		✓		
28	Fire in electrical substation ⁴		✓			


Contd...

⁴ RAM blue risk

Risk Assessment

Contd... Table 7.2.1

S.No	Hazard category	Event	Facility*		To be captured in*	
			Island Jetty + FSRU	Onshore	Island Jetty + FSRU	Onshore
29		Fire in workshop/warehouse ⁴		✓		
30		Fire on the vent ⁴		✓		
31		High pressure LNG fire/leak	✓			FSRU ERP covering the fire and Hydrocarbon leak scenarios
32		High pressure NG fire	✓			
33		Low pressure LNG fire/leak in LNGC	✓			
34		Low pressure vapour fire	✓			
35		Fire from HP arm impinging on other FSRU	✓			
36		Accommodation fire	✓			
37		Engine room fire ⁴	✓			FSRU ERP.
38		Electrical fire	✓			
39		LNG spill during STS	✓			FSRU ERP covering the fire and Hydrocarbon leak scenarios
40		Fire on the re-gas vent ⁴	✓			FSRU ERP.
41		Static electricity causing fire explosion during LNG transfer through flexi hoses;	✓			FSRU ERP covering the fire and Hydrocarbon leak scenarios



Revised Section 7.2 of Risk
Assessment Considering inputs
from Public Hearing

7.2 Approach to Disaster Management Plan

The purpose of Disaster Management Plan (DMP) is to provide a framework covering organizational setup responsibilities, actions, reporting requirements and resources needed to ensure effective and timely management of emergencies associated with the construction and operations of the proposed FSRU based LNG terminal at KDWP, Kakinada. project facilities.

7.2.1 Objectives

The overall objectives of DMP are:

- To minimize the potential damage to personnel, property, environment & ecology at protect site and in the surrounding vicinity in case of accident / disasters, emergency.
- To foresee, identify, assess and work out various kinds of possible hazards, their potential locations, damaging capacity and effected area in case of above events.
- To inform local authorities about emergency situation and have a mechanism to communicate with potentially affected surroundings.
- To coordinate with authorities including agencies that have role in the management of emergency (e.g. coast guard, hospitals, fire department, police etc.) in advance, and also at the time of actual emergency.
- Review, revise, redesign, replace or reconstruct the affected facilities as indicated by the assessments.
- Minimize the impact of the event on the installation and surrounding environment by:
 - Minimizing the hazard as far as possible
 - Minimizing the potential for escalation
 - Containing any release
- To provide necessary guidance to operational staff at project site, LNG carriers and the RLNG users to take appropriate actions to prevent accidents and to mitigate adverse effects of accidents that do nevertheless occur.

7.2.2 Phases of Disaster

Warning Phase

Many disasters are preceded by some sort of warning. For example, with the aid of satellites and network of weather stations, many meteorological disasters like cyclones and hurricanes can be monitored predicted in advance. Even the leaks of flammable hazardous material/ Natural Gas actions can be taken to eliminate/reduce the accidental/disaster damage

can be monitored through proper continuous monitoring system even at much lower concentrations than LFL level. Based on such monitoring results to counteract them.

Impact Phase

This is the period when the disaster actually strikes and very little can be done to lessen the effects of disaster. The period of impact may last for a few seconds (like fire, explosion, gas leak etc.) or may prolong for days (fire, gas leak, etc.). This is the time to bring the action plan in force.

The coordinators in organization structure will perform the responsibilities assigned to them. Needless to emphasize that prompt and well organized rescue operations can save valuable lives.

Rescue Phase

The rescue phase starts immediately after the impact and continues until necessary measures are taken to rush help and combat with the situation.

Relief Phase

In this phase, apart from organization and relief measures internally, depending on severity of the disaster, external help should also be summoned to provide relief measures (like evacuations to a safe place and providing medical help, food clothing etc.). This phase will continue till normalcy is restored.

Rehabilitation Phase

This is the final and longest phase. It includes estimating the damages, payment of compensation, rebuilding damaged property, etc. Help from revenue/insurance authorities need to be obtained to assess the damage, quantum of compensation to be paid etc.

7.2.3 Key Elements of DMP

Following are the key elements of Disaster Management Plan:

- Basis of the plan
- Accident/emergency response planning procedures
- Obtain early warning of emergency conditions so as to prevent impact on personnel, assets and environment
- Ensure safety of people, protect the environment and safeguard commercial considerations
- Immediate response to emergency scene with effective communication network and organized procedures
- On-site Disaster Management Plan
- Off-site Disaster Management Plan

- In order to handle disaster / emergency situations, an organizational chart entrusting responsibility to various personnel of the facility showing their specific roles should be available as shown in Fig. 7.2.1.
- The Disaster Management Plan also consists on-site and off-site emergency preparedness, emergency response plan.




Fig. 7.2.1: Disaster Control and Management System

7.2.4 Phases of Emergency

Following sequence to be followed in Major incident / accidental scenarios:

- **Raise Alarm:** A situation, which can potentially turn into a major incident which upon detection gets notified by precautionary monitoring system. This can be done either by raising an alarm manually or by automatic alarms which provide warning of the situation.
- **Assessment of Alarm:** Post the alarm, an assessment is made of the incident with respect to the location, source, type of incident, its severity and actions to be taken, which could include:
 - Isolating the source of incident, by controlling the scenario, i.e. isolation or emergency response. This could be done by eliminating or minimizing the causal factors which triggered the incident, or by initiating measures aimed at minimizing the consequences of an incident to project, People, Asset, Environment & Reputation.

- Escaping to a safe location, which is a pre-designated muster point, and Evacuating the facility if managing the situation is not possible as dictated by the situation and arranging for rescue of people.
- Recover and Normalize: After the incident is brought under control and secures necessary clearances, measures will be initiated to secure the area, to assess the damage, to clean up the site to ensure that the site would be brought to a state, where it can be assessed for restoration. During this process, the site would be made secure, and documentation prepared, which would include details of the incident, extent of damage etc. so that all facts concerning the incident, the response, are available. Some of the activities have to be done before clean up, while others would be done after clean up to ensure that an assessment can be made on the extent of measures needed for recommencement of operation.
- The proposed project design details cover a detailed emergency response strategy, which is described in the following section. The Emergency Response strategy considers linkages between the offshore facilities, i.e. Island Jetty, FSRU, LNG Carrier, and the Onshore Receipt Facility (ORF), as well as the linkages with which the project will have, i.e. Kakinada Sea Ports Limited (KSPL), the bulk consumers of Natural Gas etc. The plans shall be further developed, to consider required additional linkages with local administration, and surroundings to see how communication would happen in case of a major incident.
- The project would establish a competent Emergency Response and Crisis Management Team, who would take command of the situation depending on the categorization.
- Any major emergency planning, would consider two factors:
 - Impact within the project boundary
 - Impact outside the project boundaries
- Emergencies within the site boundary are managed by Incident Commander of the location, who is usually a representative of the project proponent. Any emergencies, which have an impact outside the site boundary, is administered by the district authority. Based on the safety assessments carried out as part of the project, it is envisaged that the credible major accident scenarios, would be contained at sea, and will not reach shore for any incident on the LNGC, FSRU and Island Jetty, and incident within the ORF would have its impact within the facility boundaries, not requiring an offsite emergency response plan.

7.2.5 Emergency Management Plan

The main objective of the Emergency Response Plan (ERP) during operation phase is to ensure that activities are carried out to the following priorities:

- Safeguard lives

- Protect the Environment
- Protect Company and all assets including third party assets
- Maintain the Company Image/Reputation
- Resume normal activities.

Personnel involved in dealing with emergency situations shall follow these priorities when making decisions and developing strategies.

7.2.5.1 Scope

The ERP covers the emergency response philosophy that needs to be applied to the facilities as an integrated operational entity. This integrated operational entity would cover the FSRU, Island Jetty and the onshore facility. The FSRU/LNGC will have their own a separate Emergency Response Procedure and any emergency on the FSRU/LNGC or affecting the FSRU/LNGC will be covered by the same. A HSSE bridging document shall be developed between the SPV and the FSRU to detail interfaces on a number of aspects including emergency response, which shall be used in conjunction with this document, as well as the Emergency Response Procedures of the FSRU and the vessel manager's emergency preparedness and response plans.

7.2.5.2 Emergency Response

Main objective of an Emergency Response Plan (ERP) is:

- Identify the source of emergency;
- Minimize the effects of the emergency on people and property.

The action that can successfully mitigate the effects of losses / emergencies need to be well planned, so that they would require less effort and resources to control and terminate emergencies, should the same occur. Formulation of an ERP is the first step in this process, and needs to be followed by development of a detailed ER procedure. This procedure shall be reviewed at periodic intervals and needs to be tested by holding of periodical mock emergency simulation and drill. Any shortcomings revealed during such exercise are thereafter required to be corrected by further training or making changes to the Emergency Response Plan. The procedure shall be reviewed and updated in the following circumstances, as a minimum:

- Major alteration or extension of Port, SPV facilities or pipeline.
- Major change in habitation or land use of the neighbourhood takes place.
- Change in Security threat perception;
- Change in the operating philosophy with the FSRU

As part of Emergency Response Strategy, the consequences of events for heat radiation contours for 6.3 kW/m^2 , correspond to Maximum radial distance areas where emergency actions lasting up to 30 seconds may be required by personnel without shielding but with appropriate clothing.

FSRU

The FSRU is a manned sea going LNG carrier, equipped with re-gasification and captive power generation modules on it. It receives LNG (liquid form at -161°C) from LNG carriers via cryogenic hoses, store it, re-gasify it and send RLNG (natural gas at pressure) to the onshore receiving facility via fixed unloading arms and subsea pipeline.

The FSRU is a standalone unit and would have its own emergency response systems. The only process link it has to the onshore facility is through the fixed NG discharge arms. In case of an emergency, if required, FSRU can unmoor and move away from the Island Jetty.

Security related Emergency Response of the FSRU would not be as independent as in the case of a moving ship as the dynamics of such incidents may be different, the FSRU being located at a port and co located with other activities and facilities. Also, it would be within the response plan of the port/SPV. The FSRU will be treated as a vessel and as such will have to maintain an International Ship and Port Security (ISPS) certificate based and a Ship Security Plan (SSP).

Island Jetty

The Island Jetty would be an unmanned installation, accessed by boats using the boat landing, and later stairs/monkey ladder to climb up. It is located approximately at a distance 2.5 km away from shore. It would have a high pressure NG unloading arm w.r.t hazardous chemicals (as per factory rules, LNG and Re-gasified natural gas are classified as Hazardous chemicals due to flammable properties). The current Operations & Maintenance (O&M) philosophy is to access the Island Jetty (8 hrs/day) by two Shore operators for the routine inspections and maintenances.

Sub-Sea Pipeline

From the Island Jetty the NG would be evacuated to shore via a sub-sea pipeline. This pipeline is proposed to be 3.8 km long and transfers the NG to the on-shore metering skid. It has provisions of isolation valve for safe isolation (Riser ESDV) and inlet ESDV at the onshore facility and would be designed for intelligent pigging to maintain integrity.

Onshore Receiving Facility (ORF)

The onshore receiving facility (ORF) would have a metering station/custody transfer with the customers. It is a manned location and the Central Control Room is located here. All the utilities required to support these units are located here. The facility also has a vent which will be used to vent gas during emergency depressurization of pipeline.

7.2.6 Temporary Refuge / Muster Points

7.2.6.1 FSRU and LNGC

The accommodation block on the FSRU is envisaged to act as the temporary refuge for all the people on the FSRU. Depending on Emergency situation, FSRU personnel will muster at different locations - fire control point. Primary Muster point is near the Fire Control Station (Main Deck), port side of the accommodation, main deck level. There are multiple pathways (each side plus up the stairs along trunk deck) are available for making escape towards the accommodation/muster point. Primary means of evacuation from the FSRU would be by lifeboats. Secondary means of evacuation would be via offshore side gangway, or via the Island Jetty. Life rafts would be the last option for evacuation.

The LNGC will follow its own protocol for Evacuation and muster; this will be in accordance to the Marine standards and as approved by their respective classification society and flag state.

7.2.6.2 Island Jetty

For the Island Jetty, no Temporary refuge has been developed and the personnel would use the boat landing on the send out platform or the extreme end of the mooring dolphin towards the shore side, and board the standby vessel. In an event that access to boat landing is not possible, and should the FSRU gangway access be clear, then they would go to FSRU muster location.

7.2.6.3 Onshore Receiving Facility (ORF)

In the onshore receiving facility, the muster points will be identified and the staff will choose the nearest one to them first and then follow the PA instruction, as given by the Incident Commander.

7.2.7 Emergency Guide for different Scenarios

7.2.7.1 Process Events

Upon detection of an event, the following should be considered in assessing the situation.

- Source and nature of the event, e.g. location of the event, size and type of a impact;
- Consequence of the event, i.e. determine whether ignition occurs or not;
 - If no ignition, conduct field assessment to ensure that ignition sources are isolated, e.g. ESD is initiated and that leak is being contained or dispersed to safe level;
 - If the event results in a fire or explosion, conduct damage assessment to determine the conditions of escape routes and platform structure. In addition, the potential for the event to escalate based on inventory isolated;

- Impact of the event to the Muster Station/Temporary Refuge (TR). Ensure no fire, smoke or gas is affecting the electrical systems.

If situation is under control and there is no potential for escalation, Incident Commander after confirming with Emergency Response Team (ERT) to declare situation under control and stand down. Recovery measures should then proceed. If situation is uncontrollable and further escalation occurs, Incident Commander can take relevant actions for escalation. During the emergency Incident Commander shall conduct field assessment and take appropriate action.

All affected personnel shall upon hearing alarm, proceed to Muster Station for headcount and await further instructions from Incident Commander.

7.2.7.2 Non Process Events

Upon discovery of a non process event (like medical emergencies), the following guide should be adopted,

- Provide immediate assistance to the injured, if safe to do so;
- Conduct field assessment to ensure integrity of escape routes and platform structure;
- Assess impact to the Process, i.e. leaks;
 - If the event lead to process impact;
 - If there is no impact to the process, Incident Commander to determine if Medivac is necessary.

If integrity of escape routes and structure is not affected and situation is under control, Incident Commander should declare situation under control and stand down. Recovery measures should then proceed. If situation is uncontrollable and further escalation occurs, Incident Commander can take relevant actions for escalation. During the emergency Incident Commander shall conduct field assessment and take appropriate action.

All affected personnel shall upon hearing alarm, proceed to Muster Station for headcount and await further instructions from Incident Commander.

7.2.7.3 Security Emergency

- Any security related incident shall be managed in accordance with the Security Manual. For the FSRU, the Ship Security Plan (& interface with Port Facility Security Plan, if any) shall be complied with. If the Island Jetty, is manned during a security incident on the FSRU, all personnel shall report to the FSRU, and act in accordance with the instructions of the FSRU Captain.
- There will be a need to accommodate the Port Facility Security Emergency Response plan. Therefore, this particular arrangement would further be dealt with more in detail in the related bridging document to be prepared subsequently

- Kakinada Deep Water Port is ISPS Code compliant and Port Security Plan will cover security arrangements within the port as a whole. Any breach of security within the port area shall be brought to the Port Facility Security Officer.
- In case of onshore, a security plan shall be developed, and all personnel shall act in accordance with the instructions of the Incident Command post.

7.2.7.4 Emergency Scenarios Identified

The major hazard scenarios for the project have been identified in the various exercises like HAZID and DSR. The scenarios identified for the proposed facilities are given in **Table 7.2.1**.

7.2.8 Alarms Systems

7.2.8.1 Onshore Facility and Island Jetty

- Fire Alarms: the fire alarms shall be located at all the places with a potential fire scenario. Also, automatic trip systems upon their detection might be installed. They shall be studied in the fire and gas mapping.
- Gas Alarms: Gas alarms shall be installed across all the locations with a potential to have a gas leak. The installation of automatic shutdown upon detection by these alarms shall be studied in details, depending upon the reliability of the gas detector and the scenario.
- All Clear siren: All clear siren shall be present to indicate all clear situation after an emergency.
- PA system: will be used to indicate the situation by means of verbal command.

7.2.8.2 Shipboard Emergency

- FSRU and the LNGC will be fitted with the necessary alarms in compliance with the regulations under which it is built and operated. These will include but not limited to fire alarms, gas alarms, high level alarms, high and low pressure alarms, high and low temperature alarms, hydrocarbon presence alarms.
- Manual and automatically activated alarms shall be used to activate emergency actions on board.
- Detection and alarm systems on board are provided in accordance with the rules of the Fire Safety Systems code of the IMO as part of SOLAS statutory requirements for such as re-gasification ships as approved by classification society and flag state.
- PA system: will be used to indicate the situation by means of verbal command.

7.2.8.3 ESD Alarms

- The ESD alarms from the FSRU or the facility automatically close the ESDV.

- For the Island Jetty, the Fire Alarm will have a 2ooN voting system for automatic ESD activation.
- After the initiation of shutdown systems, before resetting, the cause for the same needs to be ensured and the relevant checks need to be done.

7.2.8.4 Adverse weather / Rough Sea Condition Warnings

- The FSRU mooring arrangement is being designed to withstand non-cyclonic environmental conditions. Cyclonic developments in the Bay of Bengal will be evaluated in adequate time and FSRU removed from Island Jetty to sea to ride out cyclones that threaten FSRU operations at the Island Jetty.
- All decisions to evacuate FSRU/LNGC shall be taken by Master of FSRU/LNGC in consultation with SPV Terminal Manager, relevant Ship Management Company and Kakinada Sea Ports Limited (KSPL).
- Evacuation will be Tug assisted.
- Detailed adverse weather response plan shall be developed and signed off by all concerned prior to arrival of FSRU at Island Jetty.

7.2.9 Key Emergency Response Teams

7.2.9.1 Incident Commander (IC)

The incident commander will be leading the response team until the emergency is totally brought under control. Incident Commander takes control of an incident and manages directly or appoints personnel to positions. She/he assumes control of the organization and maintains command with site personnel.

- Assess the situation
- Appoint, brief and task personnel
- Initiate Incident action plan (IAP)
- Manage emergency operations at the incident site
- Plan, execute, review and re-assess fire fighting operations continuously
- Maintain safe environment

For Island Jetty and the onshore facility, the Production Supervisor (during day time) is the IC. He/ She will follow the notification protocol as mentioned in section. In the night time the Senior CRO will be the IC, till the Production Supervisor reaches the site.

For FSRU, the Master of the FSRU is the Incident Commander.

Depending on the magnitude of emergencies the appointment of Incident Commander may change to a different person in discussion with all entities involved in dealing with the incident.

This decision will be based on expertise, experience, awareness of local regulations etc to ensure all entities i.e. SPV, KSPL, local authorities integrate together.

7.2.9.2 Control Room Operator (CRO)

Two control room operator are always present (shift duty) in onshore facility control room. The operators would be responsible for monitoring the normal NG transfer from FSRU to the over the fence customer. His/her responsibilities include:

- The CRO's would be Emergency Duty Coordinators, or people who receive the first alert in case of an emergency
- Senior CRO acts as Incident Commander during night time till the production supervisor arrives at site
- Prompt Isolation of effected area of plant
- Aid in maintaining internal communication.

7.2.9.3 Facility Security Officer

- Any security incident will be guided by the Facility Security Officer, as detailed in the security plan.

7.2.9.4 Incident Command Post (ICP)

The Incident Command Post) comprises the Incident Commander and immediate staff, and may include other designated incident management officials and responders from State, local authorities, as well as private-sector, nongovernmental, and volunteer organizations.

The ICP is located at or in the immediate vicinity of the incident site and is the focus for the conduct of direct, on-scene control of tactical operations. Incident planning is also conducted at the ICP; an incident communications centre also would normally be established at this location. The ICP may perform local Emergency Operations Centre-like functions in the context of smaller jurisdictions or less complex incident scenarios.

ICP is expected to carry out following tasks:

- Planning/Intelligence: Gathers all information regarding the incident, it's impact on other parts of the process and it's possible evolution
- Incident Operation: Manages the practical aspects of incident control, implements the action plan, provides a practical input to it, establishes a structure of actors, identifies additional practical resources, relays current information regarding the incident back to the Incident Manager
- Safety Advice: Evaluates the adequacy of response to incident, advises the Incident Commander about response strategy and tactics.
- Security Advice: Evaluates the adequacy of response to incident, advises the Incident Commander about response strategy and tactics.

- Logistics support: Provides and maintains personnel, materials, facilities and services as and when requested by Incident Commander.
- Inform and Coordinate with Country Crisis Management Team (CCMT).

Company shall have designated and trained site personnel who will interact with press, public, govt. and media briefing during emergency. No employee or contractor would interact directly with above agencies without permission of ICP.

7.2.9.5 Onshore Receiving Facility and Island Jetty

- ICP lies with the Terminal Manger in case of an incident on the onshore receiving facility and the Island Jetty. The Key onshore team members that would coordinate (under ICP) in case of an emergency are:
 - Onshore Superintendent
 - Marine Superintendent
 - Facility Security officer
 - HSSE supervisor
 - Production Supervisor

7.2.9.6 FSRU

- In case, there is an emergency affecting the FSRU, the ICP is jointly held by the SPV Terminal Manger and the FSRU emergency response representative.

The Key FSRU team members and FSRU Operator support that would coordinate (under ICP) in case of an emergency are:

- Master FSRU or Second-in Command
- FSRU Operator Support Team (Consisting of Fleet Manager, Deputy Fleet Manager, Operations Superintendent, Engineering Superintendent additional support from FSRU Company)

7.2.9.7 Port Emergency Response Officer

In case, there is an emergency that requires the FSRU or the LNGC to leave the port, the port emergency response officer is communicated of the need for Tug boats. The Port ER officer will be responsible to communicate the need and ensure the Tugs arrive at the location of the LNGC and/or FSRU location in a timely manner to help the vessels in to the access channel.

The Port ER officer is also responsible to communicate any emergencies in the port to the facility Incident Commander to ensure proper actions are taken for the safety and operation of the facilities.

7.2.9.8 Mutual Aid / External Help Arrangements

As part of mutual aid scheme, SPV will align with neighbouring industries at Kakinada to share Emergency resources and equipment in case of serious crisis. However, the decision of seeking external assistance will be taken by duty manager on advice of ICP and CCMT. SPV would enter into mutual aid with nearby industries via District authorities and KSPL.

S.No	Hazard category	Event	Facility*		To be captured in*	
			Island Jetty + FSRU	Onshore	Island Jetty + FSRU	Onshore
1	Climate Extremes	Tsunami;	✓	✓	Tsunami Response plan	Tsunami Response Plan
2		Cyclone;	✓	✓	Adverse weather plan	Adverse weather plan
3		Adverse Weather;	✓	✓		
4	Security Hazards	Fisherman	✓	✓	SPV Security Plan & FSRU Emergency Response Plan (ERP)	SPV Security Plan
5		Terrorist attack	✓	✓		
6	Man -Made Hazards	Lube & Diesel spill (onshore)		✓		Onshore ERP
7		SIMOPS		✓		SIMOPS procedure
8		Vessel Collision in shipping Channel-fog, poor visibility	✓		SPV ERP	
9		SIMOPS	✓		SIMOPS procedure	
10		Allison between LNGC & FSRU/Allison between FSRU & Island Jetty during berthing;	✓		FSRU Emergency Response Plan (ERP)	
11		FSRU/LNGC grounding due to moving in/out of the dredged areas;	✓		FSRU ERP will cover grounding. SPV ERP to cover grounding scenario, with interfaces with KSPL.	
12		Spill during bunkering	✓		FSRU ERP	

Contd...

Contd... Table 7.2.1

S.No	Hazard category	Event	Facility*		To be captured in*	
			Island Jetty + FSRU	Onshore	Island Jetty + FSRU	Onshore
13		LNG spill (Cryogenic Hose parting)	✓		SPV ERP & FSRU ERP	
14		Un ignited gas release;	✓		FSRU ERP	
15		Boat Capsize during transport of personnel	✓		FSRU ERP & SPV/Port ERP	
16	Effect of facility on surroundings	Ammonia Release from port	✓		FSRU ERP/SPV ER Response	
17	Health & Safety	Road Transport Incidents		✓		ERP for Road Transport Emergencies
18		Un ignited gas release;		✓		Onshore ERP Plan
19		Medical emergencies		✓		Medical Emergency Response Procedure
20		Medivac from offshore	✓		FSRU ERP SPV medical emergency plan.	
21		Man-overboard	✓		FSRU ERP & SPV/Port ERP	
22	Fire	Fire in onshore facilities		✓		Fire Emergency Response Procedure
23		Electrical fire		✓		Onshore ERP
24		HP gas jet fires		✓		Fire Emergency

Contd...

Contd... Table 7.2.1

S.No	Hazard category	Event	Facility*		To be captured in*	
			Island Jetty + FSRU	Onshore	Island Jetty + FSRU	Onshore
25		Fire on diesel storage tank ¹		✓		Response Procedure
26		Fire in CCR1		✓		
27		Fire in admin buildings1		✓		
28		Fire in electrical substation1		✓		
29		Fire in workshop/warehouse1		✓		
30		Fire on the vent1		✓		
31		High pressure LNG fire/leak	✓			FSRU ERP covering the fire and Hydrocarbon leak scenarios
32		High pressure NG fire	✓			
33		Low pressure LNG fire/leak in LNGC	✓			
34		Low pressure vapour fire	✓			
35		Fire from HP arm impinging on other FSRU	✓			
36		Accommodation fire	✓			FSRU ERP.
37		Engine room fire1	✓			
38		Electrical fire	✓			
39		LNG spill during STS	✓			FSRU ERP covering the fire and Hydrocarbon leak scenarios

¹ RAM blue risk

S.No	Hazard category	Event	Facility*		To be captured in*	
			Island Jetty + FSRU	Onshore	Island Jetty + FSRU	Onshore
40		Fire on the re-gas vent1	✓			FSRU ERP.
41		Static electricity causing fire explosion during LNG transfer through flexi hoses;	✓			FSRU ERP covering the fire and Hydrocarbon leak scenarios

Accidental Scenarios – Damage Distances

This section includes the outcomes of Physical Effects Modelling done for various credible accident scenarios. Consequence effect modeling has been carried out for different hole sizes, release rates under accidental conditions.

Thermal Radiation damage distances corresponding to 37.5 kW/m², 12.5 kW/m² and 6.3kW/m² have been predicted. 37.5 kW/m² heat radiations can cause, damage to process equipment, as well as 100% lethality in 1 min. 12.5 kW/m² thermal radiation can have 1% lethality in 1 min. The personnel exposed to 6.3 kW/m² thermal radiation are very likely to be able to egress within 30 seconds from the area to other areas/evacuation routes, thereby giving them resistance to immediate impairment. It must be noted, that personnel on the site, will be wearing Personal Protective Equipment, and would have some endurance to these radiations to escape. Where applicable, consequence modelling results have been provided considering wind speeds of 2 & 5 m/s, with stability Class D, which represents neutral and stability Class F which indicates highly stable atmospheric conditions.

FSRU

The FSRU is nothing but a manned sea going LNG carrier, equipped with re-gasification and captive power generation modules. It receives LNG from LNG carriers via flexible Cryogenic hoses. There will be 10 (ten) no's flexible Cryogenic hoses for LNG handling. Eight (8) Hoses for LNG transfer to FSRU and two (2) Hoses for LNG vapour / gas return to LNGC. The operational design parameters of LNG handling are:

- Each hoses diameter: 8" (200mm)
- LNG pumping pressure: 4.5 bar(g)
- LNG temperature: -161°C
- LNG Density :435.31 Kg/m³
- LNG molecular weight:16.72 Kgmol
- LNG Flow rate:1000 m³/h/hose

Different scenarios have been simulated for the LNGC, FSRU in Physical Effects modeling. Three credible major accident scenarios are presented in this section:

LNG Leak (Cryogenic hose parting): The credible major accident event is considered as a release of sub cooled LNG liquid from the Ship to Ship (STS) transfer hoses, during offloading LNG from carrier. The Physical Effects model Results for Pool Fire and Jet Fire Scenario, considering the above process conditions are as follows:

Pool Fire:

Hole Size	Wind Speed + Stability	Pool Diameter (m)	Thermal Radiation kW/m ²		
			37.5	12.5	6.3
			Max. Downwind Distance (m)		
70mm	D05	10.5	48.8	75.7	96.2
70mm	D02	10.5	35.7	66.0	90.5
70mm	F02	10.5	36.8	66.0	89.8
150mm	D05	10.9	49.6	78.2	99.4
150mm	D02	10.9	36.7	68.2	92.9
150mm	F02	10.9	36.7	68.2	92.1

The above Physical Effects Modeling results show that any personnel in the immediate adjacent areas of the release are likely to be affected by the initial release. The subsequent release, after pump shutdown will have a significantly smaller effect zone and such longer releases will be in the form of a pool. The most likely release locations are the loading hoses connecting deck area or the sea water at FSRU /Jetty (Harbour area). The loading hose area has a bounded drip tray constructed of stainless steel with the option to drain to re-gasification. Subsequently, a release here should have little potential to escalate out with this area. Explosion overpressures associated with such LNG handling are expected to be negligible due to the open nature of the facilities. There is a cryogenic threat to the personnel on the leaks at FSRU/LNGC within the immediate area of this release but this cryogenic threat should not affect those in vicinity areas.

Jet Fire (LNG):

Hole Size	Flame Length (m)	Thermal Radiation (kW/m ²).		
		37.5	12.5	6.3
		Max. Downwind Distance (m)		
07mm	9.2	11.9	14.3	16.6
22mm	22.9	31.1	37.9	44.9

After LNG re-gasification release of High Pressure Natural Gas (NG) at FSRU/ Hard arms on Jetty:

The credible major accident scenario associated with High Pressure Natural Gas emanate from the piping flanges, valves and fittings, associated with the send out pipe work immediately upstream of the send out arms ESDVs. The design parameters during operation Phase for sending out re-gasified (pure) natural gas from FSRU vaporizer to the HP arms are as follows:

- Natural Gas temperature: 5°C
- Natural Gas density: 119.46 kg/m³
- Molecular weight : 16.72 kg/mol
- Pipe Diameter: 8" (203.2 mm)
- Pressure : 105 bar(g)
- Natural Gas Flow rate: Peak/Max. 21 MMSCMD (243 M³/sec)

Results for Jet Fire Scenario, considering the above process parameters are given below:

Jet Fire (High pressure RLNG):

Hole Size	Flame Length (m)	Thermal Radiation (kW/m ²).		
		37.5	12.5	6.3
		Max. Downwind Distance (m)		
7mm	11.3	12.4	13.4	14.8
22mm	28.3	31.6	35.1	39.1
70mm	71.6	81.9	91.3	103.3
150mm	132.0	152.2	173.1	196.5

The above result of Physical Effects Modeling show that any personnel in the immediate area of the release and adjacent areas are likely to be affected by the initial release. Initial jet fires will be very large due to the high pressure. Explosion overpressures associated with such a release are expected to be negligible due to the open nature of the facilities.

Pressure (barg)	Temperature (degC)	Density (kg/m ³)	MW (kg/mol)
109	-145.79	425.56	16.73

Pool Fire:

Hole Size	Wind Speed + Stability	Pool Diameter (m)	Thermal Radiation (kW/m ²)		
			37.5	12.5	6.3
			Max. Downwind Distance (m)		
70mm	D05	10.9	49.6	78.2	99.4
70mm	D02	10.9	36.7	68.2	92.9
70mm	F02	10.9	36.7	68.2	92.1

Hole Size	Wind Speed + Stability	Pool Diameter (m)	Thermal Radiation (kW/m ²)		
			37.5	12.5	6.3
			Max. Downwind Distance (m)		
150mm	D05	10.9	49.6	78.2	99.4
150mm	D02	10.9	36.7	68.2	92.9
150mm	F02_	10.9	36.7	68.2	92.1

Jet Fire:

Hole Size	Flame Length (m)	Thermal Radiation 37.5 kW/m ²		
		37.5	12.5	6.3
		Max. Downwind (m)		
7mm	17.3	19.9	22.0	24.8
22mm	43.3	51.0	57.3	65.6

7mm and 22mm sizes modelled as liquid pools.

The outcomes of the Physical Effects Modeling show that Anyany personnel in the immediate area of the release and adjacent areas are likely to be affected by the initial release. The subsequent release, after pump shutdown will have a significantly smaller effect zone and these longer releases will be in the form of a pool. Most pool fires will be unable to impinge on the TR structure. Explosion overpressures associated with such a release are expected to be low due to the open nature of the facilities. There is a cryogenic threat to any personnel on the FSRU within the immediate area of this release but this cryogenic threat should not affect those in adjacent areas.

Island Jetty

The Island Jetty would be an unmanned installation, accessed by boats using the boat landing, and later stairs/monkey ladder to climb up. It is located approximately at a distance 2.5 km away from shore. It would have a high pressure NG unloading arm w.r.t hazardous chemicals (as per factory rules, LNG and Re-gasified natural gas are classified as Hazardous chemicals due to flammable properties). The current Operations & Maintenance (O&M) philosophy is to access the Island Jetty (8 hrs/day) by two Shore operators for the routine inspections and maintenances.

The credible major accident event is considered as a releases associated with Island Jetty emanate from the pipework, flanges, valves and fittings on the island jetty between the send out arms and the send out pipeline. Results for Jet Fire Scenario, considering the following process conditions are given below:

Pressure (bar(g))	Temperature (deg C)	Density (kg/m ³)	MW (kg/mol)
82.5	14	78.92	16.73

Jet Fire:

Hole Size	Flame Length (m)	Thermal Radiation kW/m ²		
		37.5	12.5	6.3
		Max. Downwind Distance (m)		
7mm	9.8	10.7	11.5	12.7
22mm	24.6	27.3	29.9	33.4
70mm	62.2	70.4	79.1	88.5
150mm	115.4	132.8	149.4	169.2

The outcomes of Physical Effects Modelling, show that any personnel in the immediate area of the release and adjacent areas are likely to be affected by the initial release. Initial jet fires will be very large due to the high pressure. This is particularly the case for the larger releases which potentially can impact depending on the directionality of the jet. However, the fire size will rapidly decrease. Explosion overpressures associated with such a release are expected to be negligible due to the open nature of the facilities.

Sub-Sea Pipeline

From the Island Jetty the NG would be evacuated to shore via a sub-sea pipeline. This pipeline is proposed to be 3.8 km long and transfers the NG to the on-shore metering skid. It has provisions of isolation valve for safe isolation (Riser ESDV) and inlet ESDV at the onshore facility and would be designed for intelligent pigging to maintain integrity.

The credible major accident event is considered as a release from the high pressure send out riser and pipeline. Results for Jet Fire Scenario, considering the following process conditions are given below:

Pressure (bar(g))	Temperature (deg C)	Density (kg/m ³)	MW (kg/mol)
81	14	77.22	16.73

Jet Fire:

Hole Size	Flame Length (m)	Thermal Radiation kW/m ²		
		37.5	12.5	6.3
		Max. Downwind (m)		
150mm	28.2	47.7	61.3	101.9

Pool Fire:

Hole Size	Wind Speed + Stability	Pool Diameter (m)	Thermal Radiation (kW/m ²)		
			37.5	12.5	6.3
			Max. Downwind (m)		
7mm	D05	4.2	6.0	11.6	14.8
7mm	D02	4.2	4.9	10.8	14.1
7mm	F02	4.2	4.9	10.8	14.1
22mm	D05	7.5	14.9	23.5	30.0
22mm	D02	7.5	11.7	21.8	28.8
22mm	F02	7.5	11.7	21.8	28.8
70mm	D05	13.1	28.3	43.3	55.6
70mm	D02	13.1	22.7	40.3	53.5
70mm	F02	13.1	22.7	40.3	53.5

Note: The pool fire scenarios mentioned here are not liquid pools, but bubbling gas pools due to Loss of Containment events on subsea pipeline.

The outcomes of Physical Effects Modelling indicate that the possibility of personnel on the island jetty becoming immediate fatalities is high given the release rates and potential fire sizes. However, it is likely that personnel not immediately affected by the initial release should be able to make their way to the boat landing area given the dual escape ways and because the length of the jetty means that personnel at the boat landing should be sufficiently faraway from high levels of thermal radiation. Explosion overpressures associated with such a release are expected to be negligible due to the open nature of the facilities.

On – shore Receiving Facility (ORF)

The on-shore facility would have a metering station/custody transfer with the customers. It is a manned location and the Central Control Room is located here. All the utilities required to support these units are located here. The facility also has a vent which will be used to vent gas during the maintenance of the pipeline as well as for emergency depressurization.

The credible major accident event is considered as a jet fire emanating from the flanges, valves or fittings associated with the onshore gas metering skid. Results for Jet Fire Scenario, considering the following process conditions are given below:

Pressure (bar(g))	Temperature (deg C)	Density (kg/m ³)	MW (kg/mol)
80	14	76.09	16.73

Hole Size	Flame Length (m)	Thermal Radiation kW/m ² ,		
		37.5	12.5	6.3
		Max. Downwind (m)		
7mm	9.7	10.6	11.5	12.4
22mm	24.4	27.1	29.9	33.0
70mm	61.7	69.7	78.3	88.5
150mm	113.7	129.9	146.2	166.4

Jet Fire:

Fire Analysis: The outcomes of Physical Effects Modelling, show that other than the potential for personnel in the immediate area of the release and adjacent areas to be affected by the initial release, there should be little threat to any other equipment or structures on the onshore facility due to the separation distance between them (distance varies depending on release location). Anyone not in the immediate area should be able to escape to a place of safety. Due to open nature of facilities, explosion overpressures are expected to be negligible.

