






<p>98-02 F. 6460/2017</p>	<p>Proposed construction of Residential & Commercial group development by M/s. Vallal RCK at S.F.No: 133/1A, 134/2, 136/1, 136/2A, 136/2B, 137, 138, 139, 140, 141/1A1, 141/1B & 141/2 of kolathuvanchery Village, Sriperambudur Taluk, Kancheepuram District, Tamilnadu – Activity 8(a) & Category “B2”- Building & Construction Projects -Environmental Clearance- Regarding</p>
	<p>The Proponent, M/s. Vallal RCK has applied for Environmental Clearance for the proposed construction of Residential & Commercial group development with built up area of 70826.868 Sq.m at S.F.No: 133/1A, 134/2, 136/1, 136/2A, 136/2B, 137, 138, 139, 140, 141/1A1, 141/1B & 141/2 of Kolathuvanchery Village, Sriperambudur Taluk, Kancheepuram District, Tamilnadu on 31.10.2017.</p> <p>The proposal was placed in the 98th meeting held on 28.11.2017. Based on the presentation made by the proponent and the documents furnished, the SEAC decided to recommend the proposal for grant of EC to SEIAA subject to usual conditions after obtaining the following details:</p> <ol style="list-style-type: none"> 1. The proponent was asked to furnish the application submitted to the competent authorities for ground water withdrawal of 382 KLD. 2. The proponent was asked to furnish permission letter/application for 152 KLD treated waste water disposal to metro water pumping station/ Porur STP/Nesapakkam STP 3. Water balance chart to be revised to indicate the waste water streams contributing to the STP capacity. Treatment plant capacity is grossly inadequate to handle the waste water generated in the residential complex. 4. The proponent was asked to provide oil and grease trap in the STP. 5. Since common water treatment plant is provided, individual drinking water treatment units need not have RO units. 6. The storm water drains should be provided with silt traps before final


MEMBER SECRETARY, SEAC


CHAIRMAN, SEAC



Minutes of the 98th SEAC Meeting held on 28th November 2017

<p>discharge into the adjoining Nallah.</p> <p>7. The proponent is required to provide a house hold hazardous waste / E-waste collection and disposal mechanism.</p> <p>8. The proponent was asked to provide total area allocated for solid waste management within the premises for activity such as curing the waste from OWC, sorting the recyclable waste, storing, etc.</p> <p>9. Details of flood occurrence and also certificate stating that the proposed site had not encroached any water body (rivers, canals, lakes, ponds, tanks, etc) from its original boundary shall be obtained from the competent authority.</p> <p>10. Details of any other natural drainage like canal, channel, stream if any flowing through or adjacent to the project site and its confluence point with areal distance from the boundary.</p> <p>11. An amount of Rs. 71 Lakhs shall be spent for infrastructure development activities for nearby government schools as a part of CSR.</p>			
S.No	Name	Designation	Signature
1	Dr. K. Thanasekaran	Member	
2	Dr. A. Navaneetha Gopalakrishnan	Member	
3	Dr.K.Valivittan	Member	
4	Dr.Indumathi M. Nambi	Member	
5	Dr. G. S. Vijayalakshmi	Member	
6	Dr. M. Jayaprakash	Member	
7	Shri V. Sivasubramanian	Member	
8	Shri V. Shanmugasundaram	Member	


MEMBER SECRETARY, SEAC


CHAIRMAN, SEAC

Minutes of the 98th SEAC Meeting held on 28th November 2017

9	Shri B. Sugirtharaj Koilpillai	Member	
10	Shri. P. Balamadeswaran	Co-opt Member	
11	Shri. M.S. Jayaram	Co-opt Member	


MEMBER SECRETARY, SEAC


CHAIRMAN, SEAC