

Minutes of the 91st SEAC Meeting held on 16th June 2017

<p>91-18 F.5571</p>	<p>Proposed construction of Residential building “M/S. Vasathi Homes Pvt. Ltd.,” at Old No.132 (Part), 139-1, T.S.No. 15/2-2, 15/4-2/2, 15/4-1, Athipattu Village, Ambattur Taluk, Thiruvallur District, Tamilnadu – Category “B2”-8(a) Building & Construction Projects -Environmental Clearance- Regarding</p>
	<p>The Proponent of, “M/s. Vasathi Homes Pvt. Ltd.,” has applied for Environment Clearance for the proposed construction of Residential building with built up area of 20557.54 Sq.m. at Old No.132 (Part), 139-1, T.S.No. 15/2-2, 15/4-2/2, 15/4-1, Athipattu Village, Ambattur Taluk, Thiruvallur District, Tamilnadu on 22.07.2016.</p> <p>The proposal was placed in the 91st meeting of the SEAC held on 16.06.2017. Based on the presentation made by the proponent and the documents furnished, the SEAC decided to recommend the proposal for the grant of EC to SEIAA, subject to the following specific conditions in addition to the normal conditions.</p> <ol style="list-style-type: none"> 1. It is proposed to use the ground water at the project site as the source of water supply for the residents of the project once project comes into operation. The quality of ground water from the bore well as such is not suitable for drinking purposes. Hence, the proponent should implement measures to make the water to suit the quality prescribed for drinking as per standards. 2. In addition to the use of treated sewage (5 KLD) for Green Belt Development, 3.3 KLD should be made use for OSR landscape maintenance. The Project Proponent should also revise the water balance diagram by adopting 90% conversion from water to sewage in the case of domestic purposes. After this revision, a maximum of 52 KLD should be taken to the Koyembedu STP. 3. Excess storm water if any from the project site should be drained by providing a connecting storm water drain from the project site to the existing drain along the Vanagaram – Ambattur road. 4. The Athipattu Municipal solid waste dump site is about 1Km away. It will pose odour and dust problem to the prospective residents. Hence, the proponent should ensure that odour and

Minutes of the 91st SEAC Meeting held on 16th June 2017

	<p>dust problems are eliminated once the project becomes operation. Tall growing trees should be planted in suitable number in order to minimize these problems.</p> <p>5. As part of the corporate social responsibility activity, in addition to the commitment by the proponent to the government school in Athipattu (Rs. 20 Lakhs) for establishment of state of art knowledge centre, the proponent should provide fund for Pallikaranai Marsh Conservation Authority to the tune of Rs. 10 Lakhs in one instalment before commencement of the construction and send the copy of the receipt to SEIAA.</p>
--	--

S.No	Name	Designation	Signature
1	Dr. K. Thanasekaran	Member	
2	Dr. A. Navaneetha Gopalakrishnan	Member	
3	Dr.K.Valivittan	Member	
4	Dr.Indumathi M. Nambi	Member	
5	Dr. G. S. Vijayalakshmi	Member	
6	Dr. M. Jayaprakash	Member	
7	Shri V. Sivasubramanian	Member	
8	Shri V. Shanmugasundaram	Member	
9	Shri B. Sugirtharaj Koilpillai	Member	
10	Shri. P. Balamadeswaran	Co-opt Member	
11	Shri. M.S. Jayaram	Co-opt Member	

Member-Secretary, SEAC


Chairman, SEAC