

**Minutes of the 509th Meeting of the State Level Environment Impact
Assessment Authority, UP (SEIAA) held on 03.11.2021**

The meeting of 509th State Level Environment Impact Assessment Authority, UP (SEIAA) was held on 03.11.2021 at the Directorate of Environment. The following were present in the meeting:-

- | | |
|----------------------------------|-------------------------------------|
| 1. Dr. Rajiv Kumar Garg | Chairman, SEIAA, U.P |
| 2. Shri Paras Nath | Member, SEIAA, U.P |
| 3. Shri Ajay Kumar Sharma | Member Secretary, SEIAA, U.P |

Minutes of 588th SEAC-1 Meeting Dated 02/11/2021

- 1. Proposed Project “Maha Yogi Guru GorakhnathAyush University” at Village-pipri&tarkulha, (PipriKhata no- 296, 295, 06, 28, 435 &Tarkulhakhata no- 272, 10, 273), District-Gorakhpur, U.P. M/s Regional Ayurvedic and Unani Department, Gorakhpur File No. 6656/Proposal No. SIA/UP/MIS/236269/2021**

SEIAA noted that since being a Government importance project the separate minutes of the project proposal has been sent to SEIAA for necessary action. SEIAA agreed with the recommendations of the SEAC to grant the prior Environmental Clearance to the proposed project along with all the general and specific conditions as suggested by the SEAC. In addition to the conditions imposed by SEAC the SEIAA added following additional specific conditions:-

- 1- The project proponent shall submit within the next 3 months the details of solar power plant and solar electrification details within the project.
- 2- The project proponent shall ensure to plant broad leaf trees and their maintenance. The CPCB guidelines in this regard shall be followed.
- 3- The project proponent shall submit within the next 3 months the details on quantification of year wise CER activities along with cost and other details. CER activities must not be less 2% of the project cost. The CER activities should be related to mitigation of Environmental Pollution and awareness for the same.
- 4- The project proponent shall submit within the next 3 months the details of estimated construction waste generated during the construction period and its management plan.
- 5- The project proponent shall submit within the next 3 months the details of segregation plan of MSW.
- 6- The project proponent shall ensure that waste water is properly treated in STP and maximum amount should be reused for gardening flushing system and washing etc. For reuse of water for irrigation sprinkler and drip irrigation system shall be installed and maintained for proper

Minutes of 571st SEAC-2 Meeting Dated 16/09/2021

- function. Part of the treated sewage, if discharged to sewer line, shall meet the prescribed standards for the discharge.
- 7- Under any circumstances untreated sewage shall not be discharged to municipal sewer line.
 - 8- The project proponent will ensure that proper dust control arrangements are made during construction and proper display board is installed at the site to inform the public the steps taken to control air pollution as per the Construction and Demolition Waste Management Rules.
 - 9- The project proponent shall install micro solar power plants, toilets in nearby villages, public place or school from CER fund of the project for which E.C is granted in addition to and water harvesting pits and carbon sequestration parks / designed ecosystems.
 - 10- A certificate from Forest Department shall be obtained that no forest land is involved and if forest land is involved the project proponent shall obtain forest clearance and permission of Central and State Government as per the provisions of Forest (conservation) Act, 1980 and submit before the start of work.
 - 11- If the proposed project is situated in notified area of ground water extraction, where creation of new wells for ground water extraction is not allowed, requirement of fresh water shall be met from alternate water sources other than ground water or legally valid source and permission from the competent authority shall be obtained to use it.

(Ajay Kumar Sharma)
Member-Secretary
SEIAA

(Paras Nath)
Member
SEIAA

(Dr. Rajiv Kumar Garg)
Chairman
SEIAA