








Minutes of the 98th SEAC Meeting held on 28th November 2017

<p>98-03 F.6465</p>	<p>Proposed construction of Residential building by M/s. Dawning Developers LLP at S.F.No: 122/2A, 122/2B, 123/1B, 123/2B, 123/1A2, 123/2A2, 123/1C1 pt, 123/2C1, 123/1C2, 123/2C2, 123/2C3 pt, 123/2D pt, 123/1 pt (subdivide as 123/1A1) & 123/2 pt (subdivide as 123/2A1), 135/2A, 35/2B, 123/1C (T.S.NO. 9/6, 9/7, 11/1, 11/4, 11/5, 11/6, 11/7, 11/9, 11/10, 12/5 & 12/6) of Athipattu Village, Ambattur Taluk, Thiruvallur District, Tamilnadu – Activity 8(a) & Category “B2”- Building & Construction Projects - Environmental Clearance- Regarding</p>
	<p>The Proponent, M/s. Dawning Developers LLP has applied for Environmental Clearance for the proposed construction of Residential building with built up area of 80329.37 Sq.m at S.F.No: 122/2A, 122/2B, 123/1B, 123/2B, 123/1A2, 123/2A2, 123/1C1 pt, 123/2C1, 123/1C2, 123/2C2, 123/2C3 pt, 123/2D pt, 123/1 pt (subdivide as 123/1A1) & 123/2 pt (subdivide as 123/2A1), 135/2A, 35/2B, 123/1C (T.S.No. 9/6, 9/7, 11/1, 11/4, 11/5, 11/6, 11/7, 11/9, 11/10, 12/5 & 12/6) of Athipattu Village, Ambattur Taluk, Thiruvallur District, Tamilnadu on 14.11.2017.</p> <p>The proposal was placed in the 98th meeting held on 28.11.2017. Based on the presentation made by the proponent and the documents furnished, the SEAC decided to recommend the proposal for grant of EC to SEIAA subject to usual condition after obtaining the following details;</p> <ol style="list-style-type: none"> 1. The proponent is required to provide a house hold hazardous waste / E-waste collection and disposal mechanism. 2. The proponent was asked to provide total area allocated for solid waste management within the premises for activity such as curing the waste


Member-Secretary, SEAC


Chairman, SEAC

Minutes of the 98th SEAC Meeting held on 28th November 2017

	<p>from OWC, sorting the recyclable waste, storing, etc.</p> <p>3. Water balance chart to be revised to indicate the waste water streams contributing to the STP capacity. Treatment plant capacity is grossly inadequate to handle the waste water generated in the residential complex.</p> <p>4. Details of flood occurrence and also certificate stating that the proposed site had not encroached any water body (rivers, canals, lakes, ponds, tanks, etc) from its original boundary shall be obtained from the competent authority.</p> <p>5. Details of any other natural drainage like canal, channel, stream if any flowing through or adjacent to the project site and its confluence point with areal distance from the boundary.</p> <p>6. An amount of Rs. 91 Lakhs shall be spent for infrastructure development activities for nearby government schools as a part of CSR before the completion of the project.</p>		
S.No	Name	Designation	Signature
1	Dr. K. Thanasekaran	Member	
2	Dr. A. Navaneetha Gopalakrishnan	Member	
3	Dr.K.Valivittan	Member	
4	Dr.Indumathi M. Nambi	Member	
5	Dr. G. S. Vijayalakshmi	Member	
6	Dr. M. Jayaprakash	Member	
7	Shri V. Sivasubramanian	Member	
8	Shri V. Shanmugasundaram	Member	
9	Shri B. Sugirtharaj Koilpillai	Member	
10	Shri. P. Balamadeswaran	Co-opt Member	


Member-Secretary, SEAC


Chairman, SEAC

Minutes of the 98th SEAC Meeting held on 28th November 2017

11	Shri. M.S. Jayaram	Co-opt Member	
----	--------------------	---------------	--


Member-Secretary, SEAC


Chairman, SEAC