

**Minutes of the 765<sup>th</sup> Meeting of the State Level Environment Impact Assessment Authority, UP (SEIAA) held on 21-10-2023 Part (B)**

The meeting of 765<sup>th</sup> State Level Environment Impact Assessment Authority, UP (SEIAA) was held on-line on 21.10.2023 the Directorate of Environment. The following were present in the meeting:-

1. Smt. Mamta Sanjeev Dubey
2. Shri Paras Nath
3. Shri Ajay Kumar Sharma

Chairman, SEIAA, U.P  
Member, SEIAA, U.P  
Member Secretary, SEIAA, U.P

**Agenda-A- Minutes of 797th SEAC-2 Meeting Dated 12/10/2023**

1. **Construction of Residential and Non-residential Buildings of Police Line Amethi Village- Pachehri, Tehsil- Gauriganj, District -Amethi, U.P., File No. 8336/Proposal No. SIA/UP/INFRA2/447075/2023.**

In light of discussion held in SEIAA meeting no. 597 dated 05.05.2022. SEIAA opined to accept the recommendation of SEAC and grant EC to the said project along with all the general and specific conditions as suggested by SEAC. In addition to the conditions imposed by SEAC, SEIAA added following additional specific conditions:-

- 1- The project proponent shall submit within the next 3 months the details of solar power plant and solar electrification details within the project.
- 2- The project proponent shall ensure to plant broad leaf trees and their maintenance. The CPCB guidelines in this regard shall be followed.
- 3- The project proponent shall submit within the next 3 months the details on quantification of year wise CER activities along with cost and other details. CER activities must not be less 2% of the project cost. The CER activities should be related to mitigation of Environmental Pollution and awareness for the same.
- 4- The project proponent shall submit within the next 3 months the details of estimated construction waste generated during the construction period and its management plan.
- 5- The project proponent shall submit within the next 3 months the details of segregation plan of MSW.
- 6- The project proponent shall ensure that waste water is properly treated in STP and maximum amount should be reused for gardening flushing system and washing etc. For reuse of water for irrigation sprinkler and drip irrigation system shall be installed and maintained for proper function. Part of the treated sewage, if discharged to sewer line, shall meet the prescribed standards for the discharge.
- 7- Under any circumstances untreated sewage shall not be discharged to municipal sewer line.



- 8- The project proponent will ensure that proper dust control arrangements are made during construction and proper display board is installed at the site to inform the public the steps taken to control air pollution as per air act 1981 (as amended) and the Construction and Demolition Waste Management Rules, CAQM guidelines.
- 9- The project proponent shall install micro solar power plants
- 10- The project proponent shall install micro solar power plants, toilets in nearby villages, public place or school from CER fund of the project for which E.C is granted in addition to and water harvesting pits and carbon sequestration parks / designed ecosystems.
- 11- A certificate from Forest Department shall be obtained that no forest land is involved and if forest land is involved the project proponent shall obtain forest clearance and permission of Central and State Government as per the provisions of Forest (conservation) Act, 1980 and submit before the start of work. If the proposed project is situated in notified area of ground water extraction, where creation of new wells for ground water extraction is not allowed, requirement of fresh water shall be met from alternate water sources other than ground water or legally valid source and permission from the competent authority shall be obtained to use it.
- 12- Provision for charging of electric vehicles as per the guidelines of GoI / GoUP should be submitted within the next 3 months.
- 13- PP should display EC granted to them on their website. 6-monthly compliance report should be displayed on their website and to be given every six month to residents / occupants of the building.
- 14- EC is granted with the condition that EC is valid only for the building plan which has been submitted by PP for seeking EC. In case approved building plan is different from the one submitted for seeking EC then this EC will stand null and void.

**Nodal Officer**

**SEIAA, UP**

MoM prepared by Secretariat in consultation with  
Chairman & Members on the basis of decisions  
taken by SEIAA during the meeting.



**(Smt. Mamta Sanjeev Dubey)**  
**Chairman**  
**SEIAA**

**(Ajay Kumar Sharma)**  
**Member-Secretary**  
**SEIAA**

**(Paras Nath)**  
**Member**  
**SEIAA**