# **ANNEXURE**

| Sr No | Description                                      | Page No |
|-------|--------------------------------------------------|---------|
| 5     | Prefeasibility Report                            | 1       |
| 6     | Location Map                                     | 6       |
| 7     | Layout of Factory Premises                       | 7       |
| 8     | Aerial Photographs                               | 8       |
| 9     | Manufacturing Process of Chemicals with material | 10      |
|       | Balance and flow sheets                          |         |
| 10    | Water Budget                                     | 28      |
| 11    | Energy Budget                                    | 29      |
| 12    | 10 KM Radius Map                                 | 30      |
| 13    | Environmental Status Report                      | 31      |
| 14    | Summery                                          | 44      |

#### 6. 1. Project Proponent & Background

Somaiya group is one of the old and well-established industrial houses in India with diversified interests in:

- a. Sugar (white and refined)
- b. Alcohol and Bulk Organic Chemicals
- c. Specialty Chemicals
- d. Printing and Publishing
- e. Education & Social welfare

#### a. Sugar and its by Products

i) The Godavari Sugar Mills Limited

Sugar Plant

Location:

Sameerwadi, Dist. Bagalkot, State: Karnataka

Capacity: 7,500 TCD and propose to expand to 15,000 TCD

Average Sugar production 1,60,000 MT per annum at present and shall be 3,20,000 MT per annum after expansion.

Co-generation Power plant (Renewable Energy)

Location:

Sameerwadi, Tal Mudhol, Dist. Bagalkot, State: Karnataka

Installed Capacity: 24 MW (1<sup>st</sup> stage) and 40 MW (II<sup>nd</sup> Stage). Total capacity after expansion is 64 MW.

ii) K.J. Somaiya Institute of Applied Agricultural Research (KIAAR).

Location: Sameerwadi, Dist. Bagalkot, State: Karnataka.

Established with the objective of doing basic research in promoting early maturing & high yielding sugarcane varieties and propagating modern and scientific agricultural practices.

#### b. Alcohol and Bulk organic chemicals

i. Somaiya Organo Chemicals.

(A Unit of The Godawari Sugar Mills Ltd.)

Location:

Sakarwadi, Tal Kopargaon, Dist. Ahmednagar, State: Maharashtra

Distillery:

Capacity: Industrial Alcohol 30,000 KL per annum

Organic Chemical Plant

Capacity:

Acetic Acid : 22,000 MT per annum

Ethyl Acetate : 30,000 MT per annum

Crotonaldehyde : 5,000 MT per annum

Paraldehyde : 600 MT per annum

Crotonic Acid : 150 MT per annum

Crotonic Anhydride : 50 MT per annum

Location:

Sameerwadi, Tal Mudhol, Dist. Bagalkot, State: Karnataka

Distillery:

Capacity:

Ethyl Alcohol/Rectified Spirit : 20,000 KL per annum (Existing)

60,000 KL per Annum after expansion

Ethanol (Absolute Alcohol) : 16,500 KL per annum (Existing)

50,000 KL Annum after expansion.

Extra Neutral Alcohol (ENA) : 12,000 KL per annum

Ethyl Lactate : 500 MT per annum

Bhoomi Labh (An organic Manure) : 15,000 MT per annum (Existing)

45,000 MT per annum after expansion

#### Registered Office:

Somaiya Bhavan, 45-47, M.G. Road, PO Box No. 384, Fort, Mumbai – 400 001.

Phone: (022) 22048272/61702100

#### d. Printing and Publishing

#### i) Book Center Ltd.

It has a large, well-equipped printing press in Mumbai to cater services of Graphic Communication under one roof. Being in the industry for last 30 years and with the team of professionals, it has expertise of executing any assignment of clients (Multicolor & B/W) of any size with secrecy and of course integrity of product.

#### ii) Somaiya Publications Pvt. Ltd.,

Specializes in publication of nob-fictional and educational books of high standard. Also Publishes books on topics which have bearing on economics, philosophy, management, indian culture and heritage.

#### e. Education & Social welfare

#### i) Somaiya Vidyavihar

Founded in 1959, Somaiya Vidyavihar has come to encompass the entire educational spectrum from kindergarten to post graduate education, providing education to around 26,000 students every year, and has a faculty strength of over 1500 teachers. It comprises of 34 institutes including Jr. & Sr. Colleges in Arts, Science & Commerce, a polytechnic, Engineering College, Sanskriti peetham, Buddhist Centre, Management Institute and a "Kendriya Sanskrit Vidyapeeth", each having well equipped laboratories, libraries and hostel arrangements.

#### ii) Somaiya Ayurvihar

Somaiya Ayurvihar is committed to offering an integrated package of general and Specialized health care services. It comprises of a Medical College, a Nursing School, a 550 bed Hospital with a Blood Bank and an HIV Treatment Centre, a Research Centre complex and an Institute of Paramedical Studies –a College of Physiotherapy.

#### iii) Shri Girivanavasi Pragati Mandal

In order to bring neglected brethren living in the forest and hilly regions to the mainstream of our national life, Shri Girivanavasi Pragati Mandal was formed in 1974. The Mandal held 7 (seven) annual Eye-cum-Medical Camps in different States from 1975 to 1981 and treated 1,85,417 people in these Camps held in the interior far away from the rail head or bus stops to reach out to people living in the remotest part. The Mandal has since established a 40 bed Eye- cum-General Hospital and a permanent Experimental Farm, a Dairy, an Agricultural Training Centre, and a free Boarding School at Nareshwadi, near Dahanu, in Thane District, Maharashtra, about 120 kms away from Mumbai for the welfare of the Tribals right in the midst of the Tribal Area.





Fig 1: Location map



**Layout Map of Factory Premises** 

### **Aerial Photographs of the Factory**





pg. 8





### **Manufacturing Process**


### A) Ethyl Acetate Plant:-

#### a) Process Discreption

Ethyl acetate is produced by esterification of acetic acid and ethanol in presence of Para Toluene Sulphonic Acid as catalyst.


Glacial acetic acid, 95% ethanol and 1% PTSA are mixed and continuously feed into the esterification kettle. Suitable amount of ternary azeotrope is withdrawn from the top of the esterification column, by maintaining optimum top temperature and is then fed into the decanter. Fresh De-mineralized water is also fed in to the decanter to separate 94% ester as upper heterogeneous phase. This ester is fed to the drying (Ester Purification) column where the ternary distillation (water-ethanol-ethyl acetate) occurs. Final pure ethyl acetate is drawn continuously from the middle of the distillation column, cooled in the product cooler and sent to storage tank. The product purity is 99.5% to 99.9% pure. The top vapour outlet is again mixed with excess water is fed to another decanter. Small amount of ester separated is refluxed to the column. The bottom product of the two decanters is sent to the alcohol recovery column. From it the recovered vapor is sent to the reaction kettle.

### b) Process Flow sheet




### c) Material Balance

### **Existing Ethyl Acetate Plant**



| Water Balance (Consumption & g   | generation b      | reak-up) :-         |            |                   |             |                |           |                   |              |           |            |              |            |
|----------------------------------|-------------------|---------------------|------------|-------------------|-------------|----------------|-----------|-------------------|--------------|-----------|------------|--------------|------------|
|                                  | ess Water :-      |                     | Kg/Hr      |                   |             |                |           |                   |              |           |            |              |            |
| Reaction water                   | er generated :-   | 1575                | Kg/Hr      |                   |             |                |           |                   |              |           |            |              |            |
| Water in                         | R.S. feed :-      | 353                 | Kg/Hr      |                   |             |                |           |                   |              |           |            |              |            |
| Total net water effluen          | t generated :-    | 10117               | Kg/Hr      | ( Drain of C-3 co | olumn)      |                |           |                   |              |           |            |              |            |
| Total waste water                |                   |                     | m3/day     | 1                 | ,           |                |           |                   |              |           |            |              |            |
|                                  |                   |                     |            |                   |             |                |           |                   |              |           |            |              |            |
| (Note :- Water effluent ge       | enerated fro      | m system is being r | ecycled to | cooling tower a   | s cooling t | ower makeup w  | ater, hen | ce there is zero  | effluent dis | change f  | rom the pl | ant.)        |            |
| Energy balance :-                |                   |                     |            |                   |             |                |           |                   |              |           |            |              |            |
| Column                           | C1                | Unit                | C2         | Unit              | C3          | Unit           | C4        | Unit              | Total Heat   |           |            |              |            |
|                                  |                   |                     |            |                   |             |                |           |                   | Load         |           |            |              |            |
| Total Evaporation Load           | 61261             | Kg/hr.              | 9509       | Kg/hr.            | 4193        | Kg/hr.         | 1356      | Kg/hr.            |              |           |            |              |            |
| Reflux Ratio                     | 4:01              |                     | 3:01       |                   | 1:01        |                | 4:01      |                   |              |           |            |              |            |
| Avg.Latent Heat                  | 120               | Kcal/Kg.            | 120        | Kcal/Kg.          | 107         | Kcal/Kg.       | 88        | Kcal/Kg.          |              |           |            |              |            |
| 0.1                              |                   |                     |            | 11 10 10 5        | ,== /       | 14 10 10 5     | *****     | 14 10 10 5        |              |           |            |              |            |
| Condenser/cooler Load QC         | 7336587           | Kcal/hr.(QC-1)      | 1138819    | Kcal/hr.(QC-2)    | 450135      | Kcal/hr.(QC-3) | 119350    | Kcal/hr.(QC-4)    | 9206141      | Kcal/hr.( | 1C)        |              |            |
|                                  |                   |                     | 161248     | Kcal/hr.(QC-5)    |             |                |           |                   |              |           |            |              |            |
|                                  |                   |                     |            |                   |             |                |           |                   |              |           |            |              |            |
| Reboiler load                    | 7336587           | Kcal/hr.            | 1138819    | Kcal/hr.          | 450135      | Kcal/hr.       | 119350    | Kcal/hr.          |              |           |            |              |            |
| Excess duty due to Low Feed temp | 382268            | Kcal/hr.            | 173448     | Kcal/hr.          | 54016       | Kcal/hr.       | 11935     | Kcal/hr.          |              |           |            |              |            |
| Total Reboiler Duty QR           | 7718855           | Kcal/hr.(QR-1)      | 1312267    | Kcal/hr.(QR-2)    | 504152      | Kcal/hr.(QR-3) | 131285    | Kcal/hr.(QR-4)    | 9666559      | Kcal/hr.( | QR)        |              |            |
| Enthalpy of steam                | 540               | Kcal/Kg.            | 540        | Kcal/Kg.          | 540         | Kcal/Kg.       | 540       | Kcal/Kg.          | 540          |           |            |              |            |
| Steam Consumption                | 14294             | Kg/hr.              | 2430       | Kg/hr.            | 934         | Kg/hr.         | 243       | Kg/hr.            | 17901        |           |            |              |            |
| ,                                |                   |                     |            |                   |             |                |           |                   | 2.39         | Ton/ Ton  | EA         |              |            |
|                                  |                   |                     |            |                   |             |                |           | Chiller Load      | 497828       | Kcal/hr   | 16         | 5 TR         |            |
|                                  |                   |                     |            |                   |             | Stea           | m Consum  | ption for Chiller |              | Ton/ Ton  | EA         |              |            |
|                                  |                   |                     |            |                   |             |                |           |                   |              | Ton/ Tor  |            |              |            |
|                                  |                   |                     |            |                   |             |                | Stean     | Condensate :-     |              | Kg/Hr     |            | to boiler as | hot water) |
| Cooling Water requirement :-     |                   |                     |            |                   |             |                |           |                   |              |           |            |              |            |
|                                  | er Capacity :-    | 2200                | m3/hr.     |                   |             |                |           |                   |              |           |            |              |            |
|                                  | ter drift loss :- |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Cooling Tower Blow               |                   |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Required Cooling Tower ma        |                   |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Water recycle from pr            |                   |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Actual Cooling Tower make-up wa  |                   |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Required make-up wa              |                   |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
|                                  | er Required:      |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Actual Water                     | Say:              |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Water Consumption Statement      |                   |                     |            |                   |             |                |           |                   |              |           |            |              |            |
| Process water                    |                   | 191                 | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Utility water                    |                   |                     | m3/day     |                   |             |                |           |                   |              |           |            |              |            |
| Othicy water                     |                   | 301                 |            |                   |             |                |           |                   |              |           |            |              |            |

### **Proposed Ethyl Acetate Plant**



| Water Balance (Consumption & g   | eneration break     | .: lau                |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
|----------------------------------|---------------------|-----------------------|---------------|---------------------------------------------|-----------------|-------------------|-----------------|------------------|--------------------|--------------|-----------------------|------------|
|                                  | Process Water :-    |                       | Kg/Hr         |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  | water generated :-  |                       | Kg/Hr         |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  | er in R.S. feed :-  |                       | Kg/Hr         |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Total net water eff              |                     |                       |               | / Drain of C 2 or                           | nlumn\          |                   |                 |                  |                    |              |                       |            |
|                                  | ater Generated :-   |                       | Kg/Hr         | ( Drain of C-3 co                           | olumnj          |                   |                 |                  |                    |              |                       |            |
|                                  |                     |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Total net waste water recycle t  | to cooling tower:-  | 391                   | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| (Note :- Water effluent ge       | naratad from au     | otom is boing room    | olod to oooli | na tower on coo                             | ling tower m    | akaun watar h     | anaa thara ia z | oro offluent die | ohanaa from        | the plant \  |                       |            |
| (Note water emuent ge            | merateu nom sy      | stelli is bellig recy | cieu io cooii | ily tower as coo                            | illig tower ill | iakeup water, iii | ence mere is z  | ero emuem un     | change nom         | uie piaii.j  |                       |            |
| Energy balance :-                |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
| 3)                               |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Column                           | C1                  | Unit                  | C2            | Unit                                        | C3              | Unit              | C4              | Unit             | Total Heat<br>Load |              |                       |            |
| Total Evaporation Load           | 80069               | Kg/hr.                | 15320         | Kg/hr.                                      | 6756            | Kg/hr.            | 2185            | Kg/hr.           | Loud               |              |                       |            |
| Reflux Ratio                     | 4:01                | - g                   | 3:01          | - · · · · · · · · · · · · · · · · · · ·     | 1:01            | 1.3               | 4:01            | -g               |                    |              |                       |            |
| Avg.Latent Heat                  | 120                 | Kcal/Kg.              | 120           | Kcal/Kg.                                    | 107             | Kcal/Kg.          | 88              | Kcal/Kg.         |                    |              |                       |            |
| r ng.ssaront rivet               | IEV                 | i wairing.            | 120           | rounty.                                     | ivi             | rounty.           | 30              | rounty.          |                    |              |                       |            |
| Condenser/cooler Load QC         | 9589063             | Kcal/hr.(QC-1)        | 1834730       | Kcal/hr.(QC-2)                              | 725301          | Kcal/hr.(QC-3)    | 192286          | Kcal/hr.(QC-4)   | 12601170           | Kcal/hr.(QC) |                       |            |
| 35/105/105/107 E000 40           | 000000              | TOURTH (NOT)          | 259789        | Kcal/hr.(QC-5)                              | 120001          | nouni.(wo')       | 102200          | rvaini.(40.4)    | 12001110           | rtourni.(QO) |                       |            |
|                                  |                     |                       | 233103        | rcairii.(40-3)                              |                 |                   |                 |                  |                    |              |                       |            |
| Reboiler load                    | 9589063             | Kcal/hr.              | 1834730       | Kcal/hr.                                    | 725301          | Kcal/hr.          | 192286          | Kcal/hr.         |                    |              |                       |            |
| Excess duty due to Low Feed temp | 499631              | Kcal/hr.              | 279439        | Kcal/hr.                                    | 87036           | Kcal/hr.          | 19229           | Kcal/hr.         |                    |              |                       |            |
| Total Reboiler Duty QR           | 10088695            | Kcal/hr.(QR-1)        | 2114168       | Kcal/hr.(QR-2)                              | 812337          | Kcal/hr.(QR-3)    | 211515          | Kcal/hr.(QR-4)   | 13006716           | Kcal/hr.(QR) |                       |            |
| Total Nepolici Daty Wit          | 10000033            | rcairii.(\\\x\-1)     | 2114100       | rcairii.(\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\ | 012331          | rcairii.(Qr-5)    | 211010          | rcairii.(Qr-4)   | 132207 13          | rcairii.(Qr) |                       |            |
| Enthalpy of steam                | 540                 | Kcal/Kg.              | 540           | Kcal/Kg.                                    | 540             | Kcal/Kg.          | 540             | Kcal/Kg.         | 540                |              |                       |            |
| Steam Consumption                | 18683               | Kg/hr.                | 3915          | Kg/hr.                                      | 1504            | Kg/hr.            |                 | Kg/hr.           |                    | Kg/Hr        |                       |            |
| Oteani Consumption               | 10003               | rvy/III.              | 3313          | Nyrii.                                      | 1304            | rtyrii.           | JJL             | rvy/III.         |                    | Ton/ Ton EA  |                       |            |
|                                  |                     |                       |               |                                             |                 |                   |                 | Chiller Load     |                    | Kcal/hr      | 225 TR                |            |
|                                  |                     |                       |               |                                             |                 |                   |                 |                  |                    | Ton/ Ton EA  | 220 IK                |            |
|                                  |                     |                       |               |                                             |                 |                   | Steam Consum    | puon ioi Chiller |                    |              |                       |            |
|                                  |                     |                       |               |                                             |                 |                   | 01              | Candanasta       |                    | Ton/ Ton EA  | /Describe to belleves | ادمادا     |
|                                  |                     |                       |               |                                             |                 |                   | Steam           | Condensate :-    | 20010              | Kg/Hr        | (Recycle to boiler as | not water) |
| Caaling Water requirement .      |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Cooling Water requirement :-     | T 0'h               | 0500                  | 2/1           |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  | Tower Capacity :-   |                       | m3/hr.        |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  | water drift loss :- |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  | low Down water :-   |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Required Cooling Towe            |                     |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Water recycle from               |                     |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  | m RO permeate :-    |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Actual Cooling Tower make-up     |                     |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Required make-up                 |                     |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Actual v                         | vater Required:-    |                       | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  | Say :-              | 150                   | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Water Consumption Statement      |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Process water                    |                     | 207                   | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
| Utility water                    |                     | 150                   | m3/day        |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |
|                                  |                     |                       |               |                                             |                 |                   |                 |                  |                    |              |                       |            |

### **B) Acetaldehyde Plant**

### a) Process Description

Acetaldehyde is manufactured by vapour phase oxidation of alcohol with air in presence of silver catalyst. The reaction is presented as follows.

$$C_2H_5OH + \frac{1}{2} O_2 \longrightarrow CH_3CHO + H_2O$$
46 16 44 18

The ethanol vapours from alcohol recovery column are fed into the carburetor filter at a temperature of 68°C. The mixture of alcohol vapours air of required composition coming out from the carburetor is fed to the reactor. The reaction starts in presence of Silver catalyst [the temperature of which is maintained around 500°C]. This reaction is highly exothermic and the reaction heat is recovered and utilized for distillation of Acetaldehyde. This reactor is designed and used as vapour generator.

The reaction mixture coming out from the reactor, mainly consist of unconverted ethanol, water vapour and acetaldehyde formed in the reaction is sent to cooler condenser. The unreacted ethanol and water vapour is mostly condensed and separated in the cooler condenser. The acetaldehyde vapour is scrubbed in Aldehyde scrubber, first with process liquid and subsequently with water before venting into atmosphere. The Scrubber is connected with 3 coolers in process liquid section and one cooler in water section for removing heat of absorption.

The absorbate from the absorber and the condensate from cooler condensers after preheating in heat exchanger is fed to Aldehyde distillation column. The acetaldehyde is drawn from the top of the column by keeping the top temperature at 55 °C. The extra alcohol, water, mixture at the bottom of the distillation column is fed to the alcohol recovery columns. The distillation is generally done under 65 PSI pressure. Acetaldehyde is cooled and stored in the storage tank under pressure and nitrogen blanket.

Raw Material Consumption For Acetaldehyde:-


Basis :- 1.0 Ton of Acetaldehyde

| Sr.No. | Component     | Norms | Unit of Measure |
|--------|---------------|-------|-----------------|
| 1.     | Ethyl Alcohol | 1.5   | KL              |

#### Product :-


| Sr.No. | Component    | Norms | Unit of Measure |
|--------|--------------|-------|-----------------|
| 1.     | Acetaldehyde | 1.0   | Ton             |

### b) Process Flow sheet




### C)Material Balance

### **Existing Acetaldehyde Unit**



| Water Balance (Consumption & g   | generation b                         | reak-up) :-    |                                       |                   |                                      |                   |                    |                                         |          |                      |
|----------------------------------|--------------------------------------|----------------|---------------------------------------|-------------------|--------------------------------------|-------------------|--------------------|-----------------------------------------|----------|----------------------|
|                                  | cess Water :-                        |                | Kg/Hr                                 |                   |                                      |                   |                    |                                         |          |                      |
| Reaction water                   | er generated :-                      |                | Kg/Hr                                 |                   |                                      |                   |                    |                                         |          |                      |
|                                  | R.S. feed :-                         |                | Kg/Hr                                 |                   |                                      |                   |                    |                                         |          |                      |
| Total net water effluer          | nt generated :-                      |                | Kg/Hr                                 | ( Drain of C-3 of | column)                              |                   |                    |                                         |          |                      |
|                                  | Generated :-                         |                | m3/day                                | (@ 2.8% A/A       |                                      |                   |                    |                                         |          |                      |
|                                  | Say                                  |                | m3/day                                | (62.0             |                                      |                   |                    |                                         |          |                      |
|                                  |                                      |                |                                       |                   |                                      |                   |                    |                                         |          |                      |
| Energy balance :-                |                                      |                |                                       |                   |                                      |                   |                    |                                         |          |                      |
| Column                           | Carburator<br>(C4)                   | Unit           | Alcohol<br>Recovery<br>Column<br>(C3) | Unit              | Aldehyde<br>Dist.<br>Column<br>(C13) | Unit              | Total Heat<br>Load |                                         |          |                      |
| Total Evaporation Load           |                                      | Kg/hr.         | 4122                                  | Kg/hr.            | 6875                                 | Kg/hr.            |                    |                                         |          |                      |
| Reflux Ratio                     |                                      | ,              | -                                     | 3                 | 2.5:01                               | g                 |                    |                                         |          |                      |
| Avg.Latent Heat                  | -                                    | Kcal/Kg.       | 231                                   | Kcal/Kg.          | 136                                  | Kcal/Kg.          |                    |                                         |          |                      |
| 0 1 1 1 100                      |                                      | 17 17 700      |                                       | 17 18             | 4007400                              | 14 18 400 41      | 0044000            | 14 14 400                               |          |                      |
| Condenser/cooler Load QC         | -                                    | Kcal/hr.(QC)   | 0                                     | Kcal/hr           |                                      | Kcal/hr.(QC-1)    | 2844863            | Kcal/hr.(QC)                            |          |                      |
|                                  |                                      |                | 362909                                | Kcal/hr.(QC-2)    |                                      |                   |                    |                                         |          |                      |
|                                  |                                      |                | 900000                                | Kcal/hr.(QC-3)    |                                      |                   |                    |                                         |          |                      |
|                                  |                                      |                | 574767                                | Kcal/hr.(QC-4)    |                                      |                   |                    |                                         |          |                      |
| Reboiler load                    | 70486                                | Kcal/hr.       | 951610                                | Kcal/hr.          | 935000                               | Kcal/hr.          |                    |                                         |          |                      |
| Excess duty due to Low Feed temp |                                      | Kcal/hr.       | 95161                                 | Kcal/hr.          | 93500                                | Kcal/hr.          |                    |                                         |          |                      |
| Total Reboiler Duty QR           | 91750                                | Kcal/hr.(QR-2) |                                       | Kcal/hr.(QR-1)    |                                      | Kcal/hr.(QR-3)    | 2167022            | Kcal/hr.(QR)                            |          |                      |
|                                  |                                      | (              |                                       | \                 |                                      |                   |                    | , , , , , , , , , , , , , , , , , , , , |          |                      |
| Enthalpy of steam                | 540                                  | Kcal/Kg.       | 540                                   | Kcal/Kg.          | 540                                  | Kcal/Kg.          | 540                |                                         |          |                      |
| Steam Consumption                | 170                                  | Kg/hr.         | 1938                                  | Kg/hr.            | 1905                                 | Kg/hr.            | 4013               |                                         |          |                      |
| ·                                |                                      | Ť              |                                       | Ĭ                 |                                      |                   | 1.93               | Ton/ Ton Acet                           | aldehvde |                      |
|                                  |                                      |                |                                       |                   |                                      | Chiller Load      |                    | Kcal/hr                                 |          | TR                   |
|                                  |                                      |                |                                       | St                | eam Consum                           | ption for Chiller |                    | Ton/ Ton Aceta                          |          |                      |
|                                  |                                      |                |                                       |                   |                                      |                   |                    | Ton/ Ton Ace                            |          |                      |
|                                  |                                      |                |                                       |                   | Stean                                | Condensate :-     |                    | Kg/Hr                                   |          | boiler as hot water) |
| Cooling Water re                 |                                      |                |                                       |                   |                                      |                   |                    |                                         |          |                      |
| Cooling Water requirement :-     | or Canacity                          | 750            | m2/hr                                 |                   |                                      |                   |                    |                                         |          |                      |
| Cooling Tow                      | rer Capacity :-<br>ter drift loss :- |                | m3/hr.                                |                   |                                      |                   |                    |                                         |          |                      |
| Cooling Tower Blow               |                                      |                | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
| Required Cooling Tower m         |                                      |                | m3/day<br>m3/day                      |                   |                                      |                   |                    |                                         |          |                      |
| Actual Cooling Tower make-up wa  |                                      |                | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
| Required make-up wa              |                                      |                | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
|                                  | er Required:-                        |                | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
| Actual Wat                       | er kequireu:-<br>-: Say              |                | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
| Weter Comments - State -         |                                      |                |                                       |                   |                                      |                   |                    |                                         |          |                      |
| Water Consumption Statement      |                                      | E3             | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
| Process water                    |                                      |                | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
| Hility water                     |                                      |                | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
| Utility water                    |                                      | 110            | m3/day                                |                   |                                      |                   |                    |                                         |          |                      |
|                                  |                                      |                |                                       |                   |                                      |                   |                    |                                         |          |                      |

### **Proposed Acetaldehyde Unit**



| Water Balance (Consumption & g   | eneration brea      | k-up) :-       |                                       |                  |                                   |                                         |                    |               |               |                   |     |
|----------------------------------|---------------------|----------------|---------------------------------------|------------------|-----------------------------------|-----------------------------------------|--------------------|---------------|---------------|-------------------|-----|
|                                  | rocess Water :-     |                | Kg/Hr                                 |                  |                                   |                                         |                    |               |               |                   |     |
|                                  | vater generated :-  |                | Kg/Hr                                 |                  |                                   |                                         |                    |               |               |                   |     |
|                                  | er in R.S. feed :-  |                | Kg/Hr                                 |                  |                                   |                                         |                    |               |               |                   |     |
| Total net water effl             |                     |                | Kg/Hr                                 | ( Drain of C-3   | column)                           |                                         |                    |               |               |                   |     |
|                                  | ent Generated :-    |                | m3/day                                | ( Dialii di C-3  | Columni                           |                                         |                    |               |               |                   |     |
| Total Lillu                      |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
|                                  | Say                 | 00             | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Energy balance :-                |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
| Lifety balance                   |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
| Column                           | Carburator<br>(C4)  | Unit           | Alcohol<br>Recovery<br>Column<br>(C3) | Unit             | Aldehyde<br>Dist. Column<br>(C13) | Unit                                    | Total Heat<br>Load |               |               |                   |     |
| Total Evaporation Load           |                     | Kg/hr.         | 5696                                  | Kg/hr.           | 8750                              | Kg/hr.                                  |                    |               |               |                   |     |
| Reflux Ratio                     |                     |                |                                       | Ĭ                | 2.0:01                            |                                         |                    |               |               |                   |     |
| Avg.Latent Heat                  |                     | Kcal/Kg.       | 231                                   | Kcal/Kg.         | 136                               | Kcal/Kg.                                |                    |               |               |                   |     |
|                                  |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
| Condenser/cooler Load QC         | -                   | Kcal/hr.(QC)   | 0                                     | Kcal/hr          | 1281875                           | Kcal/hr.(QC-1)                          | 4886260            | Kcal/hr.(QC)  |               |                   |     |
|                                  |                     | (40)           | 504538                                | Kcal/hr.(QC-2)   |                                   | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, |                    | (42)          |               |                   |     |
|                                  |                     |                | 1800000                               | Kcal/hr.(QC-3)   |                                   |                                         |                    |               |               |                   |     |
|                                  |                     |                | 1299848                               | Kcal/hr.(QC-4)   |                                   |                                         |                    |               |               |                   |     |
|                                  |                     |                | 1200040                               | rtouirii.(QO +   |                                   |                                         |                    |               |               |                   |     |
| Reboiler load                    | 97863               | Kcal/hr.       | 1315075                               | Kcal/hr.         | 737800                            | Kcal/hr.                                |                    |               |               |                   |     |
| Excess duty due to Low Feed temp | 29522               | Kcal/hr.       | 131508                                | Kcal/hr.         | 119000                            | Kcal/hr.                                |                    |               |               |                   |     |
| Total Reboiler Duty QR           | 127385              | Kcal/hr.(QR-2) | 1446583                               | Kcal/hr.(QR-1)   | 856800                            | Kcal/hr.(QR-3)                          | 2430768            | Kcal/hr.(QR)  |               |                   |     |
| Total Robbilot Buty Qit          | 127000              | rouim.(Qrv 2)  | 1440000                               | rtouirii. (art i | 000000                            | rtodiim.(direo)                         | 2400100            | rtourni.(Qrt) |               |                   |     |
| Enthalpy of steam                | 540                 | Kcal/Kg.       | 540                                   | Kcal/Kg.         | 540                               | Kcal/Kg.                                | 540                |               |               |                   |     |
| Steam Consumption                | 236                 | Kg/hr.         | 2679                                  | Kg/hr.           | 1587                              | Kg/hr.                                  | 4501               |               |               |                   |     |
| Ctourn Concumption               | 200                 | rtgrii.        | 2010                                  | rtg              | 1001                              | rtgrii.                                 |                    | Ton/ Ton Acet | aldehyde      |                   |     |
|                                  |                     |                |                                       |                  |                                   | Chiller Load                            |                    | Kcal/hr       |               | TR                |     |
|                                  |                     |                |                                       |                  | Steam Concum                      | ption for Chiller                       |                    | Ton/ Ton Acet |               | IIX               |     |
|                                  |                     |                |                                       | '                | Steam Consum                      | phon for Chiller                        |                    | Ton/ Ton Ace  |               |                   |     |
|                                  |                     |                |                                       |                  | Ctoon                             | Condensate :-                           |                    | Kg/Hr         |               | ooiler as hot wat | 00) |
|                                  |                     |                |                                       |                  | Steam                             | Condensate                              | 4070               | Ng/III        | (Recycle to L | oner as not wat   | erj |
| Cooling Water requirement :-     |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
|                                  | Tower Capacity :-   | 850            | m3/hr.                                |                  |                                   |                                         |                    |               |               |                   |     |
|                                  | water drift loss :- |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Cooling Tower BI                 |                     |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Required Cooling Tower           |                     |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Actual Cooling Tower             |                     |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Required make-up                 |                     |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
|                                  | vater Required:-    |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Actual v                         | Say :-              |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
|                                  | Jay                 | 133            | moruay                                |                  |                                   |                                         |                    |               |               |                   |     |
| Water Consumption Statement :-   |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
| Process water                    |                     | 39             | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
|                                  |                     |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Utility water                    |                     |                | m3/day                                |                  |                                   |                                         |                    |               |               |                   |     |
| Other water                      |                     | 133            | morudy                                |                  |                                   |                                         |                    |               |               |                   |     |
|                                  |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
|                                  |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |
|                                  |                     |                |                                       |                  |                                   |                                         |                    |               |               |                   |     |

### C) Acetic Acid

### a) Process Discription:-

Here Acetic acid is manufactured by liquid phase oxidation of acetaldehyde with air. The reaction is presented as follows: -

Acetaldehyde is fed to the reactor in which air under 65 PSIpressure. Air is uniformly distributed and dispatched from the bottom. The reaction proceeds in liquid phase and is exothermic. The catalyst Manganese Acetate and Potassium permanganate is present in dissolved form in the ratio of 0.1 % and 0.015 % respectively. The reactor has two coolers attached to remove the reaction heat continuously and maintain reactor temperature around 60 °C. The reactor mixture drawn out from the reactor consists of unreacted Aldehyde, acetic acid. It is put through a Vapour-Liquid Separator. The vapours coming out of the separator is fed directly to the top of Aldehyde stripper. The liquid portion is fed into the middle of the Aldehyde scrubber. The temperature of the scrubber is maintained in such way that all the Aldehyde separate out from the top which is further condensed and cooled and put back into the mixing tank as shown in the P&ID. The residual air mostly N<sub>2</sub> leaving the reactor is scrubbed with Aldehyde free acetic acid and then washed with water to recover traces of acetic acid before venting out to the atmosphere. The reactor and absorber system is maintained under 65 PSI pressure. The absorbate from the Aldehyde Absorber is fed back to the reactor. The bottom product of the Aldehyde scrubber is put into the acid distillation column. In this column, water along with traces of acid and other impurities are separated as a distillate ( Dilute acid ). The middle temperature of the column is maintained acetic acid in vapour form is removed continuously as bottom product through a condenser cooler and stored at ambient temperature.

#### **Raw Material Consumption For Acetic Acid:**


#### **Basis :- 1.0 Ton of Acetic Acid**

| Sr.No. | Component    | Norms | Unit of Measure |
|--------|--------------|-------|-----------------|
| 1.     | Acetaldehyde | 0.76  | Ton             |

#### **Product:-**


| Sr.No. | Component      | Norms  | Unit of Measure |
|--------|----------------|--------|-----------------|
| 1.     | Acetic Acid    | 1.0    | Ton             |
| 2.     | Dil. Acid(35%) | 0.0734 | Ton             |

### b) Process Flow sheet




### c) Material Balance

### **Existing Acetic Acid Plant**



| Process Water :-                   | 44                            | Kg/Hr          |                              |                   |                    |             |            |             |           |
|------------------------------------|-------------------------------|----------------|------------------------------|-------------------|--------------------|-------------|------------|-------------|-----------|
|                                    |                               |                |                              |                   |                    |             |            |             |           |
| (Note :- There is no liquid & soli | d waste efflu                 | ent generation | from the p                   | lant)             |                    |             |            |             |           |
| Energy balance :-                  |                               |                |                              |                   |                    |             |            |             |           |
| Column                             | Aldehyde<br>Stripper<br>(C36) | Unit           | Acetic<br>Acid Dist.<br>C-25 | Unit              | Total Heat<br>Load |             |            |             |           |
| Total Evaporation Load             | 1055                          | Kg/hr.         | 3300                         | Kg/hr.            |                    |             |            |             |           |
| Reflux Ratio                       |                               |                | -                            |                   |                    |             |            |             |           |
| Avg.Latent Heat                    | 136                           | Kcal/Kg.       | 385                          | Kcal/Kg.          |                    |             |            |             |           |
| Condenser/cooler Load QC           | 143480                        | Kcal/hr.(QC-1) | 1335989                      | Kcal/hr.(QC-2)    | 5492498            | Kcal/hr.(Q0 | C)         |             |           |
|                                    | 3649667                       | Kcal/hr.(QC-4) | 201458                       | Kcal/hr.(QC-3)    |                    |             |            |             |           |
|                                    | 161904                        | Kcal/hr.(QC-5) |                              |                   |                    |             |            |             |           |
| Reboiler load                      | 143480                        | Kcal/hr.       | 1537447                      | Kcal/hr.          |                    |             |            |             |           |
| Excess duty due to Low Feed tem    | 14348                         | Kcal/hr.       | 190498                       | Kcal/hr.          |                    |             |            |             |           |
| Total Reboiler Duty QR             | 157828                        | Kcal/hr.(QR-2) | 1727945                      | Kcal/hr.(QR-1)    | 1885773            | Kcal/hr.(QF | ₹)         |             |           |
| Enthalpy of steam                  | 540                           | Kcal/Kg.       | 540                          | Kcal/Kg.          | 540                |             |            |             |           |
| Steam Consumption                  | 292                           | Kg/hr.         | 3200                         | Kg/hr.            | 3492               |             |            |             |           |
|                                    |                               |                |                              |                   |                    | Ton/ Ton A  |            |             |           |
|                                    |                               |                |                              | m Consumption     |                    | Kcal/hr     | 125        |             |           |
|                                    |                               | Ste            | am Consum                    | ption for Chiller |                    | Ton/ Ton A  |            |             |           |
|                                    |                               |                | _                            |                   |                    | Ton/ Ton /  |            |             |           |
|                                    |                               |                | Steam                        | Condensate :-     | 4148               | Kg/Hr       | (Recycle t | o boiler as | hot water |
| Cooling Water requirement :-       |                               |                |                              |                   |                    |             |            |             |           |
|                                    | ver Capacity :-               |                | m3/hr.                       |                   |                    |             |            |             |           |
| •                                  | ter drift loss :-             |                | m3/day                       |                   |                    |             |            |             |           |
| Cooling Tower Blow                 |                               |                | m3/day                       |                   |                    |             |            |             |           |
| Required Cooling Tower ma          |                               |                | m3/day                       |                   |                    |             |            |             |           |
| Required make-up wa                |                               |                | m3/day                       |                   |                    |             |            |             |           |
| Actual water                       | er Required:-                 |                | m3/day                       |                   |                    |             |            |             |           |
|                                    | Say :-                        | 240            | m3/day                       |                   |                    |             |            |             |           |
| Water Consumption Statement        | :-                            |                |                              |                   |                    |             |            |             |           |
| Process water                      |                               | 1.1            | m3/day                       |                   |                    |             |            |             |           |
|                                    |                               |                | m3/day                       |                   |                    |             |            |             |           |

### **Proposed Acetic Acid Plant**



| Water Balance (Consumption &       | generation bre              | ak-up) :-                                          |                              |                                  |                    |               |            |             |            |
|------------------------------------|-----------------------------|----------------------------------------------------|------------------------------|----------------------------------|--------------------|---------------|------------|-------------|------------|
| Process Water :-                   |                             | Kg/Hr                                              |                              |                                  |                    |               |            |             |            |
|                                    |                             |                                                    |                              |                                  |                    |               |            |             |            |
| (Note :- There is no liquid & soli | d waste effluen             | t generation fro                                   | m the plant                  |                                  |                    |               |            |             |            |
| Energy balance :-                  |                             |                                                    |                              |                                  |                    |               |            |             |            |
| Column                             | Aldehyde<br>Stripper (C36)  | Unit                                               | Acetic<br>Acid Dist.<br>C-25 | Unit                             | Total Heat<br>Load |               |            |             |            |
| Total Evaporation Load             | 1372                        | Kg/hr.                                             | 3250                         | Kg/hr.                           |                    |               |            |             |            |
| Reflux Ratio                       |                             |                                                    |                              | ,                                |                    |               |            |             |            |
| Avg.Latent Heat                    | 136                         | Kcal/Kg.                                           | 385                          | Kcal/Kg.                         |                    |               |            |             |            |
| Condenser/cooler Load QC           | 186524<br>4744566<br>210475 | Kcal/hr.(QC-1)<br>Kcal/hr.(QC-4)<br>Kcal/hr.(QC-5) | 1315746<br>261896            | Kcal/hr.(QC-2)<br>Kcal/hr.(QC-3) | 6719208            | Kcal/hr.(QC)  |            |             |            |
| Reboiler load                      | 186524                      | Kcal/hr.                                           | 1577642                      | Kcal/hr.                         |                    |               |            |             |            |
| Excess duty due to Low Feed tem    | 18652                       | Kcal/hr.                                           |                              | Kcal/hr.                         |                    |               |            |             |            |
| Total Reboiler Duty QR             | 205176                      | Kcal/hr.(QR-2)                                     |                              | Kcal/hr.(QR-1)                   | 1970430            | Kcal/hr.(QR)  |            |             |            |
| Enthalpy of steam                  | 540                         | Kcal/Kg.                                           | 540                          | Kcal/Kg.                         | 540                |               |            |             |            |
| Steam Consumption                  | 380                         | Kg/hr.                                             | 3269                         | Kg/hr.                           | 3649               |               |            |             |            |
| ·                                  |                             |                                                    |                              |                                  | 1.35               | Ton/ Ton Acet | tic Acid   |             |            |
|                                    |                             |                                                    | Chiller stea                 | m Consumption                    | 394086             | Kcal/hr       | 130        | TR          |            |
|                                    |                             | Ste                                                |                              | ption for Chiller                |                    | Ton/ Ton Acet | tic Acid   |             |            |
|                                    |                             |                                                    |                              |                                  | 1.60               | Ton/ Ton Ace  | etaldehyd  | е           |            |
|                                    |                             |                                                    | Steam                        | Condensate :-                    | 4334               | Kg/Hr         | (Recycle t | o boiler as | hot water) |
| Cooling Water requirement :-       |                             |                                                    |                              |                                  |                    |               |            |             |            |
| Cooling 7                          | Fower Capacity :-           | 1050                                               | m3/hr.                       |                                  |                    |               |            |             |            |
| -                                  | water drift loss :-         |                                                    | m3/day                       |                                  |                    |               |            |             |            |
| Cooling Tower Bl                   |                             |                                                    | m3/day                       |                                  |                    |               |            |             |            |
| Required Cooling Tower             |                             |                                                    | m3/day                       |                                  |                    |               |            |             |            |
| Required make-up                   |                             |                                                    | m3/day                       |                                  |                    |               |            |             |            |
| Actual w                           | rater Required:-            |                                                    | m3/day                       |                                  |                    |               |            |             |            |
|                                    | Say :-                      | 263                                                | m3/day                       |                                  |                    |               |            |             |            |
| Water Consumption Statement        | :-                          |                                                    |                              |                                  |                    |               |            |             |            |
| Process water                      |                             |                                                    | m3/day                       |                                  |                    |               |            |             |            |
| Utility water                      |                             | 265                                                | m3/day                       |                                  |                    |               |            |             |            |
|                                    |                             |                                                    |                              |                                  |                    |               |            |             |            |

### **Water Budget**

|                  |                    |                                |                                                                            | Exist                  | ing          |           |          |                                                                              | Proposed                       |                                                                |                        |                            |           |          |                                                                               |
|------------------|--------------------|--------------------------------|----------------------------------------------------------------------------|------------------------|--------------|-----------|----------|------------------------------------------------------------------------------|--------------------------------|----------------------------------------------------------------|------------------------|----------------------------|-----------|----------|-------------------------------------------------------------------------------|
| Sr.No.           | Station            | Net Fresh Water<br>Consumption | Actual Water<br>Input                                                      | Losses/<br>Evaporation | Recycling To | Blow down | Effluent | Remark                                                                       | Net Fresh Water<br>Consumption | Actual Water Input                                             | Losses/<br>Evaporation | Recycling To cooling Tower | Blow down | Effluent | Remark                                                                        |
| 1                | Process Cons.      | 245                            | 245                                                                        | 0                      | 243          | 0         | 80       | 78m3 Addition<br>of Raw Material<br>& React.water                            | 348                            | 348                                                            | 0                      | 391                        |           | 80       | 123m3 Addition<br>of Raw Material<br>& React.water                            |
|                  | Total              | 245                            | 245                                                                        | 0                      | 243          |           | 80       |                                                                              | 348                            | 348                                                            | 0                      | 391                        |           | 80       |                                                                               |
| 2                | Cooling Tower      | 592                            | 915<br>592m3 Fresh<br>Water + 80m3 RO<br>permeate + 243m3<br>Process drain | 871                    | 0            | 44        |          | 80m3 RO<br>permeate +<br>243m3 Process<br>drain recycled<br>to cooling tower | 471                            | 1015 471m3 Fresh Water +153m3 RO permeate +391m3 Process drain | 970                    | 0                          | 44        | 0        | 153m3 RO<br>permeate &<br>391m3 Process<br>drain recycled<br>to cooling tower |
| 3                | Boiler             | 65                             | 65                                                                         | 65                     |              | 0         | 0        |                                                                              | 83                             | 83                                                             | 83                     | 0                          | 0         | 0        |                                                                               |
| 4                | Domestic           | 93                             | 93                                                                         | 47                     | 0            | 0         | 46       |                                                                              | 93                             | 93                                                             | 47                     | 0                          | 0         | 46       | Existing<br>workes will be<br>used so there<br>is no increase<br>in man power |
|                  | Total              | 995                            | 1318                                                                       | 983                    | 243          | 44        | 126      | 78m3 Addition<br>of Raw<br>Material &<br>React.water                         | 995                            | 1539                                                           | 1101                   | 391                        | 44        | 126      | 123m3<br>Addition of<br>Raw Material<br>& React.water                         |
| ote :- All water | quantity in m3/day | otherwise specified            | 1                                                                          |                        |              |           |          |                                                                              |                                |                                                                |                        |                            |           |          |                                                                               |

### **Energy Budget**

|        | Existing Plant |                  |                    |                |                          |                       |                    |                         |               |
|--------|----------------|------------------|--------------------|----------------|--------------------------|-----------------------|--------------------|-------------------------|---------------|
| Sr.No. | Plant          | Consent Capacity | No.of Working Days | Plant Capacity | Steam Consumption Norms  | Net Steam Consumption | F                  | Power                   |               |
|        |                | MT/Month         | Days               | MTD            | Ton/Ton                  | Tons/Day              | Unit/Ton           | Unit/Day                |               |
| 1      | Acetaldehyde   | 1500             | 30                 | 50.0           | 2.0                      | 100                   | 184                | 9200                    |               |
| 2      | Acetic Acid    | 1500             | 30                 | 50             |                          | 400                   | 242                |                         |               |
| 3      | Dilute Acid    | 110              | 30                 | 3.67           | 2.0                      | 100                   | 343                | 17150                   |               |
| 4      | Ethyl Acetate  | 5400             | 30                 | 180            | 2.50                     | 450                   | 49                 | 8820                    |               |
|        |                |                  |                    |                |                          | 650                   |                    | 35170                   | 27.1 Tons/hr. |
|        |                |                  |                    |                | Steam:Coal ratio         | 4.38                  | ton/ton( @ Raw coa | al GCV-4375Kcal/kg)     |               |
|        |                |                  |                    |                | Coal consumption per day | 149                   | Tons               | 6.19                    | Tons/hr.      |
|        |                |                  |                    |                |                          |                       |                    |                         |               |
|        |                |                  |                    |                |                          |                       |                    |                         |               |
|        |                |                  |                    |                |                          |                       |                    |                         |               |
|        |                |                  |                    |                |                          |                       |                    |                         |               |
|        | Proposed Plant |                  |                    |                |                          |                       |                    |                         |               |
|        |                |                  |                    |                |                          |                       |                    |                         |               |
| Sr.No. | Plant          | Consent Capacity | No.of Working Days | Plant Capacity | Steam Consumption Norms  | Net Steam Consumption | Power              |                         |               |
|        |                | MT/Month         | Days               | MTD            | Ton/Ton                  | Tons/Day              | Unit/Ton           | Unit/Day                |               |
| 1      | Acetaldehyde   | 2100             | 30                 | 70.0           | 1.60                     | 112                   | 165                | 11550                   |               |
| 2      | Acetic Acid    | 1950             | 30                 | 65             | 4.50                     |                       |                    |                         |               |
| 3      | Dilute Acid    | 143              | 30                 | 4.77           | 1.60                     | 104                   | 293                | 19045                   |               |
| 4      | Ethyl Acetate  | 8700             | 30                 | 290            | 2.1                      | 616                   | 45                 | 13050                   |               |
|        |                |                  |                    |                |                          | 832                   |                    | 43645                   | 34.7 Tons/hr. |
|        |                |                  |                    |                | Steam:Coal ratio         | 5.60                  | ton/ton(@Importe   | ed coal GCV-5600Kcal/kg | ()            |
|        |                |                  |                    |                | Coal consumption per day |                       | Tons               |                         | Tons/hr.      |
|        |                |                  |                    |                | , , ,                    |                       |                    |                         |               |
|        |                |                  |                    |                |                          |                       |                    |                         |               |
|        |                |                  |                    |                |                          |                       |                    |                         |               |

### **Environment Status of 10 KM Radius**




Fig 2: 10 km radius map

#### **ANALYSIS REPORT**

# MAHARASHTRA POLLUTION CONTROL BOARD REGIONAL LABORATORY, NASHIK



Tel. No. (0253) 2362820 Fax No. (0253) 2365150

Udyog Bhavan 1 <sup>o</sup> Floor Trimbak Road, Satpur, NASHIK - 422007. Date: 17.01.2014

To,

The Sub-Regional Officer, M.P.C. Board, Ahmednagar

Lab. Report No.:-1552

Sample code No :- SRO/ANR/JVS/534/13

Date of Collection: 07.11,2013

Date of receipt : 12.11.2013

#### ANALYSIS REPORT

| Particulars                | 1552                              |
|----------------------------|-----------------------------------|
| pΙ <b>Ι</b>                | 5.63                              |
| B.O.D.(3 Days 27 °C)       | 7.5                               |
| con                        | 32.0                              |
| Suspended Solids           | 8.0                               |
| Total Dissolved Solids     | 390.0                             |
| Chloride                   | 100.0                             |
| Sulphate                   | 10.0                              |
| Sample collected by: Shri, | (Field Officer), Scal No. 171/223 |

Note:

1) All results are expressed in ppm except plL

2) N.A. indicates Not Analysed.

3) N.D. Indicates Not Detectable

4) BDL indicates Below Detectable Level.

(A. P. Kolhe)
Scientific Officer,
Regional Laboratory, Nashik.

Handows 1 1 - The condition of the condi

n)s Godawari Biorefinery

LH,

Alp Kopargaon Tal-Kopargain

Location - R.o. permit

### MAHARASITTRA POLLUTION CONTROL BOARD Regional Laboratory, Nashik



1<sup>st</sup> floor, Udyog Bhavan, Near ITI, Tcimbak Road, Satpur, NASHIK – 7, Tel.0253-2362820 Email : striashiklab@mpcb.gov.in

Date :- 27/08/2013

To.

Sub-Regional Officer, M.P.C. Board, Ahmednagar

Stack (point source) Ernission Report

Ref : Your letter No: -MPCB/ANR/TB/Camop of Nashik/2013 | Dated-13/08/2013

Lab Report No. :- S-145

Date of Collection :- 08 /08/2013

Sample Code No.: -SRO/ANR/JVS/Stack- 448

Date of Receipt:- 13./08/2013

. Type of Industry: -

Seal No. - 171

| r.No | Parameters                            | Stack Details |
|------|---------------------------------------|---------------|
| 1    | Date of Sampling                      | 08 /08/2013   |
| 2    | Stack ( Identity)                     | Boiler no.1   |
| _ 3  | Strick height mts.                    | 30            |
| 4    | Stack area Sq.m.                      | 1.884         |
| 5    | Flue gas temperature "c               | 137           |
| 6    | Exit gas velocity m/s,                | 11.75         |
| 7    | Fuel Used                             | coal          |
| 8    | Gas quantity Nm³/hr                   | 57923.00      |
| 9    | Particulate matter emission mg/Nm3    | 63.61         |
| 10   | SO <sub>2</sub> (mg/Nm <sup>3</sup> ) | 142,49        |

mts Godawani Poin refinery at Sakerroundi Tall Kapangas --Ai Nagar

(A. P. Kolhe) Surentific Officer, Regional Laboratory, Nashik

Botter Stauc. 1

# MAHARASITTRA POLLUTION CONTROL BOARD Regional Laboratory, Nashik



j<sup>at</sup> floor, Udyog Bhavan, Near ITI, Trimbak Road, Salpur, NASHIK – 7. Tel.0253-2362820 Email : agwashiklab@mpcb.gov.in

Date - 27/08/2013

To

Sub-Regional Officer,

M.P.C. Board.

Ahmednaga:

Stack (point source) Emission Report

Ref : Your latter No: -MPCB/ANR/TB/Camop of Nasbik/2013 Dated-13/08/2013

Lub Report No. :- S-150

Date of Collection :- 10 /08/2013

Sample Code No.:-SRO/ANR/JVS/Stack- 459

Date of Receipt: 13/08/2013

Type of Industry: -

Seal No. - 171

|       | Parameters                                     | Stack Details        |
|-------|------------------------------------------------|----------------------|
| Br.No | Date of Sampling                               | 10 /08/2013          |
| 2     | Stack ( Identity)                              | Boiler No. 2 GT 1895 |
| 3     | Stack height mts.                              | 30                   |
| 4     | Stack area Sq.m.                               | 2.06154              |
| 5     | Flue gas temperature <sup>0</sup> c            | 101                  |
| 6     | Exit gas velocity m/s.                         | 10.25                |
| 7     | Fuel Used                                      | Ceal                 |
| 8     | Gas quartity Nm³/hr                            | 60511.0              |
| 9     | Particulate matter emission mg/Nm <sup>3</sup> | 73.77                |
| 10    | SO <sub>2</sub> (mg/Nm <sup>2</sup> )          | 117.76               |

m/s Godowani Bre refinany al Salamukersti "Tar- kopanyan Al Masa(A. P. Kolhe)
Scientific Officer,
Regional Laboratory, Nashik

8011en 31erec\_ 6 NO -2-Gr.-1895- 501



Cellaborators: International Schools in Environmental Management Studies 311, W. Callo-De-Ca-Ba-LL05, TEMPE, Acades- 85284 ② (001) (602) 6974732 Ernad : bsbhaskar/gyaluo.com

Dt. 15/02/2014

### STACK MONITORING REPORT

(Distillery Division)

Name of the Factory: Godawari Biorefinerics Ltd., Sakarwadi

Date of Stack Monitoring: 28/12/2013

| S. No | Parameter                             | Stack -I        | Stack - TO |
|-------|---------------------------------------|-----------------|------------|
| 1.    | Stack Height (m)                      | . 30            | 31         |
| 2.    | Stack Diameter (m)                    | 1.20            | 1.6        |
| 3.    | Boiler Capacity (T/hr.)               | 18.00           | 18.00      |
| 4.    | Boiler                                | Thermax         | ISGEC      |
| 5.    | Furnace type                          | Spreader Stoker | 1 87       |
| ú.    | Fuel Used                             | Coal. Bin-gas   | Coal       |
| 7.    | Fluc Gas Temp. (°C)                   | 142             | J21        |
| 8,    | Flue Gas Velocity (m/sec.)            | 8.10            | 7.98       |
| 9.,   | P.M. (mg/Nin <sup>3</sup> )           | 118,00          | 176        |
| 10.   | NO <sub>X</sub> (mg/Nm <sup>2</sup> ) | 79.00           | 74.00      |
| 11.   | SO <sub>2</sub> (mg/Nm <sup>2</sup> ) | X4.00           | 88.00      |

Water And Waste Water Research Centre

Sangli - (6233) 2301857, 2302664

Fax. (0233) 2302664 Mob. 9372109522; 9x50992118
- E-Mail: basubbaaao@yahoo..com, bashara@yahou.com
Pan No.: AAAFW 1498C

STC No.: AAAFW 1498CST001

REGD. OFFICE: "ARUNDHATT" Opp. Sahyogungar, Old Dhanni Ruad, Vishnanbag, Sangli - 416 415



CXILLABORATGRS: International Schools in Environment Management Studies
REGD. OFFICE: 'ARUNDHATI' Opp. Sahayograçar, Old Dhamani Road, Vishrambag, Sangli - 416-415.

Dt. 23/04/2014

#### ANALYSIS REPORT

Name of the Factory: Godawari Biorefineries Ltd., Sakarwadi. Date of sampling : 28/03/2014. Sample Description: Ground Water Samples.

| Sr.Nn. | Parameter                                  | Unit     | Well Near Dispensary<br>Well Water |  |
|--------|--------------------------------------------|----------|------------------------------------|--|
| 1.     | Color                                      |          | Colorless                          |  |
| 2.     | Odor                                       |          | Odorloss                           |  |
| - 3,   | рН                                         | -        | 7.78                               |  |
| 4.     | Turbidity                                  | NTU      | 0.4                                |  |
| 5.     | Total Dissulved Solids                     | mg/l     | 2312                               |  |
| 6.     | Electrical Conductivity                    | umhos/em | . 2920                             |  |
| 7.     | Total Hardness (us CaCO <sub>1</sub> )     | mg/l     | 1590                               |  |
| 8.     | Calcium Hordness (as CaCO <sub>3</sub> )   | mg/l     | 1635                               |  |
| 9.     | Magnesium Hardness (as CaCO <sub>3</sub> ) | mg/l .   | 262                                |  |
| 10.    | Calcium (as Ca)                            | 7mg/l    | 651                                |  |
| 11.    | Magnesium (as Mg)                          | mg/l     | 63                                 |  |
| 12.    | Total Alkatinity (as CaCO <sub>3</sub> )   | mg/l     | 425                                |  |
| 13.    | Chlorides (as CI)                          | mg/l     | 1051                               |  |
| 14.    | Sulphete (as SO <sub>4</sub> )             | mg/l     | - 68                               |  |
| 15.    | Total Nitrate (as NO <sub>3</sub> )        | nig/l    | 1.62                               |  |
| 16.    | Total Nitrogen (as N)                      | lagar    | < 0.5                              |  |
| 17.    | Total Phosphale (as POc)                   | mg/l     | <0.01                              |  |
| 18.    | Ammonical Nitrogen (us N)                  | ing/l    | < 0.01                             |  |

Sangti - (0233) 2301857, 2302664, Fax : (0233) 2302664, Mob. 9372109522, 9890992118 E-mail : bssubbarac@yaboc.com, bssharat@yaboc.com Pan No. : AAAFW 1498C, STC No. : AAAFW 1498CST001



COLLABORATORS: International Schools in Environment Management Studies
RECD. OFFICE: "ARUNDHAT!" Opp. Sahayognagar, Old Dhamani Road, Vishrambag, Sangli - 416 415.

| Sr.No. | Parameter                      | Unit        | Well Near Dispensary<br>Well Water |
|--------|--------------------------------|-------------|------------------------------------|
| 19     | Copper (as Cu)                 | тар/І       | < 0.01                             |
| 20.    | Manganese (as Mu)              | iag/l       | < 0.01                             |
| 21,    | Iron (us Fc)                   | rag/l       | 0.16                               |
| 22.    | Fluorido (as F)                | mg/l        | 0.53                               |
| 23.    | Cyanide (as CN)                | mg/l        |                                    |
| 24.    | Phanolic Compounds (as C6H5OH) | tng/l       | < 0.001                            |
| 25,    | Boron (as B)                   | mg/l        | < 0.05                             |
| 26.    | Zine (as Zn)                   | mg/l        | < 5                                |
| 27.    | Alominium (as Al)              | mg/l        | <0.03                              |
| 28.    | Cadminutt (us Cd)              | nig/l       | < 0.002                            |
| 29.    | Lead (cs Pb).                  | mg/l        | < 0.01                             |
| 30.    | Nickel (as Ni)                 | mg/l        | < 0.02                             |
| 31.    | Mercury (as Hg)                | 1 1/400     | < 0.001                            |
| 32.    | Arsenic (us As)                | mg/l        | < 0.001                            |
| 33.    | Selenium (as Se)               | mg/l        | < 0.001                            |
| 34.    | Sodium (as Na)                 | ng/l        | 196                                |
| 35.    | Polassium (as K)               | mg/l        |                                    |
| 36.    | Chemical Oxygon Demand         | mg/l·       | 788                                |
| 37.    | BOD 3days at 27oC              | mg/         | 27                                 |
| 18.    | Dissolved Oxygen               | mg/i        |                                    |
| 39.    | Total Cotrform Organisms       | Nos/100 ml  | Absent                             |
| 40.    | Faecal Culiform Organisms      | Nos/100 m.1 | Absent                             |

Sangli - (0233) 2301357, 2302664, Fax : (0233) 2302664, Mob. 9372109522, 9890992118 E-mail : basubbarao@yaboo.com, basharat@yaboo.com Pan No. : AAAFW 1498C, STC No. : AAAFW 1498CST001



COLLABORATORS: International Solocols in Environment Management Studies
REGD, OFFICE: "ARIINDHAIT" One, Sahayogatagar, Old Dhamani Ruad, Vishmunbag, Sangti - 416-415.

Dr. 23/04/2014

#### ANALYSIS REPORT

Name of the Factory : Godawari Biorefineries Ltd., Sakarwadi.

Date of sampling : 28/03/2014.

Sample Description: Ground Water Samples.

| Sr.No. | Parameter                                   | Unit      | Kanhegaon Railway Station<br>Well Water |
|--------|---------------------------------------------|-----------|-----------------------------------------|
| 1.     | Coln                                        | -         | Colorless                               |
| 2.     | Odor                                        | -         | Odoriess                                |
| 3.     | рН                                          | 1 -       | 7.78                                    |
| 1.     | Turbidity .                                 | NTU       | 0.6                                     |
| 5.     | Total Dissolved Solids                      | mg/1      | 1411                                    |
| 6.     | Electrical Conductivity                     | panhos/em | 1781                                    |
| 7,     | Total Hardness (as Ca(X) <sub>3</sub> )     | mg/I      | 1353                                    |
| 8.     | Calcium Hardness (as CaCO <sub>3</sub> )    | n:g/l     | 1070                                    |
| 9.     | Magnesium Hardness (as CcCO <sub>1</sub> )- | mg/l      | 283                                     |
| 10.    | Calcium (as Ca)                             | . mg/l    | 128                                     |
| 11.    | Magnesium (as Mg)                           | rng/l     | 68                                      |
| 12.    | Total Alkalinity (as CaCO <sub>3</sub> )    | mg/l      | 445                                     |
| 13.    | Chlorides (as CI)                           | mg/i      | 538                                     |
| 14.    | Sulphate (as SO <sub>4</sub> )              | . mg/!    | 57                                      |
| 15.    | Total Nitrate (as NO <sub>3</sub> )         | mg/l      | 0.75                                    |
| 16.    | Total Nitrogen (as N)                       | mg/l      | < 0.5                                   |
| 17.    | Total Phosphate (as PO <sub>4</sub> )       | mg/l      | <0).01                                  |
| 18.    | Ammonicai Nitrogen (as N)                   | mg/l      | < 0.01                                  |

Sangli - (0233) 2301857, 2302664, Fax : (0233) 2302664, Mub. 9372109522, 9890992118 B-mail: bambbaran@yahou.com, basharan@yahou.com Pan No. : AAAFW 1498C, STC No. : AAAFW 1498CST001



COLLABORATORS: International Solvools in Environment Management Studies
REGIL OFFICE: "ARUNDHATI" Opp. Salasyognagar, Old Dhamani Road, Vishrambag, Sangli - 416 415.

Dr. 23/04/2014

#### ANALYSIS REPORT

Name of the Factory: Godawari Riorefineries Ltd., Sakarwadi. Date of sampling: 28/03/2014.

Sample Description: Ground Water Samples.

| Sr.No. | Parameter                                  | Unit     | Hanumau Gate Arca<br>Handpump<br>Borewell Water |
|--------|--------------------------------------------|----------|-------------------------------------------------|
| 1.     | Colcr                                      | - 1      | Colorless                                       |
| 2.     | Odor '                                     |          | Odorless                                        |
| 3.     | pH .                                       |          | 8.10                                            |
| 4,     | Turbidity                                  | NIU      | 3.0                                             |
| 5.     | Total Dissolved Solids                     | mg/l     | 356                                             |
| 6.     | Electrical Conductivity                    | pmkos/em | 1079                                            |
| 7.     | Total Hardness (us CaCO <sub>3</sub> )     | mg/l     | 595                                             |
| S.     | Calcium Hantness (as CoCO;)                | mg/l     | 595                                             |
| 9.     | Magnesium Hardness (as CaCO <sub>1</sub> ) | mg/l     | 100                                             |
| lů.    | Calcium (as Ca)                            | nig/J    | 238                                             |
| 11,    | Magnesium (as Mg)                          | mg/l     | 21 —                                            |
| 12.    | Total Alkalinity (as CaCO <sub>3</sub> )   | mg/l     | 232                                             |
| 13.    | Calorides (us CI)                          | nig/l    | 161                                             |
| 14.    | Sulphate (as SQ <sub>2</sub> )             | mg/l     | 23                                              |
| 15.    | Total Nitrate (as NO:)                     | nug/1    | 0.83                                            |
| 16     | Total Nitrogen (as N)                      | mg/      | < 0.5                                           |
| 17.    | Total Phesphate (as PO <sub>4</sub> )      | mg/.     | <0.01                                           |
| 18"    | Ammonical Nitrogen (as N)                  | mg/i     | < 0.0[                                          |

Sangli - (0233) 2301857, 2302664, Fax : (0233) 2302664, Mob. 9372109522, 9890992118
E-mzil : besubbarao(gyaboo.com, basharat@yaboo.com Pan No. : AAAFW 1498C, STC No. : AAAFW 1498CST001



COLLABORATORS: International Schools in Environment Management Studies
REGD. OFFICE: "ARUNDHAT!" Opp. Sahayoguagar, Old Dhanemi Road, Vishrambag, Sangti - 416 415.

| ir.No. | Panuacter                      | Unit       | Hanuman Gate Area<br>Handpump<br>Borewell Water |
|--------|--------------------------------|------------|-------------------------------------------------|
| .9.    | Copper (as Cu)                 | fgm        | < 0.01                                          |
| 20,    | Manganese (as Mn)              | mg/l       | < 0.01                                          |
| 21.    | Iron (as Fe)                   | ng/l       | 0.07                                            |
| 22.    | Fluoride (as F)                | mg/l       | 0.28                                            |
| 23.    | Cyanide (us CN)                | Lea        | Nil .                                           |
| 24. ,  | Phonolic Compounds (as C6H5OH) | mg/l       | . < 0.001                                       |
| 25.    | Boron (as B)                   | mgd        | < 0.05                                          |
| . 26.  | (nX sk) aniX                   | ing/l      | < 5                                             |
| 27.    | Aluminium (as Al)              | mg/l       | <0.03                                           |
| 28.    | Cadmium (as Cd)                | Fgm        | < 0.002                                         |
| 29.    | Lead (as Pb)                   | mg/l       | < 0.01                                          |
| 30.    | Nickel (as Ni)                 | mg/l       | < 0.02                                          |
| 35.    | Meroury (as Hg)                | ng1        | < 0.001                                         |
| 32.    | Atsenie (as As)                | Pgm        | < 0.001                                         |
| 33.    | Selection (as So)              | mg/l       | < 0.01                                          |
| 34.    | Sodium (as Na)                 | ngl        | 75 -                                            |
| 35.    | Potassium (as K)               | mg/l       | 0.9                                             |
| 36.    | Chemical Oxygou Demand         | mg/l       | 104                                             |
| 37.    | BOD 3days at 27oC              | mog/l      | 15                                              |
| 38.    | Dissolved Oxygen               | l'yar      | 6.1                                             |
| 39,    | Total Coliform Organisms       | Nos/100 mt | Absent                                          |
| 40,    | Faecal Coliform Oceanisms      | Nos/100 mt | Absent                                          |

Sangti - (0233) 2301857, 2302664, Fax : (0233) 2302664, Mab. 9372109522, 9890992118 E-mail : hembbarao@yalloo.com, besharao@yalnoo.com Pan No. : AAAFW 1498C, STC No. : AAAFW 1498CST001



COLLABORATORS: International Schools in Environment Management Studies
REGD. OFFICE: "ARUNDHATF" Opp. Safrayognagar, Old Dharnani Road, Vishrambag, Sanghi - 416 415.

Dt. 23/04/2014

### AMBIENT AIR QUALITY REPORT

Name of the Factory: Godawari Biorefineries Ltd., Sakarwadi

Date of Ambient Air sampling: 28/03/2014

| Sr. Sampling Statio | P.M <sub>7,5</sub> (μg/m <sup>3</sup> ) | P.M <sub>111</sub> (µg/m <sup>3</sup> ) | SPM (µg/m³)        | NO <sub>X</sub> (µg/m³) | SO <sub>2</sub><br>(ug/m <sup>3</sup> ) |
|---------------------|-----------------------------------------|-----------------------------------------|--------------------|-------------------------|-----------------------------------------|
| 1. Main Gate        |                                         | 65                                      | - <sub>195</sub> - | 27.00                   | 11.00                                   |
| 2. Guest house      | 14                                      | 40                                      | 155                | 12.00                   | 09,00                                   |

Sangh - (0233) 2301857, 2302664, Fox : (0233) 2302664, Mob. 9372109522, 9890992118 E-mail : hssubbarao@yahoo.com. bssharat@yahoo.com. Pap No. : AAAFW 1498C, STC No. : AAAFW 1498CS17001



COLLABORATORS: International Schools in Environment Management Studies
REGD, OFFICE: "ARUNDHATI" Opp. Sahayognagar, Old Dhamani Road, Vishrambag, Sangli - 416 415.

Dt. 23/04/2014

### NOISE LEVEL MEASUREMENT REPORT (OUTSIDE FACTORY)

Name of the Factory : Godawari Biorefineries Ltd., Sakarwadi.

Date of Noise level measurement : 28/03/2014.

| Sr. No. | Location of recording Sound level         | dB (A) Leq<br>(Day time) | dB (A) Leq<br>(Night time) |
|---------|-------------------------------------------|--------------------------|----------------------------|
| 1       | Main Gate                                 | 51.7                     | 49.0                       |
| 2       | Main Gate (Road Side)                     | 49.9                     | 45.0                       |
| 3       | CD Type Colony                            | 54.3                     | 36.9                       |
| 4       | Survey No. 2                              | 48.3                     | 37.0                       |
| 5       | Back Side of Biogas Plant                 | 49.9                     | 35.0                       |
| 6       | Biogas Plant Gule                         | 54,6                     | 41.0                       |
| 7       | Guest House                               | 36.2                     | 32.9                       |
| 8       | Gandhi Maidan (Back side of Ganesh Singe) | 36.6                     | 32.9                       |

Sangli - (0233) 2301857, 2302664, Fax : (0233) 2302664, Mob. 9372109522, 9890992118 E-mail : bssubbarao@yuhon.com, bsaharat@yahon.com Pan No. : AAAFW 1498C, STC No. : AAAFW 1498CST001



COLLABORATORS: International Schools in Environment Management Studies
REGD, OFFICE: "ARUNDHATI" Opp. Sahayognagar, Old Dhamani Road, Vishrambag, Sangli - 416 415.

Dt. 23/04/2014

#### ANALYSIS REPORT

Name of the Factory: Godawari Biorefineries Ltd., Sakarwadi.

(Distillery Unit)

Date of sampling: 28/03/2014. Sample Description: Soil Sample.

| Sr. No | Parameter       | Unit       | Rupali Sham Jadhav<br>Gat No. 432/1 & 432/5 Wari,<br>Tq.: Kopergaon, Dist: Ahmednagar |
|--------|-----------------|------------|---------------------------------------------------------------------------------------|
| 1.     | pH              |            | 7.64                                                                                  |
| 2.     | Conductivity    | mmhos/cm   | 0.852                                                                                 |
| 3.     | Ava. Nitrogen   | kg/hectare | 220                                                                                   |
| 4.     | Ava. Phosphorus | kg/hectare | 68                                                                                    |
| 5.     | Ava. Potassium  | kg/hectare | 982                                                                                   |
| 6.     | Org. Carbon     | %          | 1.02                                                                                  |
| 7.     | Sodium          | %          | 0.090                                                                                 |
| 8.     | Calcium         | %          | 0.460                                                                                 |
| 9.     | Magnesium       | %          | 0.084                                                                                 |
| 10     | C.E.C           | meq/100gm  | 29.28                                                                                 |
| 11     | Grade           | les.       | B                                                                                     |

Water And Waste Water Research Centre

Partner

Sangli - (0233) 2301857, 2302664, Fax : (0233) 2302664, Mob. 9372109522, 9890992118



COLLABORATORS: International Schools in Environment Management Studies REGD. OFFICE: "ARUNDHATI" Opp. Sahayognagar, Old Dhamani Road, Vishrambag, Sangli - 416 415.

Dt. 23/04/2014

#### ANALYSIS REPORT

Name of the Factory: Godawari Biorefineries Ltd., Sakarwadi.

(Distillery Unit)

Date of sampling: 28/03/2014. Sample Description: Soil Sample.

| Sr. No | Parameter       | Unit       | Subhash Anandrao Teke<br>Gat No. 134/141 Doangoan/<br>Wari,<br>Tq.: Kopergaon, Dist:<br>Ahmednagar |
|--------|-----------------|------------|----------------------------------------------------------------------------------------------------|
| 1.     | pH              | 4122       | 8.14                                                                                               |
| 2.     | Conductivity    | mmhos/em   | 0.356                                                                                              |
| 3.     | Ava. Nitrogen   | kg/hectare | 198                                                                                                |
| 4.     | Ava. Phosphorus | kg/hectare | 42                                                                                                 |
| 5.     | Ava. Potassium  | kg/hectare | 248                                                                                                |
| 6.     | Org. Carbon     | %          | 1.05                                                                                               |
| 7.     | Sodium          | %          | 0.074                                                                                              |
| 8.     | Calcium         | %          | 1.006                                                                                              |
| 9.     | Magnesium       | 9/0        | 0.116                                                                                              |
| 10     | C.E.C           | meq/100gm  | 26.06                                                                                              |
| 11     | Grade           |            | В                                                                                                  |

Water And Waste Water Research Centre



Sangli - (0233) 2301857, 2302664, Fax: (0233) 2302664, Mob. 9372109522, 9890992118

#### 4.SUMMARY

- 1. Godavari Biorefineries Limited is situated at Sakarwadi, Kopargaon (Tq), Ahmednagar (Dist). It has existing chemical units i.e. Acetaldehyde, Acetic Acid, Dilute Acetic Acid and Ethyl Acetate of following capacities i.e. Acetaldehyde= 1500MT/M, Acetic Acid= 1500MT/M, Dilute Acetic Acid = 110MT/M, Ethyl Acetate= 5400MT/M and it is proposed to De-bottle neck the capacity of these units i.e. Acetaldehyde= 2100MT/M, Acetic Acid= 1950MT/M, Dilute Acetic Acid = 143MT/M, Ethyl Acetate= 8700MT/M.
- 2. The industry provided the treatment of effluent of acetaldehyde based on Biomethanation, followed by Reverse Osmosis & bio-composting. There is no effluent generated from Ethyl Acetate and Acetic Acid plants. The Dilute Acetic Acid from Acetic acid is sold in open market. It is proposed to follow the existing treatment plant method of anaerobic digestion followed by RO and Bio-composting even after expansion for the treatment of acetaldehyde effluent.
- 3. The industry has 194.0 hectares of land out of which 7.2 hectors is utilized for all plants.
- 4. The steam requirement for the expansion shall be met from the existing 2 nos. of Boiler of 18TPH each using Coal as fuel. At present 149T/day of indigenous coal is used. It is proposed to use imported coal as fuel for the generation of steam after expansion. The imported coal has calorific value of 5600Kcal/kg whereas the indigenous coal which is at present used has a calorific value of 4375Kacla/kg. **Thus the requirement of coal even after expansion would remain same.** Further, there would not be any increase in stack emissions and in fact the air emission will get reduced as the ash content in imported coal is not more than 12%, whereas in indigenous coal it varies from 30-35%. Thus there is overall improvement of Environment status of surrounding area.
- 5. There will not be any increase in water requirement as it is proposed to have a complete water recycle/arrangement system. The permeate of RO shall be used as make up water for cooling towers.
- 6. The existing effluent treatment plant facilities of anaerobic digester followed by Biocomposting shall be adequate as there is no increase in effluent quantity after expansion.

- 7. The manufacturing process of chemical plants are enclosed.
- 8. The water budget details are given.
- 9. The 10 km radius map of the surrounding villages is given, with the details of Environmental status.
- 10. The total project cost is estimated as 20.99 corers